

**SAN ANTONIO WATER SYSTEM**  
**Van Dyke Service Center Standing Seam Metal Roof Replacement Project**  
**SAWS Job No. 14-0105**  
**Solicitation No. B-14-055-RA**

**ADDENDUM NO. 3**

**July 25, 2014**

This addendum, applicable to project noted above, is an amendment to the bidding and specification documents and as such shall be a part of and included in the Contract. Acknowledge receipt of this addendum by entering the addendum number and issue date in the spaces provided on all submitted copies of the proposal.

**1.0 Addendum Purpose**

Answers to Questions:

- 1. We noticed that this project is up for re-bid. We decline the bid last time because it was a Butler system. Do you require a Butler SSR?**

*A: Page – PR-1 – paragraph # 3 indicates "Double-Loc" roof panel or equivalent," Double-Loc" is a MBCI standing seam roof system.*

- 2. I am interested in bidding this re-roofing project. Will I be able to visit the site to look at the logistics of the existing structure.**

*A: A non-mandatory site visit was held July 22, 2014 at 10:00 a.m. (CT) as noted in Addendum No. 1 posted to the SAWS website July 15, 2014.*

- 3. Please confirm the carport canopy and the metal siding will not be part of this scope of work.**

*A: The project does not include the detached carport or the metal addition to the main building.*

- 4. Are there any specs for the structural purlins to aid in accurately bidding a price/foot?**

*A. Specifications were not provided for existing materials. Building construction drawings were included. Found structural purlin referred to as a Hat Channel.*

Addendum No. 3  
Van Dyke Service Center Standing Seam Metal Roof Replacement Project  
SAWS Job No. 14-0105  
Solicitation No. B-14-055-RA

**ACKNOWLEDGEMENT BY BIDDER**

Each bidder is requested to acknowledge receipt of this Addendum No. 3 and the associated attachments by his/her signature affixed hereto and to file same and attach with his/her bid.

The undersigned acknowledges receipt of this Addendum No. 3 along with the bid submitted herewith is in accordance with the information and stipulations set forth.

---

Date

---

Signature

END OF ADDENDUM NO. 3