


**ADDENDUM NO. 3**  
**to**  
**PLANS and SPECIFICATIONS**  
**for**

**Medina River Sewer Outfall, Segment 3**  
**SAWS Job No. 11-2504**

**Issue Date: October 11, 2011**



**SAN ANTONIO WATER SYSTEM  
MEDINA RIVER SEWER OUTFALL, SEGMENT 3  
SAWS PROJECT # 11-2504  
ADDENDUM NO. 3**

**October 12, 2011**

This addendum, applicable to the project noted above, is an amendment to the bidding and specification documents and as such shall be a part of and included in the Contract. Acknowledge receipt of this addendum by entering the addendum number and issue date in the spaces provided on all submitted copies of the proposal.

**1.0 Addendum Purpose**

The purpose of this addendum is to issue revisions and clarifications for the Medina River Sewer Outfall (MRSO), Segment 3 (SAWS Job No. 11-2504).

**2.0 Plans**

- A. Drawing No. C-63, Sheet No. 31 – Revise the callout for the Siphon Barrels to read: 1-42” Barrel (FRP, SN-72), 1-36” Barrel (FRP, SN-72), 1-12” Barrel (FRP, SN-72), and 1-30” Air Bypass Pipe. Note: The 12” Siphon Barrel can also be 12” (PVC, SDR 26)

Addendum No. 3  
Medina River Sewer Outfall, Segment 3  
Saws Project # 11-2504  
October 7, 2011

**ACKNOWLEDGEMENT BY BIDDER**

Each bidder is requested to acknowledge receipt of this Addendum No. 3 and the associated attachments by his/her signature affixed hereto and to file same and attach with his/her bid.

The undersigned acknowledges receipt of this Addendum No. 3 along with the bid submitted herewith is in accordance with the information and stipulations set forth.

---

Date

---

Signature

END OF ADDENDUM NO. 3

P:\68\66\00\12.0 Bidding Phase\Segment 3 (11-2504)\ADDENDUM 3\111006-Addendum 3 .doc