

**SAN ANTONIO WATER SYSTEM
WATER SYSTEM CONSTRUCTION
Addendum No. 1**

**To
Plans and Specifications
For**

**Job No. 08-4501: Wastewater Collection System Small Main Repairs at Focus Areas
Solicitation No. B-09-075-CM**

January 5, 2010

To Bidder of Record:

This addendum, applicable to the work specified above, is an amendment to the bidding documents and as such shall be a part of and included in the Contract. The original contract documents and any prior addenda remain in full force except as modified by the following, which shall take precedence over any contrary provisions in prior documents.

- A. Please note the following clarifications if using the bid documents from the website:
1. Bid Item SP1 in the Bid Proposal refers to Special Provision, Internal CIPP Point Repair of Pipelines.
 2. SS-1, Special Specification 4438, Flowable Backfill is made part of SC-1, Special Conditions.
 3. These clarifications to the bid documents on the website are consistent with the bid documents on the compact disk (CD).
- B. Response to questions.
- Q1. Is flowable fill required for backfill?
A1. Yes, in all paved areas. See Special Conditions for more detail.
- Q2. Is SAWS handling ROW permits?
A2. Yes. See Special Conditions for more detail.
- C. Delete the sentence: "The couplings shall be encased in concrete." from the fifth paragraph on Page SC-2, Special Conditions, SC-6: Point Repair.

Peter Lai, P.E.
Project Engineer
RJN Group, Inc.



The undersigned acknowledges receipt of this Addendum No. 1 and the bid submitted herewith is in accordance with the information and stipulation set forth.

Date

Signature of Bidder

END OF ADDENDUM