



**SAN ANTONIO WATER SYSTEM
 STEIN TO SALADO INTERCONNECTION DSP PROJECT
 JOB # 12-7210
 Solicitation No. B-12-060-MR
 ADDENDUM NO. 2**

October 15, 2012

This addendum, applicable to work designed above, is an amendment to the bidding and specification documents and as such shall be a part of and included in the Contract. Acknowledge receipt of this addendum by entering the addendum number and issue date in the spaces provided on all submitted copies of the bid.

1.0 RESPONSES TO QUESTIONS:

Q1. Is the clearing for this job part of our scope or is it provided by SAWS?

A1. Any clearing for this project shall be paid under SAWS bid Item 101 – Preparing Right of Way.

2.0 TO PROVIDE CLARIFICATION :

1. Any Steel pipe called out on this project shall be Grade 80, 200 psi. Steel pipe to be coated as per SAWS Specification 816 Steel Pipe. Valves on steel pipe shall be Ductile Iron with ANSI 125 drillings. All bends, valves, meters, appurtenances, etc. for the steel pipe shall be 250 psi with ANSI 125 drillings.

2. Electrical drawings E1-E13 scales reflect 11“ x 17” print size.



10-15-12

ACKNOWLEDGEMENT BY BIDDER

Each bidder is requested to acknowledge receipt of this Addendum No. 2 by his/her signature affixed hereto and to file same and attach with his/her bid.

The undersigned acknowledges receipt of this Addendum No. 2 along with the bid submitted herewith is in accordance with the information and stipulations set forth.

_____ Date

_____ Signature

END OF ADDENDUM NO. 2 – (1 page)