

SAN ANTONIO WATER SYSTEM

SAWS Desalination Production Well
Construction Services – Package I
Wells BGD 1-4
Job No. : 10-8610
Solicitation No.: B-11-022-DD

Addendum No.: 3
July 15, 2011

To the Respondent of Record:

This Addendum, applicable to work designed above, is an amendment to the bidding documents and such will be a part of and included in the Contract. Acknowledge receipt of this Addendum by the entering the Addendum number in the space provided in submitted copies of the Price Proposal.

A. CLARIFICATIONS

1. Excavated material from Water Storage Reservoir C can be stock piled or spread in the area designated on Drawing C-6.0. Excavated material from Water Storage Reservoir A and Pond B can be stock piled or spread in areas located within about 500 feet of the excavations, as acceptable to SAWS and the ENGINEER. All outfall pipe locations will be staked at the job site when construction begins.
2. Drawings C-26.0, C-27.0 and C-29.0 show cement stabilized base material on the approaches to the culvert crossings. The cement stabilized base material shall extend a combined total of 150 feet in the two directions of the road approach and the lengths will be staked in the field prior to cement stabilized base installation.
3. The Geotechnical Report prepared by Arias & Associates, Inc. is available on the SAWS website as supplemental information only. The link is as follows: http://www.saws.org/business_center/contractsol/Drill.cfm?id=234&View=Yes. Possible chip seal discussed in the report is not a part of this project.

B. Division 0 - BIDDING AND CONTRACT REQUIREMENTS

1. Section IV-1 – Invitation for Competitive Sealed Proposals: Paragraph 5, Delete “10 am, July 22, 2011” and replace with “10 am, July 27, 2011”.

ACKNOWLEDGEMENT BY RESPONDENT

Each Respondent shall acknowledge receipt of this Addendum in the space provided in the Price Proposal.

July 15, 2011
LBG-Guyton Associates
TBPE No. F-4432

AD-1

