

# SAN ANTONIO WATER SYSTEM

**SAWS Desalination Production Well  
Construction Services – Package I  
Wells BGD 5-8  
Job No. : 10-8610  
Solicitation No.: B-11-036-DD**

---

**Addendum No.: 2  
February 13, 2012**

To the Respondent of Record:

This Addendum, applicable to work designed above, is an amendment to the bidding documents and such will be a part of and included in the Contract. Acknowledge receipt of this Addendum by the entering the Addendum number in the space provided in submitted copies of the Price Proposal.

**A. CLARIFICATIONS**

1. The height and method of construction for the sound barriers to be constructed at BGD-5 and BGD-6 is specified in Section 01500, Paragraph 3.04 on Page 01500-10.
2. The maximum pilot hole diameter is 9.875 inches as specified in Section 02634, Paragraph 3.03.A.
3. The surface casing cannot be cemented by tremmie pipe. The casing shall be cemented in place using the Halliburton cementing method as specified in Section 02634, Paragraph 3.09.H.
4. A cement bond log is not required for the 16-inch surface casing.
5. A Section Gauge Log is equivalent to a Caliper Log.
6. The stainless steel production casing can be plain end beveled.

**B. Division 1 – GENERAL REQUIREMENTS**

1. Section 01270 – MEASUREMENT AND BASIS OF PAYMENT: Page 01270-8, Delete the words “and casing pressure testing” from the last sentence of Paragraph 3.

**C. Division 2 – SITE WORK**


1. Section 02633 – WELL DRILLING AND TESTING, GENERAL: Page 02633-7, Delete Paragraph 1.04.O. in its entirety.

---

**ACKNOWLEDGEMENT BY RESPONDENT**

Each Respondent shall acknowledge receipt of this Addendum in the space provided in the Price Proposal.

February 13, 2012  
LBG-Guyton Associates  
TBPE No. F-4432



*William J. Seifert, Jr.*  
2/13/12