



**REQUEST FOR QUALIFICATIONS**  
**Solicitation Number: Q-11-016-MR**

**Naco Pump Station Improvements Project**  
**SAWS Job No. 12-6003**

**ADDENDUM #1 – 04:50 PM Central | January 3, 2012**

This addendum provides answers to questions submitted by 4:00 PM December 30, 2011.

**ANSWER TO QUESTIONS**

1. Is SAWS planning to install a surge protection system for the pump station? If so, has a transient analysis been done that defines what the proposed surge protection system will be or is the analysis to be done as part of the project?
  - a. SAWS is not planning to install a surge protection system for the pump station. A transient analysis will not be part of the scope of work.
  
2. The proposed work scope seems to infer that a new chlorine building will be required to provide storage of chlorine cylinders, chemical dosing equipment, and dry scrubbers. Is it necessary for this building to meet a particular architectural theme?
  - a. SAWS does not have a particular architectural theme for buildings at this time.
  
3. In response to SAWS Solicitation Number G-11-016-MR / Job No. 12-6003 for the Naco Pump Station - Are all team firms required to submit separate Litigation Disclosure forms or only the prime? Please clarify.
  - a. Only the prime firm is required to complete this form.

**END ANSWERS TO QUESTIONS**

No other items, dates, or deadlines for this RFQ are changed.

END ADDENDUM #1