



SAN ANTONIO WATER SYSTEM
NORTHWEST SERVICE CENTER FACILITY – FUEL DISPENSING FACILITIES DEMOLITION
SAWS Job No. 14-0123
SAWS Solicitation No. CO-00037-JG

ADDENDUM NO. 1
April 7, 2016

To Respondent of Record:

This addendum, applicable to work referenced above, is an amendment to the bidding documents and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the addendum number and issue date in the space provided in submitted copies of the proposal.

A. Modifications to the Specifications

1. Special Conditions – Replace Item 4.0 as follows:

“4.0 Building and Site Permits: The Northwest Service Center is located within the City of Leon Valley and the proposed facility and improvements are subject to the City of Leon Valley Site and Bexar County Building **Permit for Fuel Tank Removal** requirements. **The CONTRACTOR is responsible for obtaining the Fuel Tank Removal Permit from the Bexar County Fire Marshall as part of the Work.**”

B. Modifications to the Drawings

1. Sheet C-03 - Revise Note 4 as follows:

“4. Remove material to 3-feet below the bottom of the storage tank foundation **within the denoted limits of the sawcut excavation extent surrounding the fuel storage tanks.**”

Stephanie Sue

Stephanie Sue, P.E.
Project Manager
ARCADIS U.S., Inc.
TBPE Firm No. F-533



END OF ADDENDUM