

**SAN ANTONIO WATER SYSTEM  
WATER SYSTEM CONSTRUCTION**

**Addendum No. 2**

To Specifications For

**2016 Annual Sanitary Sewer Manhole Adjustment, Rehabilitation and Replacement  
Construction Contract, Package 3**

**SAWS Job Nos. 16-0116 (O&M) and 16-1403 (CIP)**

**Solicitation No. CD-B-16-011-SM**

To Bidder of Record:

This addendum, applicable to the work associated with the above referenced Contract, is an amendment to the bidding documents and as such shall be a part of and included in the Contract. The original contract documents and any prior addenda remain in full force except as modified by the following, which shall take precedence over any contrary provisions in prior documents. Acknowledge receipt of this addendum by entering the addendum number and issue date in the space provided in submitted copies of the proposal.


**Questions and Answers:**

*Question 1: Per the addendum for SAWS' project C-13 Broadway Corridor - Package 1.C and 3.C, I would like to ask that the same Technical Specifications be included for the upcoming Annual Sanitary Sewer Manhole projects (Package 1, 2, 3, and 4).*

*Answer 1: APM MS-10,000 with ConShield Biotech Armor, applied at the required one inch thick application, is included as an approved product which does not require a subsequent epoxy coating.*

*Question 2: Will SAWS consider allowing Quadex Aluminaliner PF or Quadex GeoKrete products for manhole and structure coatings as alternatives to the specified Kerneos SewperCoat with a single 1" application thickness?*

*Answer 2: No. Neither Quadex Aluminaliner PF nor Quadex GeoKrete are approved materials.*



*Jerome A. Iltis*  
6/21/16

*Jerome A. Iltis*  
Jerome A. Iltis, P.E.

**END OF ADDENDUM NO. 2**