



**SAN ANTONIO WATER SYSTEM  
HIGHLAND ESTATES, UNIT 1 P.U.D. MONTANA PASS FLOATING GROUND  
STORAGE TANK PROJECT**

**SAWS JOB NUMBER 15-1177  
SOLICITATION NO. CO-00092**

**ADDENDUM NO. 8  
October 24, 2016**

**To Bidder of Record:**

This addendum, applicable to work referenced above, is an amendment to the bidding documents and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the addendum number and issue date in the space provide in submitted copies of the proposal.

**Clarifications:**

1. Flanges on steel pipe will be allowed where called out on plans and as required by specifications. Flanges shall be welded at the factory.
2. Field welded joints are permitted. Refer to SAWS Standard Specification Item No. 816 Steel Pipe Installation for direction on field applied protective coatings requirements.
3. Interior and exterior coating of the steel pipe shall conform to SAWS Standard Specification Item No. 816 Steel Pipe Installation.

**END OF ADDENDUM 8**

This Addendum, is one (1) page in its entirety.

