



**SAN ANTONIO WATER SYSTEM  
CENTRAL SEWERSHED PACKAGE 3**

**SAWS Job No. 17-4528  
SAWS Solicitation No. CO-00139**

**ADDENDUM NO. 2  
September 28, 2017**

**To Bidder of Record:**

This addendum, applicable to work referenced above, is an amendment to the bidding documents and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the addendum number and issue date in the space provided in the bid proposal.

**Addition to the Special Provisions of the Technical Specifications:**

Add the following:


- L. Revision to SAWS Standard Specification 901 Rehabilitation of Sanitary Sewer by Cured-In-Place Pipe (Hot Water or Steam Cured)

901.1 DESCRIPTION: Add the following:

This project shall utilize water inversion and hot water curing.

All other language in this specification 901 remains in full force.

This Addendum is one (1) page in its entirety.

  
\_\_\_\_\_  
Carl Bain, P.E.  
Bain Medina Bain, Inc.  
TBPE Registration No: F-1712



**END OF ADDENDUM NO. 2**