



**SAN ANTONIO WATER SYSTEM
CENTRAL WATER INTEGRATION PIPELINE
SEGMENT 5-4
SAWS Job No. 18-8614
SAWS Solicitation No. CO-00182**

**ADDENDUM No. 3
November 7, 2018**

To Bidder of Record:

This addendum, applicable to work referenced above, is an amendment to the bidding documents and as such will be made a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the addendum number and issue date in the space provided in submitted copies of the proposal.

CLARIFICATIONS

1. None.

QUESTIONS AND ANSWERS

1. See Questions and Answers sheet provided as attachment to this Addendum.

The remainder of the bid documents remain unchanged.

This addendum is comprised of a total of 2 pages (including attachments).

A handwritten signature in blue ink that reads 'Mark W. Bush'.

Mark W. Bush, P.E.
Tetra Tech, Inc.



11-07-2018

END OF ADDENDUM No. 3

Project: Central Water Integration Pipeline Segment 5-4 Project			Solicitation No.: CO-00182
Question and Answer Form			Job No.: 18-8614
Question No.	Received	Questions	Answer
20	11/1/2018	Please confirm the casing spec is 0.625" thickness. The normal SAWS spec is 0.438" for 42", unless it's a railroad crossing.	Revised per Addendum No. 2
21	11/1/2018	Bore Log BA-3 only goes to 15' deep, but the bore work pit is about 34'. Will the engineer provide any other geotech for this?	No additional geotech work will be provided.
22	11/1/2018	Is liner plate an acceptable alternative to casing?	Liner plate is not acceptable to SAWS for this application.
23	11/2/2018	Please clarify the materials, pressure class, approved manufacturers, and model for the Combination Air valves. SAWS Standard Spec is too broad to be used as the only guideline.	SAWS Material Standard Specification (29-01) is available on the SAWS website, which includes the necessary information.
24	11/5/2018	The above project requires for us to turn in a company packet. I looked in the specifications and didn't see it. Would you please let me where I could find it?	Refer to Supplemental Conditions, Instructions to Bidder, Section 24 regarding the items that are to be included in the company information packet. As stated in Addendum 1, there is no template or standard format as long as the information that is being requested is provided.
25	11/5/2018	Electrofusion Fittings are not available for the 30" HDPE DIPS Pipe what is the alternative at this point if fittings are needed?	SAWS does not accept butt fused fittings. If fittings are required, they must meet the requirements of Specification Section 15060, Paragraph 2.02.