



**Steven M. Clouse Water Recycling Center Perimeter Fence
Solicitation Number: B-19-017-AT
Job No.: 19-0132**

**ADDENDUM 4
September 11, 2019**

To Bidder of Record:

This addendum, applicable to work referenced above, is an amendment to the bid proposal, plans and specifications and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the Addendum number and issue date on the space provided in submitted copies of the bid proposal.

RESPONSES TO QUESTIONS

1. Question 1

Will a full time superintendent be required at the jobsite at all times?

Response: Yes

2. Question 2

Will SS40 high tensile pipe be allowed as an alternate to the schedule 40 pipe in the specifications? SS40 pipe has a higher tensile 50kpsi strength in lieu of 30kpsi schedule 40 pipe & is more readily available & more cost effective compared to import schedule 40 pipe.

Response: Pipe shall be as specified.

3. Question 3

Is the mow -strip at the drainage channel area's going to be just laid on top & doweled into the existing concrete drainage ?

Response: Where mow-strip meets side of channels will be level with channel and doweled into side of channels existing concrete.

4. Question 4

If a contractor is awarded both of these jobs, is it possible that they could have the same start date? And if they do would they both have to be done within the same 60 day time frame?

Response: SAWS would work with awarded Contractor to establish NTP dates for projects. The timeline for the projects would be within the same time frame.

5. Question 5

Will there be an extension to the submittal deadline date and time?

Response: Yes. Please reference Addendum 02, posted to the SAWS website on Monday, September 9, 2019, for the new date and time.

6. Question 6

Is the SMWVB 20% goal mandatory?

Response: This is an aspirational goal set aside by SAWS. It is not mandatory, however, we ask prime contractors to do their best with good faith outreach efforts. If the goal is not met, proof of outreach efforts is required with the submittal. Please reference the PowerPoint presentation (Page 8, "Good Faith Effort Plan (GFEP) FAQs)) provided with the solicitation documents for additional information.

7. Question 7

Is that the plan sheet with the bid, or will a new one be given?

Response: Signed and sealed Specifications, which include fencing plan sheets were posted as part of Addendum 2 on September 9th.

8. Question 8

Will there be specifications for a roll gate?

Response: No Cantilever slide gate is included in this project.

9. Question 9

Are there utilities underground?

Response: Yes

10. Question 10

Will Water be available on site and easily accessible?

Response: SAWS will provide a water source for project. Contractor responsible for any transport of water.

11. Question 11

Are Permits required for this Project?

Response: No

12. Question 12

Can Baseline Schedule be done on Excel Spreadsheet?

Response: Yes

13. Is line post concrete footings 12 Inch diameter?

Response: Concrete footings shall be 18" as specified.

END OF ADDENDUM

This Addendum is three (3) page(s) in its entirety.