



**2020 Annual Water Distribution Leak Repairs Contract, Package IV
Solicitation Number: B-19-028-AT
Job No.: 20-0111**

**ADDENDUM 2
October 23, 2019**

To Bidder of Record:

This addendum, applicable to work referenced above, is an amendment to the bid proposal, plans and specifications and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the Addendum number and issue date on the space provided in submitted copies of the bid proposal.

CLARIFICATIONS

1. Regarding Line Item 200: Flexible Base:
Description: Construct a base course for surfacing, pavement, or other base courses composed of crushed stone, and constructed as herein specified in one or more courses in conformance with the typical sections shown on the plans and to the lines and grades as established by the Engineer.

END OF ADDENDUM

This Addendum is one (1) page in its entirety.

Adam E. Aranda
San Antonio Water System



Adam E. Aranda
10/23/19