



CENTRAL SEWERSHED PACKAGE 14 – CIPP (LD)
Solicitation Number: CO-00524
Job No.: 20-4510

ADDENDUM 2
March 8, 2022

To Bidder of Record:

This addendum, applicable to work referenced above, is an amendment to the bid proposal, plans and specifications and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the Addendum number and issue date on the space provided in submitted copies of the bid proposal.

CLARIFICATIONS

1. Peak wet weather flows have been provided in the project bypass pumping plans. The flow information was provided by SAWS master planning team for the corresponding segments to be rehabilitated. The Contractor is advised to follow the bypass pumping General Notes on Plan Sheet Gen-03 and requirements stated in Specification 864 Large Diameter Bypass Pumping for Sanitary Sewer bypass pumping requirements. Alternatives to the required Bypass pumping system for all phases of the project shall be in compliance with Specification 864 Large Diameter Bypass Pumping for Sanitary Sewer.
2. Concurrent bypass pumping of the parallel sewer pipes is not directed in the plans. The contractor can rehabilitate one large sewer pipe at a time while bypass pumping the flow of the other sewer pipe. The contractor can adopt an approach that best suits their respective construction activities while ensuring that the sewer flow in the sewer pipe to be rehabilitated is bypassed at all times.

END OF ADDENDUM

This Addendum is one page with no attachments.

Attachments: None



Kajuluri 03-08-2022

Veerabhadra R. Kajuluri
WESTON SOLUTIONS, INC.
Texas Registered Engineering Firm F-3123
70 N.E. Loop 410, Suite 200
San Antonio, Texas 78216
210-308-4300 • Fax 210-308-4329