



**East Houston St. Pump Station Disinfection System
Solicitation Number: CO-00546**

Job No.: 21-6002

**ADDENDUM 5
September 6, 2022**

To Bidder of Record:

This addendum, applicable to work referenced above, is an amendment to the bidding documents and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the addendum number and issue date in the space provided in the submitted bid proposal.

CLARIFICATION

All required information for the new Chemical Building Structural Steel Canopy and Analyzer Canopy Per Structural Drawings (S-1 thru S-11) and Division 5 of the Specifications and SAWS confirms that it shall be constructed using Hot Dipped Galvanized High Strength steel, and Galvanized steel roof decking with 316 Stainless Steel anchors and hardware.

END OF ADDENDUM 5

This Addendum, including this one (1) page.