



Gallagher Tract 16" Water Extension Project
Solicitation Number: CO-00610
Job No.: 22-1001

ADDENDUM 1
December 2, 2022

To Bidder of Record:

This addendum, applicable to work referenced above, is an amendment to the bid proposal, plans and specifications and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the Addendum number and issue date on the space provided in submitted copies of the bid proposal.

RESPONSES TO QUESTIONS

1. Question: Can we use 16" DI pipe in lieu of 16" PVC?

Response: 16" DI pipe is acceptable and has been added. See #1, Changes to the Specifications, with a revised bid proposal to include the option to provide pricing for 16" DI pipe or 16" PVC.

2. Question: May 16" PC250 ductile iron pipe be considered as an equal to the 16" DR18 235psi PVC pipe? If allowed will zinc coatings be required on ductile iron pipe?

Response: 16" 250 PSI DI pipe is acceptable and has been added. See #1, Changes to the Specifications, with a revised bid proposal to include the option to provide pricing for 16" DI pipe or 16" PVC. Zinc coatings will not be required.

3. Question: On the plans it calls for an 8" x 8" cut-in tee at the tie-in at the existing line, but on the bid form it calls for a tie-in with a tapping sleeve. Can you please verify which one is needing to be priced?

Response: The tie-in shall be performed with a cut-in tee as per SAWS spec 831. See #1, Changes to the Specifications, with a revised bid proposal with the reference to the tapping sleeve removed.

CHANGES TO THE SPECIFICATIONS

- 1. Remove the Bid Proposal in its entirety and replace with the attached revised Bid Proposal. The description for line item 5 has been revised to remove the reference to a tapping sleeve and an additional line to allow for 16" DI pipe instead of 16" PVC pipe has been added. Bidders shall use the revised bid proposal when submitting a bid for this project. Failure to use the revised version may result in the bid being found non-responsive.**

CLARIFICATIONS

- 1. Bidders may use 16" DI pipe or 16" PVC pipe for Bid Line Item #1 and shall only provide pricing for one or the other when submitting a bid using this revised version of the Bid Proposal attached to this Addendum.**

END OF ADDENDUM

This Addendum is five (5) pages in its entirety.

Attachments:
Bid Proposal



Christopher Carruth
KFW Engineers

BID PROPOSAL

PROPOSAL OF _____, a corporation
a partnership consisting of _____
an individual doing business as _____

THE SAN ANTONIO WATER SYSTEM:

Pursuant to Instructions and Invitation to Bidders, the undersigned proposes to furnish all labor and materials as specified and perform the work required for the project as specified, in accordance with the Plans and Specifications for the following prices in the bid proposal to wit:

PLEASE SEE ATTACHED LIST OF BID ITEMS.

BIDDER'S SIGNATURE & TITLE

FIRM'S NAME (TYPE OR PRINT)

FIRM'S ADDRESS

FIRM'S PHONE NO. /FAX NO.

FIRM'S EMAIL ADDRESS

The Contractor herein acknowledges receipt of the following: **Addendum No(s)**. _____

OWNER RESERVES THE RIGHT TO ACCEPT THE OVERALL MOST RESPONSIBLE BID.

The bidder offers to construct the Project in accordance with the Contract Documents for the contract price, and to complete the Project within **150** calendar days after the start date, as set forth in the Authorization to Proceed. **The bidder understands and accepts the provisions of the contract Documents relating to liquidated damages of the project if not completed on time.**

Complete the additional requirements of the Bid Proposal which are included on the following pages.

Statement on President's Executive Orders

Has your firm previously performed work subject to the President's Executive Orders Numbers 11246 and 11375 or any preceding similar executive orders (Numbers 10925 and 11114)? Yes No

Texas Government Code Chapter 2274 Verifications

- (1) Are you, Contractor, held or controlled by individuals who are citizens of China, Iran, North Korea, Russia or a country designated by the Governor of the State of Texas pursuant to Texas Government Code Chapter 2274? Yes No
- (2) Are you, Contractor, held or controlled by a company or other entity, including a governmental entity, that is owned or controlled by citizens of or directly controlled by the government of China, Iran, North Korea, Russia or a country designated by the Governor of the State of Texas pursuant to Texas Government Code Chapter 2274? Yes No
- (3) Are you, Contractor, headquartered in China, Iran, North Korea, Russia or a country designated by the Governor of the State of Texas pursuant to Texas Government Code Chapter 2274? Yes No

Line Items						
Line No.	Item No.	Item Description	Unit	Quantity	Unit Price	Total
FOR ITEMS 1 AND 2 BIDDERS WILL EITHER PROVIDE A BID FOR 814 OR 818, NOT BOTH						
1	814	16" Ductile Iron Pipe	LF	5,784		
1	818	16" PVC Water Main	LF	5,784		
2	818	16" Water Main Cap	EA	1		
3	828	8" Gate Valve	EA	1		
4	828	16" Gate Valve	EA	8		
5	831	Existing Water Tie-In	EA	1		
6	834	Fire Hydrant	EA	5		
7	836	Ductile Iron Fittings	TN	2.04		
8	841	Hydrostatic Testing	LS	1		
9	550	Trench Excavation Safety Protection	LF	5,784		
10	844	Temporary 2" Blowoff	EA	1		
11	844	Permanent 2" Blowoff	EA	1		
12	846	2" Air Release Valve Assembly	EA	1		
13	858	Concrete Encaement	CY	65		
14	3001	Pole Bracing	EA	2		
15	COSA 103	Remove Concrete	SY	70		
16	COSA 503	Concrete Driveway (6" Thick)	SY	18		
17	COS 505	Concrete Riprap (5" Thick)	SY	22		
18	COSA 507	Temporary Barbed Wire Fence - Install and Replace	LF	1,041		
19	COSA 507	Permanent Barbed Wire Fence - Remove and Replace	LF	89		
20	COSA 507	16' Wide Gate	EA	2		
21	103	Revegetation	SY	24,755		
22	COSA 540	Equipment Storage Area	LS	1		
23	100	SWPPP	LS	1		
24	103	Channel Restoration	LS	1		
SUBTOTAL (ITEMS 1 - 24)						
25	100	Mobilization Maximum 10% of line items 1-24	LS	10%		
26	100	Intermediate Mobilization and Demobilization	LS	1		

27	101	Preparation of Right-of-Way - This item shall include preparing the right-of-way for construction operations by removing and disposing all obstructions from the right-of-way and from designated easements where removal of such obstructions is not otherwise provided for in the contract documents. Maximum 5% of line items 1-24	LS	5%		
----	-----	---	----	----	--	--

MOBILIZATION LUMP SUM BID SHALL BE LIMITED TO A MAXIMUM OF 10% OF THE LINE ITEM "1-24" SUB-TOTAL BASE BID AMOUNT. PREPARING RIGH-OF-WAY LUMP SUM BID SHALL BE LIMITED TO A MAXIMUM OF 5% OF THE LINE ITEM "1-24" SUB-TOTAL BASE BID AMOUNT. THE LINE ITEM "1-24" SUB-TOTAL BASE BID IS DEFINED AS ALL BID ITEMS EXCLUDING ITEM 100, MOBILIZATION AND ITEM 101, PREPARATION OF RIGHT-OF-WAY. IN THE EVENT OF A DISCREPANCY BETWEEN THE WRITTEN PERCENTAGE AND DOLLAR AMOUNT SHOWN FOR MOBILIZATION AND PREPARATION OF ROW BID ITEMS THE WRITTEN PERCENTAGE WILL GOVERN. IF THE PERCENTAGE WRITTEN EXCEEDS

TOTAL BID PRICE (TO INCLUDE LINE ITEMS 1- 27)	
---	--