

**SAN ANTONIO WATER SYSTEM**  
**WATER RESOURCES INTEGRATION PROGRAM**  
**OLD PEARSALL ROAD PUMP STATION PHASE I**  
**SAWS JOB NO. 13-8610-220**  
**SOLICITATION NO. B-14-012-DD**

---

**ADDENDUM NO. 1**  
**August 15, 2014**

To Bidder of Record:

This addendum, applicable to work designed above, is an amendment to the bidding documents and such will be a part of and included in the Contract. Each bidder shall acknowledge receipt of this addendum by entering the addendum number in the space provided in the Price Proposal.

**A. DRAWINGS.**

**1. Sheet SOP-19 (66 of 150).**

- a. On the roof plan, change "32 KCS w/5" Joist Seat" to 30 KCS w/5" Joist Seat."

**2. Sheet EOP-19 (102 of 150).**

- a. On Detail E (Chlorine Residual Analyzer), replace the aluminum back plate and stainless steel sun shade with a NEMA 4X enclosure and add the following notations:

"Install the chlorine residual analyzer, chlorine sensor, isolation valve, and calibration port inside the enclosure. All piping and electrical penetrations shall be sealed to maintain the NEMA 4X rating of the enclosure.

The enclosure shall be equipped with a strip heater and thermostat. The strip heater shall be rated 240 volts powered at 120 volts AC, with sufficient wattage to prevent freezing and condensation should the interior temperature drop below the dew point."

B. BIDDING AND CONTRACT REQUIREMENTS.

1. SPECIAL CONDITIONS.

- a. Page 1, Article 4. Add the following article to the end of the Special Conditions.

“4. GEOTECHNICAL REPORT. A Geotechnical Report has been developed by SAWS on this project and upon request will be made available for review by Contractors for information purposes only. (See Article 22 in Section 01015 for additional information.) Please contact Diana W. Dwyer via email at [Diana.Dwyer@saws.org](mailto:Diana.Dwyer@saws.org). SAWS will require execution of a SAWS disclaimer form by the Contractor as a condition of and prior to review of the report.”

C. TECHNICAL SPECIFICATIONS.

1. Section 09811 – POLYURETHANE COATING FOR STEEL PIPE.

- a. Page 2, Article 1.03.C.3. Add the following sentence to the end of this article:

“A color pallette shall also be submitted for Owner’s use in making a color selection for the coating material.”

- b. Page 4, Article 2.01.A.2. Change the minimum dry film thickness from 30 mils to 35 mils.

- c. Page 4, Article 2.01.A.3. Add Lifefast “Durashield 210” to the list of accepted coating materials.

\*\*\*\*\*

