



**WATER RESOURCES INTEGRATION PROGRAM, PHASE 1 PIPELINE SEGMENT 2B**

Solicitation No. B-14-044-DD

SAWS Job No. 14-8606

**ADDENDUM No. 2**

SEPTEMBER 22, 2014

To Respondent of Record:

This addendum, applicable to work referenced above, is an amendment to the proposal and plans and specifications and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the Addendum number and issue date on the space provided in submitted copies of the proposal.

**MODIFICATIONS TO THE SPECIFICATIONS**

- Supplementary Instructions to Respondents, #12, page SIR-3 and SIR-4, Insert the following as a new paragraph below item h:

“All pipe manufacturer/fabricator qualifications requested as part of #12 a.-h. of the Supplementary Instructions to Respondents will be considered required documents and will not count towards the page limit.”

- Section 15117. Air Release and Air Vacuum Valves, 1.02 Update the specifications to indicate acceptable Combination Air Valves with and without surge check by replacing paragraph C with the following:

"C. Acceptable Manufacturers--Combination Air Valves 6" through 12" Diameter, with and without Surge Protection				
Manufacturer	6" Flange	8" Flange	10" Flange	12" Flange
Vent-O-Mat	150.RBX.P.F.E4	200.RBX.P.F.E4	250.RBX.P.F.E4	300.RBX.P.F.E4
<p>P= Pressure rating, use 19, 25, or 40 representing 276 psi, 363 psi, or 580 psi            F= Flanged valve inlet connection, use 41 for ANSI B16.5 Class 150# or 61 for ANSI B16.5 Class 300#            E4 designates epoxy flanges with 304SS trim. Other materials also available.</p> <p>Actual model numbers, setup, and configuration shall be coordinated by the Contractor with his supplier and manufacturer to match the needs of these contract documents."</p>				

  
CIVIL ENGINEERING CONSULTANTS  
Terry L. Conn, P. E.



**ACKNOWLEDGEMENT BY RESPONDENT**

Each Respondent shall acknowledge receipt of this Addendum No. 2 by noting such and signing the Price Proposal.

This undersigned acknowledges receipt of this Addendum No. 2 and the proposal submitted herewith is in accordance with the information and stipulations set forth.

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature of Respondent

**END OF ADDENDUM**