

SAN ANTONIO WATER SYSTEM CENTRAL WATER INTEGRATION PIPELINE TERMINUS TREATMENT FACILITY SAWS Job No. 18-8616 SAWS Solicitation No. CO-00185

ADDENDUM No. 9 September 12, 2018

To Respondent of Record:

This addendum, applicable to work referenced above, is an amendment to the bidding documents and as such will be made a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the addendum number and issue date in the space provided in submitted copies of the proposal.

QUESTIONS AND ANSWERS

- Q1. Could [SAWS] consider including GA Industries as an acceptable manufacturer for the AWWA Butterfly Valves?
- A1. GA Industries is not listed as an approved manufacturer in the SAWS Standard Specification for Butterfly Valves and would need to be submitted to the SAWS Product Standards Committee for consideration through the process described on the website. http://www.saws.org/business_center/specs/product_submittal/

REVISIONS TO CONTRACT DOCUMENTS AND TECHNICAL SPECIFICATIONS

<u>SECTION 11241</u>

- a) Replace Paragraph 2.03.C.6 as follows:
 - 6. Pump shall be Blue-White M3 Series with integral leak detection, or approved equal.

This addendum is comprised of a total of $\underline{2}$ pages.



Jarrett Kinslow, P.E.

Tetra Tech, Inc.
Texas Registered Engineering Firm No. 3924
700 North Saint Mary's Street, Suite 300
San Antonio, Texas 78205

END OF ADDENDUM No. 9