



**Turtle Creek No. 3 Primary Pump Station Project**  
**Solicitation Number: CO-00404-SM**  
**Job No.: 21-6001**

**ADDENDUM NO. 6**  
**September 23, 2021**

To Respondent of Record:

This addendum, applicable to work referenced above, is an amendment to the bid proposal, plans and specifications and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the Addendum number and issue date on the space provided in submitted copies of the Respondent Questionnaire.

<b>RESPONSES TO QUESTIONS</b>
-------------------------------

- 1. Question: Plan Sheet P-1. Valve Schedule - Item #30, #31 & #32 Are all noted as Actuated Valves. Please verify if these are truly Electric Operated Valves or if they are Manual Valves**

*Response: Items #30, #31, and #32 on the Valve Schedule located on Sheet P-1 have been modified from actuated valves to manual valves. Refer to Item No. 1 in the CHANGES TO THE PLANS section of this addendum.*

- 2. Question: Refer to Dwg. C-7 to C-9 (Grading & Paving Plans) and Dwg. C-18 (Pavement Details). The thickness of the paving is not indicated on the paving drawings, and no paving hatching is shown, however paving details on Dwg. C-18 specifies 8” thick paving. Please clarify, if all the concrete paving for this project is 8” thick.**

*Response: Yes, all concrete is 8” thick.*

- 3. Question: Refer Specs 03 30 00 (Cast-in-place Concrete) & 32 13 13 (Concrete Paving) – As per Spec 03 30 00 Class B Concrete (3000 PSI) is specified for Pavement, Gutters and Sidewalk whereas in specs 32 13 13 Class A Concrete (4400 PSI) is mentioned. Please clarify, which to follow.**

*Response: Please follow Section 32 13 13 (Class A concrete).*

- 4. Question: Detail E27/EZ-4 specifies to refer structural drawings for Light Pole Footings, however no detail is provided on the structural drawings. Please provide details.**

*Response: Refer to revised Drawing S-20 issued in Addendum No. 5.*

- 5. Question: Refer pavement details on Dwg. C-18 – Please provide height of Ribbon Curb.**

*Response: Ribbon curb is to be 10” deep.*

- 6. Question: Please confirm ground storage tank slab, walls & roof are by others.**

*Response: Ground storage tank is to be provided by Tank Manufacturer.*

## CHANGES TO THE SPECIFICATIONS

### 1. Invitation to Bidders

**Delete:** Paragraph 6 through 8 of the Invitation to Bidders

**Replace with:**

“Due to the COVID-19 emergency and to protect the health of the public, SAWS is implementing new procedures for the submission of proposals. Proposals will be received electronically only, until 2:00 PM (CDT), **September 30, 2021**. Electronic proposals will be received via the secure SAWS FTP site. See the Electronic Proposal Opening Instructions attachment for additional information regarding an electronic proposal submittal. Electronic proposals shall be accompanied by a bid bond in an amount not less than five percent of the total proposal price. (Or, if providing SAWS with a cashier's check or certified check in an amount not less than five percent of the total proposal price, SAWS will request this within 24 hours from the Respondent who did not submit a bid bond). Proposals will then be publicly opened and read aloud by Contract Administration via WebEx.

<https://saws.webex.com>

Audio Connection: (210) 233-2090

Meeting number (access code): 1461 53 9097

Meeting password: 77jJzNPhNW7

Respondents will need to submit a request by **September 29, 2021 at 2:00 PM** (CDT) to receive access to the File Transfer Protocol (FTP) site via email to [Stella.Manzello@saws.org](mailto:Stella.Manzello@saws.org). Respondent's email requesting access to the FTP site shall provide the legal name of Respondent's company and the intended recipient's email address and phone number. No requests for FTP site access will be accepted after **September 29, 2021 at 9:00 PM** (CDT).”

2. **Delete** the Electronic Proposal Instructions in its entirety **and replace with** the revised Electronic Proposal Instructions included in this addendum.

## CHANGES TO THE PLANS

### 1. Drawing C-10, Inset “D”

**Delete:** “Mitered 30” RCP”

**Replace with:** “Mitered 36” RCP”

### 2. Drawing C-13, Tank Overflow Outlet Profile

a) **Delete:** “80.05’ – 30” RCP Class II @ 2.0%”

**Replace with:** “80.05’ – 36” RCP Class III @ 2.0%”

b) **Delete:** “28.40’ – 30” RCP Class III @ 2.5%”

**Replace with:** “28.40’ – 36” RCP Class III @ 2.5%”

c) **Add** Note 3 “Contractor to maintain at least 12” of cover over the proposed 36” pipe. 30” of cover is preferred.”

### 3. Sheet P-1, Site Piping Overall Layout

a) **Valve Schedule Item No. 30, Operator**

**Delete:** “Actuated”

**Replace with:** “Manual”

b) **Valve Schedule Item No. 31, Operator**

**Delete:** “Actuated”

**Replace with:** “Manual”

c) **Valve Schedule Item No. 32, Operator**

**Delete:** “Actuated”

**Replace with:** “Manual”

4. **Modify Addendum No. 5 Item No. 17 in the CHANGES TO THE PLANS Section**

**Delete:** “30” RCP Tank Overflow Drain See SHT. C-9”

**Replace with:** “36” RCP Tank Overflow Drain See SHT. C-9”

5. **Modify Addendum No. 5 Item No. 18 in the CHANGES TO THE PLANS Section**

**Delete:** “30” RCP Tank Overflow Drain See SHT. C-9”

**Replace with:** “36” RCP Tank Overflow Drain See SHT. C-9”

6. **Modify Addendum No. 5 Item No. 19 in the CHANGES TO THE PLANS Section**

**Delete:** “30” RCP Tank Overflow Drain Line: Tank Manufacturer to design and verify flow line during construction.”

**Replace with:** “36” RCP Tank Overflow Drain Line: Tank Manufacturer to design and verify flow line during construction.”

**CLARIFICATIONS**

1. None

**END OF ADDENDUM**

This Addendum, including these three (3) pages, is five (5) pages with attachments in its entirety.

Attachments:

Attachment 1 – Electronic Proposal Instructions



*Estella Cota-Treviño*

Estella Cota-Treviño, P.E.  
Freese and Nichols, Inc.

Attachment 1  
Electronic Proposal Instructions



**Turtle Creek No. 3 Primary Pump Station Project**  
**Solicitation Number: CO-00404-SM**

**ELECTRONIC PROPOSAL INSTRUCTIONS**  
**September 30, 2021 - 2:00 PM (CDT)**

**FTP BID PROPOSAL UPLOAD**

In order to receive electronic proposal for this RFCSP, SAWS will utilize a SAWS secured File Transfer Protocol (FTP) site. Only Respondents submitting as Prime Contractors will need to submit their request prior to **September 29, 2021 by 2:00 PM (CDT)** to receive access to the FTP site via email to [Stella.Manzello@saws.org](mailto:Stella.Manzello@saws.org). Respondent's email shall provide the legal name of the Respondent's company and the intended recipient's email address and phone number. No requests for FTP site access will be accepted after **September 29, 2021 by 2:00 PM (CDT)**. Once a Respondent is approved for access, an email with a hyperlink to the FTP site and a unique password for the Respondent will be provided to the Respondent's email recipient.

Once access is received, Respondent may upload the required documents per the Respondent's Proposal checklist any time before **September 30, 2021 - 2:00 PM (CDT)**. Please ensure to allow sufficient time should Respondent experience technical difficulties in uploading the required documents. No changes to the Proposal price can be made once the Proposal has been submitted.

**Respondents shall comply with the following:**

- 1) Limit files to three (3) pdf file that includes all items as indicated on the Respondent's Proposal Checklist. ONLY 3 SUBMITTALS PER RESPONDENT WILL BE ACCEPTED PER REQUEST. Do not upload any zip files.
- 2) Ensure that the itemized General Price Proposal Items is the first page(s) of File 1.
- 3) Respondents may protect the documents from editing by adding a password. However, the document must be accessible for viewing by SAWS without requiring a password.
- 4) File shall be titled as required on the Respondent's Proposal Checklist.
- 5) DO NOT SHARE ACCESS AND/OR PASSWORD WITH OTHER PARTIES OUTSIDE YOUR COMPANY.
- 6) ENSURE THE PROPOSAL IS SENT NO LATER THAN THE DUE DATE AND TIME. PROPOSALS SUBMITTED AFTER THE PROPOSAL OPENING DEADLINE WILL NOT BE ACCEPTED.

If the Respondent is in need of help, they may contact the SAWS Contract Administrator, **Stella Manzello**, at **210-233-3354** or view troubleshooting tips at <http://www.Serv-U.com/sharefiles>

**WEBEX PROPOSAL OPENING MEETING**

The WebEx meeting details are below if you would like to view the public opening of the price proposal.

*Access Information*

Meeting Number: **1461 53 9097**

Meeting Password: 77jJzNPhNW7

Audio Connection: 210-233-2550 (SAWS WebEx)

If you have any questions or concerns, please feel free to contact me.

Thank you,

**Stella Manzello**

Contract Administrator

2800 U.S. Highway 281 North, Ste. 171 | San Antonio, TX 78212

Office | 210-233-3854

Email | [Stella.Manzello@saws.org](mailto:Stella.Manzello@saws.org)