



Questions and Answers for  
Solicitation No: PS-00025  
Request for Qualifications

WATER RESOURCES INTEGRATION PROGRAM (WRIP) PHASE 2, PUMP STATIONS  
IMPROVEMENTS

May 09, 2016

1. Can you please clarify if the transfer pump station moving water from Old Pearsall Road Pump Station to Anderson Pump Station and the associated surge tank facility shall be included in the contract scope of services?

**The proposed scope of work at the Old Pearsall Pump Station includes the design of the pumps, pumping facilities, and surge facilities.**

2. What is the planned size of the ground storage tank at Old Pearsall PS?

**The proposed ground storage tank will be similar to the tank being built in Phase 1, which is 7.5 MG.**

3. Has the alignment been established for the Anderson PS piping?

**No. It is included in the proposed design scope of work.**