

**SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT**

---

Issued By: **D. Anthony Rubin**  
BID NO.: 19-0017

Date Issued: June 28, 2018

---

**FORMAL INVITATION FOR BIDS  
ANNUAL CONTRACT FOR JOINT RESTRAINTS  
ADDENDUM NO. 1**

---

Sealed bids addressed to the Purchasing Director, San Antonio Water System, 2800 US Hwy 281 North, Administration Bldg., 5<sup>th</sup> Floor, San Antonio, TX 78212 will be received until **3:00 p.m., July 8, 2019** and then publicly opened and read aloud for furnishing materials or services as described herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids  
Terms and Conditions of Invitation for Bids

Specifications and General Requirements  
Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name: \_\_\_\_\_ Firm Name: \_\_\_\_\_  
(Please Print or Type)

Address: \_\_\_\_\_

Signature of Person Authorized to Sign Bid \_\_\_\_\_ City, State, Zip Code: \_\_\_\_\_

Email Address: \_\_\_\_\_ Telephone No.: \_\_\_\_\_

Fax No.: \_\_\_\_\_

Please complete the following:

Prompt Payment Discount: \_\_\_\_\_% \_\_\_\_\_ days. (If no discount is offered, Net 30 will apply.)

Please check the following blanks which apply to your company:

Ownership of firm (51% or more):

Non-minority  Hispanic  African-American  Other Minority (specify) \_\_\_\_\_

Female Owned  Handicapped Owned  Small Business (less than \$1 million annual receipts or 100 employees)

Indicate Status:  Partnership  Corporation  Sole Proprietorship  Other (specify) \_\_\_\_\_

Tax Identification Number: \_\_\_\_\_

**To report suspected ethics violations impacting the San Antonio Water System, please call 1-800-687-1918.**

---

This **Addendum no. 1** is being issued to provide clarification and answer to questions submitted for bid no. 19-0017 for the Annual Contract for Joint Restraints

Adding the requirement that:

- PVC (C900) restraints must be compatible with HDPE piping
- All of the restraints must be epoxy coated
- All of the bolts, nuts, rods and washers must be treated with Cor Blue or an equivalent corrosion protection.

1. Do the mega lugs need to have the epoxy coating on them?

**Answer:** All of the restraints must be epoxy coated.

2. Are the MJ Accessory packs with the Gland or without the Gland being just bolts and gaskets only?

**Answer:** The MJ Accessory packs are without the glands and all the bolts, nuts, rods and washers must be treated with Cor Blue or an equivalent corrosion protection.

3. I do not see SIP on the approved manufacturers are they not approved anymore? **Answer:** SIP is approved.

Restraint Systems For PVC	Slip on Joint	See Specs	EZPVCP	<b>SIP Industries</b>	95-10
Restraint Systems For PVC	Slip on Joint	See Specs	PTPVC	<b>SIP Industries</b>	95-10
Restraint Systems For Ductile Iron Pipe	Slip on Joint	See Specs	EZDP	<b>SIP Industries</b>	95-10

**IT IS NECESSARY TO RETURN THIS ADDENDUM TOGETHER WITH YOUR BID**