

SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT

Issued By: Author E. Sandlain II
BID NO.: 19-19110

Date Issued: August 27, 2019

**FORMAL INVITATION FOR BIDS
FORMAL ONE-TIME PURCHASE FOR BAUER HOSES
ADDENDUM 1**

Sealed bids addressed to the Purchasing Director, San Antonio Water System, 2800 US Hwy 281 North, Administration Bldg., 5th Floor, San Antonio, TX 78212 will be received until **3:00 p.m., September 5, 2019** and then publicly opened and read aloud for furnishing materials or services as described herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids
Terms and Conditions of Invitation for Bids

Specifications and General Requirements
Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name: _____ Firm Name: _____
(Please Print or Type)

Address: _____

Signature of Person Authorized to Sign Bid _____ City, State, Zip Code: _____

Email Address: _____ Telephone No.: _____

Fax No.: _____

Please complete the following:

Prompt Payment Discount: _____% _____days. (If no discount is offered, Net 30 will apply.)

Please check the following blanks which apply to your company:

Ownership of firm (51% or more):

___Non-minority ___Hispanic ___African-American ___Other Minority (specify) _____

___Female Owned ___Handicapped Owned ___Small Business (less than \$1 million annual receipts or 100 employees)

Indicate Status: ___Partnership ___Corporation ___Sole Proprietorship ___Other (specify) _____

Tax Identification Number: _____

To report suspected ethics violations impacting the San Antonio Water System, please call 1-800-687-1918.

The purpose of this Addendum 1 is to respond to vendors' questions.

Q1. Do you have a list of approved equals for these Bauer fittings?

A1. No.

Q2. What is the material of the Bauer ball/socket, if other than HDPE?

A2. Must be HDPE fuse able pipe, DR 17.

Q3. How long are the HDPE tails for each of the couplers?

A3. 18" to 24" HDPE attached tail pieces.

Q4. How long does the poly sleeve need to be for all four items?

A4. Between 18 inches and 24 inches.

Q5. The Description mentions DR 17 HDPE Tail – are you requesting the below in HDPE (High Density Polyethylene)?

A5. Must have HDPE tail piece attached to Bauer fitting.

Q6. Can you ask the end user if the Bauer fitting is a TYPE A or TYPE B fitting?

A6. Type B fitting.

IT IS NOT NECESSARY TO RETURN THIS ADDENDUM 1 AS PART OF YOUR BID SUBMISSION.

All terms and conditions of the Formal Bid remained unchanged.