
SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT

Issued By: Joseph Ramon
BID NO.: 18-18043

Date Issued: April 3, 2018

FORMAL INVITATION FOR BIDS
FOR PURCHASE OF TWO (2) SCREENINGS WASHER COMPACTORS FOR DOS RIOS WRC
ADDENDUM 2

Sealed bids addressed to the Purchasing Director, San Antonio Water System, 2800 US Hwy 281 North, Administration Bldg., 5th Floor, San Antonio, TX 78212 will be received until 3:00 p.m. **April 11, 2018** and then publicly opened and read aloud for furnishing materials or services as described herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

(Contractor's Insurance Requirements Attached)

This invitation includes the following:

Invitation for Bids
Terms and Conditions of Invitation for Bids

Specifications and General Requirements
Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name: _____ Firm Name: _____
(Please Print or Type)

Address: _____

Signature of Person Authorized to Sign Bid _____ City, State, Zip Code: _____

Email Address: _____ Telephone No.: _____

Fax No.: _____

Please complete the following:

Prompt Payment Discount: _____% _____days. (If no discount is offered, Net 30 will apply.)

Please check the following blanks which apply to your company:

Ownership of firm (51% or more):

Non-minority Hispanic African-American Other Minority (specify) _____

Female Owned Handicapped Owned Small Business (less than \$1 million annual receipts or 100 employees)

Indicate Status: Partnership Corporation Sole Proprietorship Other (specify) _____

Tax Identification Number: _____

To report suspected ethics violations impacting the San Antonio Water System, please call 1-800-687-1918.

***** This **Addendum 2** is issued to make the following changes on Bid 18-14043.

1. Question due Date has changed as follows:

“4:00 p.m., April 5, 2018”

2. Revised 3.1 General- Screenings washer compactor page 19 section 3.1.J Provide a spray wash assembly to rinse the organic material from the processed solids back into the waste stream. The assembly shall consist of a ball valve, strainer, and solenoid valve. NPW pressure at Salado Creek WRC ranges from 90-70 psi. Equipment provider shall supply a pressure reducing valve. All components of the spray wash assembly shall be type 316 stainless steel. Changed to General-Screenings washer compactor page 19 section 3.1.J Provide a spray wash assembly to rinse the organic material from the processed solids back into the waste stream. The assembly shall consist of a ball valve, strainer, and solenoid valve. NPW pressure at Dos Rios WRC ranges from 90-70 psi. Equipment provider shall supply a pressure reducing valve. All components of the spray wash assembly shall be type 316 stainless steel.
3. Revised 3.3 Service conditions –Screening washer compactor page 20 section 3.3 Continuous Operating Capacity (per unit): 140 cubic feet per hour (wet screenings) Changed to Service conditions –Screening washer compactor page 20 section 3.3 Continuous Operating Capacity (per unit): 103 cubic feet per hour (wet screenings)
4. Approved equal- WesTech, Salt Lake City UT

All other terms and conditions of the original bid remain unchanged.

IT IS **NOT NECESSARY** TO RETURN THIS ADDENDUM 1 AS PART OF YOUR BID SUBMISSION