SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT

Issued By: Gina Cappa Date Issued: August 22, 2018

BID NO.: 18-18086-1

FORMAL INVITATION FOR BIDS FOR THE ONE TIME PURCHASE OF UNINTERRUPTIBLE POWER SUPPLY (UPS) FOR SAWS DATACENTER ADDENDUM 1

Sealed bids addressed to the Purchasing Department, San Antonio Water System, 2800 US Hwy 281 North, Administration Bldg., 5th Floor, San Antonio, TX 78212 will be received until **3:00 PM, September 7, 2018** and then publicly opened and read aloud for furnishing materials or services as described herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids Specifications and General Requirements
Terms and Conditions of Invitation for Bids Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name:	Firm Name:
(Please Print or Type)	
	Address:
Signature of Person Authorized to Sign Bid	City, State, Zip Code:
Email Address:	Telephone No.:
	Fax No.:
Please complete the following:	
Prompt Payment Discount:%days.	(If no discount is offered, Net 30 will apply.)
Please check the following blanks which apply to you	r company:
Ownership of firm (51% or more):	
Non-minorityHispanicAfrican-Am	ericanOther Minority (specify)
Female OwnedHandicapped OwnedSmal	ll Business (less than \$1 million annual receipts or 100 employees)
Indicate Status:PartnershipCorporation _	Sole ProprietorshipOther (specify)
Tax Identification Number:	

To report suspected ethics violations impacting the San Antonio Water System, please call 1-800-687-1918.

***** This **Addendum 1** is issued for Bid 18-18086-1 to do the following:

1. Provide questions and responses.

IT IS NOT NECESSARY TO RETURN THIS ADDENDUM 1 AS PART OF YOUR BID SUBMISSION

QUESTIONS AND RESPONSES

1. Your bid calls for FOB San Antonio SAWS facility. Normal we ship directly to the installer. Please advise if you will need a lift gate or anything special to the Facility you're requesting to ship.

Response: The bid does require FOB San Antonio SAWS facility. All delivery arrangements will be made after award of the bid, but before delivery is made.

2. I was wondering of the KVA size of the unit you are interested in.

Response: 50 kW.

3. Is this a meet or exceed opportunity or will SAWS only be accepting the named product and part numbers?

Response: Only the named product and part numbers will be accepted.

4. Does the bid include installation?

Response: No.

5. Can you please provide the necessary battery runtime for the UPS please?

Response: 23 minutes of runtime at 50 kW and 78 minutes at 20kW.