

SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT

Issued By: Gina Cappa
BID NO.: 19-19014

Date Issued: February 19, 2019

**FORMAL INVITATION FOR BIDS FOR THE ONE TIME PURCHASE OF 13 PROMAG L400
FLOW METERS, TO INCLUDE 26 PROMAG GROUNDING DISKS
Addendum 1**

Sealed bids addressed to the Purchasing Department, San Antonio Water System, 2800 US Hwy 281 North, Administration Bldg., 5th Floor, San Antonio, TX 78212 will be received until **3:00 PM, February 26, 2019** and then publicly opened and read aloud for furnishing materials or services as described herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids
Terms and Conditions of Invitation for Bids

Specifications and General Requirements
Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name: _____ Firm Name: _____
(Please Print or Type)

Address: _____

Signature of Person Authorized to Sign Bid _____ City, State, Zip Code: _____

Email Address: _____ Telephone No.: _____

Fax No.: _____

Please complete the following:

Prompt Payment Discount: _____% _____days. (If no discount is offered, Net 30 will apply.)

Please check the following blanks which apply to your company:

Ownership of firm (51% or more):

Non-minority Hispanic African-American Other Minority (specify) _____

Female Owned Handicapped Owned Small Business (less than \$1 million annual receipts or 100 employees)

Indicate Status: Partnership Corporation Sole Proprietorship Other (specify) _____

Tax Identification Number: _____

To report suspected ethics violations impacting the San Antonio Water System, please call 1-800-687-1918.

***** This **Addendum 1** is issued for Bid 19-19014 to do the following:

- 1. Provide questions and responses.**

IT IS NECESSARY TO RETURN THIS ADDENDUM 1 AS PART OF YOUR BID SUBMISSION

QUESTIONS AND RESPONSES

- 1. Will approved equals be considered for this bid?**

Response: No. Flow meters being purchased through this bid are consistent with equipment at the existing facility.

- 2. Part number 5L4C2H- AALMN5DQA12GA+AAPC does not explicitly mention the cable length required to link the remote transmitter and flow sensor? How many feet of cable would you need?**

Response: 150 FT for each flow meter.
