SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT

Issued By: Gina Cappa BID NO.: 19-19032 Date Issued: March 13, 2019

FORMAL INVITATION FOR BIDS FOR THE ONE TIME PURCHASE OF STANDBY UNINTERRUPTIBLE POWER SUPPLY (UPS) UNITS FOR INSTRUMENTATION ADDENDUM 2

Sealed bids addressed to the Purchasing Department, San Antonio Water System, 2800 US Hwy 281 North, Administration Bldg., 5th Floor, San Antonio, TX 78212 will be received until **3:00 PM (CT), March 27, 2019** and then publicly opened and read aloud for furnishing materials or services as described herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids Terms and Conditions of Invitation for Bids Specifications and General Requirements Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name:	Firm Name:
(Please Print or Type)	_ Firm Name:
	Address:
Signature of Person Authorized to Sign Bid	City, State, Zip Code:
Email Address:	Telephone No.:
Please complete the following:	Fax No.:
Prompt Payment Discount:%days. (If	f no discount is offered, Net 30 will apply.)
Female OwnedHandicapped OwnedSmall I	company: icanOther Minority (specify) Business (less than \$1 million annual receipts or 100 employees) _Sole ProprietorshipOther (specify)

To report suspected ethics violations impacting the San Antonio Water System, please call 1-800-687-1918.

***** This Addendum 2 is issued for Bid 19-19032 to do the following:

- 1. Provide question and response.
- 2. Provide an approved equal where name and model number in the invitation for bid designate manufacturers and models.

IT IS NECESSARY TO RETURN THIS ADDENDUM 2 AS PART OF YOUR BID SUBMISSION

QUESTIONS AND RESPONSES

GROUP 1

1. Are you considering equivalents for the group 1, 120 APC units?

Response: Yes. All requests for approved equals must be submitted in writing with printed manufacturers' specification sheets to Gina Cappa at <u>Gina.Cappa@saws.org</u> no later than March 19, 2019 by 4:00 PM (CT). SAWS will review to determine acceptability in accordance with specifications contained in the bid and provide notice, in writing of its determination.

Approved Equal

Item	REQUIRED DESCRIPTION	APPROVED EQUAL
1	APC Smart UPS Unit – UPSXLA – 1500VA, 120 Volts	N1C L2000 UPS - 2000 VA, 120 Volts

End of Addendum