SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT

Issued By: D. Anthony Rubin Date Issued: December 20, 2019

BID NO.: 19-19171

FORMAL INVITATION FOR BIDS CONTRACT FOR THE PURCHASE OF AN ELECTRIC MOTOR FOR PORT OF SAN ANTONIO CHILLER NO. 2 ADDENDUM NO. 1

Sealed bids addressed to the Purchasing Director, San Antonio Water System, 2800 US Hwy 281 North, Administration Bldg., 5th Floor, San Antonio, TX 78212 will be received until **3:00 p.m.**, **January 9, 2020** and then publicly opened and read aloud for furnishing materials or services as described herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:


Invitation for Bids Terms and Conditions of Invitation for B	Specifications and General Requirements Fids Price Schedule
	he/she is authorized to bind the Bidder to fully comply with the unt(s) shown on the accompanying bid sheet(s). By signing below, terms therein.
Signer's Name:	Firm Name:
(Please Print or Type)	Address:
Signature of Person Authorized to Sign Bid	City, State, Zip Code:
Email Address:	Telephone No.:
	Fax No.:
Please complete the following: Prompt Payment Discount:%days. ((If no discount is offered, Net 30 will apply.)
Please check the following blanks which apply to your Ownership of firm (51% or more):	r company:
	ericanOther Minority (specify) I Business (less than \$1 million annual receipts or 100 employees)
	Sole ProprietorshipOther (specify)
	g the San Antonio Water System, please call 1-800-687-1918.

This **Addendum no. 1** is being issued to respond to question submitted and to revise the price schedule.

Question: Bid No. 19-19171 Purchase of an Electric Motor for Port of San Antonio Chiller No. 2

- 1. I have a question regarding the above mentioned bid. In the Invitation to Bid one sections states "bids for a one time purchase of a Reliance Electric Motor..." but then on the pricing sheet the Qty is (5). We just want to make sure of the quantity. **Answer: (1)**
- 2. Do you anticipate extending the bid due date? Answer: The bid due date is January 9, 2020 at 3:00 pm.
- 3. What additional details are you willing to provide, if any, beyond what is stated in bid documents concerning how you will identify the winning bid? **Answer: All information concerning this motor is n provided in the bid document.**
- 4. Was this bid posted to the nationwide free bid notification website at www.mygovwatch.com? Answer:SAWS post there bids on Demand Star, SAWS website and an Ad notice is sent to The Heart Beat newspaper.
- 5. Other than your own website, where was this bid posted? Answer: See response to question 4.
- 6. Possible to get a pic of the nameplate off this 1117hp York Chiller motor? **Answer: Please see attachment.**

IT IS NECESSARY TO RETURN THIS ADDENDUM TOGETHER WITH YOUR ORIGINAL BID DOCUMENT.



PRICE SCHEDULE

		QTY	Unit	Unit of	Extended
Item	Description		Price	Measure	Price
	Electric Motor, 1117 HP				
	4160 Volt, 3 Phase Motor for a 1500	1	\$	EACH	\$
1	Ton York Chiller		,		,
	Freight to San Antonio Water System,				
	Port SA Bldg. 356 Cooling Plant	1	\$	EACH	\$
	Chiller 2, 335 S. Airlift, San Antonio,				
2	Texas 78226				
				ТОТАТ	¢
				TOTAL	Φ

DELIVERY SCHEDULE: Delivery will be o	completed within	calendar days of purchase order.
MAKE / MODEL:		-
BY:	_	
TITLE:		
FOR:(Name of Firm Submitting Bid)	-	
DATE.		