

**SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT**

**Issued By: D. Anthony Rubin**  
**BID NO.: 20-20070**

**Date Issued: July 9, 2020**

---

**FORMAL INVITATION FOR BIDS**  
**CONTRACT FOR PURCHASE OF SIX (6) 7.5 HP AND TWO (2) 20 HP ASPIRATING**  
**AERATORS FOR RECYCLED WATER**  
**ADDENDUM NO. 1**

---

Sealed bids addressed to the Purchasing Director, San Antonio Water System, 2800 US Hwy 281 North, Administration Bldg., 5<sup>th</sup> Floor, San Antonio, TX 78212 will be received until **3:00 p.m., July 17, 2020** and then publicly opened and read aloud for furnishing materials or services as described herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids  
Terms and Conditions of Invitation for Bids

Specifications and General Requirements  
Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name: \_\_\_\_\_ Firm Name: \_\_\_\_\_  
(Please Print or Type)

Address: \_\_\_\_\_

Signature of Person Authorized to Sign Bid \_\_\_\_\_ City, State, Zip Code: \_\_\_\_\_

Email Address: \_\_\_\_\_ Telephone No.: \_\_\_\_\_

Fax No.: \_\_\_\_\_

Please complete the following:

Prompt Payment Discount: \_\_\_\_\_% \_\_\_\_\_ days. (If no discount is offered, Net 30 will apply.)

Please check the following blanks which apply to your company:

Ownership of firm (51% or more):

Non-minority  Hispanic  African-American  Other Minority (specify) \_\_\_\_\_

Female Owned  Handicapped Owned  Small Business (less than \$1 million annual receipts or 100 employees)

Indicate Status:  Partnership  Corporation  Sole Proprietorship  Other (specify) \_\_\_\_\_

Tax Identification Number: \_\_\_\_\_

**To report suspected ethics violations impacting the San Antonio Water System, please call 1-800-687-1918.**

---

This **Addendum no. 1** is being issued for **Contract for Purchase of Six (6) 7.5 HP and Two (2) 20 HP Aspirating Aerators for Water Recycling Center bid no. 20-20070** to provide responses and clarification to question submitted.

Question submitted for Purchasing of Aspirating Aerators for SMC WRC bid no. 20-20070.

1. Sheet S11 shows steel grate covers. Are these in the aerator supplier's scope of supply?  
Answer: Steel grate covers aren't in the scope of supply, provided the new mounts and guide rails don't prevent the use of the existing grates.
2. Or are they existing or provided by others?  
Answer: Steel grate covers aren't in the scope of supply, provided the new mounts and guide rails don't prevent the use of the existing grates.
3. Contract documents do not specify requisite embedded angle for the steel grate covers. Are these in the aerator supplier's scope of supply?  
Answer: Steel grate covers aren't in the scope of supply, provided the new mounts and guide rails don't prevent the use of the existing grates.
4. Or are they existing or provided by others?  
Answer: Steel grate covers aren't in the scope of supply, provided the new mounts and guide rails don't prevent the use of the existing grates.
5. Sheet S11 shows HILTI 304 anchors to mount the aerator mount to the basin. Are these in the aerator supplier's scope of supply?  
Answer: Yes.
6. Regarding warranty section 1.04, our standard three-year manufacturing warranty does not cover valves or actuators as these are not included in our offering. Would SAWS consider revision to this section to assign the warranty to the aspirators, motors, and wall mounts included in our system?  
Answer: Yes, section 1.04 A should read, "The warranty for the aerators, motors, and mounting hardware shall begin on the date that the aerators, motors, and mounting hardware are put in service. The mounting hardware warranty period shall be 1 year minimum. The aerator and motor warranty period shall be 3 years minimum."
7. Regarding electrical service cable section 2.12, we would like to know the approximate lengths of cable required? The cable run lengths will help us accurately size cable for the application. In some of our applications we have seen long spans of electrical cable significantly impact the required sizing.  
Answer: The cable length needs to be 10 ft.

**IT IS NOT NECESSARY TO RETURN THIS ADDENDUM.**