## SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT

Issued By: Clifford Gorman Date Issued: August 2, 2012

BID NO.: 12-1281

## FORMAL INVITATION FOR BIDS CONTRACT FOR COOLING TOWER REPAIRS AT PORT SAN ANTONIO FACILITIES ADDENDUM NO. 1

Sealed bids addressed to the Purchasing Director, San Antonio Water System, 2800 US Hwy 281 North, P.O. Box 2449, San Antonio, TX 78298-2449 will be received until **3:00 p.m.**, **August 9, 2012** and then publicly opened and read aloud for furnishing materials or services as described received herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids	Specifications and General Requirements
Terms and Conditions of Invitation for Bids	Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name:	Firm Name:	
(Please Print or Type)		
	Address:	
Signature of Person Authorized to Sign Bid	City, State, Zip Code:	
Email Address:	Telephone No.:	
	Fax No.:	
Please complete the following:		
Prompt Payment Discount:%days. (If no discount is offered, Net 30 will apply.)		
Please check the following blanks which apply to your co	ompany:	
Ownership of firm (51% or more):		
Non-minorityHispanicAfrican-Americ	canOther Minority (specify)	
Female OwnedHandicapped OwnedSmall B	usiness (less than \$1 million annual receipts or 100 employees)	
Indicate Status:PartnershipCorporation	_Sole ProprietorshipOther (specify)	
Tax Identification Number:		

This addendum is being issued to revise and clarify the scope of the repair services being requested in Bid # 12-1281.

At San Antonio Water System Chilled Water Plant # 325 the following additions are to be made to the scope of work:

- Install a patch of 16 gauge galvanized metal over the corrosion located below the access panel above the cool water basin. Patch is to extend a minimum of 3 inches around existing corroded hole. Patch is to be secured to existing structure using stainless steel 304 bolts or rivets.
- Install an industrial grade fiberglass grate above the recess in the cold water basin. Grate must have a minimum strength rating of 719 pounds with a safety factor of 2. Grate shall cover recess by a minimum of 6 inches on each side. Grate shall be secured with stainless steel 304 hardware and fasteners.

To clarify the items that were discussed:

- Please bid the replacement of the hot water basin, repair of the basin will not be considered at this time.
- The chiller at San Antonio Water System Chilled Water Plant # 1625 cannot be taken out of service until chiller #2 at that site is returned to operation.

IT IS NOT NECESSARY TO RETURN THIS ADDENDUM WITH YOUR BID.