

**SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT**

---

Issued By: **Clifford Gorman**  
BID NO.: **12-1308**

Date Issued: **September 5, 2012**

---

**FORMAL INVITATION FOR BIDS  
FOR THE PURCHASE AND INSTALLATION OF OVERHEAD ROLLUP GARAGE DOORS  
ADDENDUM NO. 1**

---

Sealed bids addressed to the Purchasing Director, San Antonio Water System, 2800 US Hwy 281 North, P.O. Box 2449, San Antonio, TX 78298-2449 will be received until **3:00 p.m., September 11, 2012** and then publicly opened and read aloud for furnishing materials or services as described received herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids  
Terms and Conditions of Invitation for Bids

Specifications and General Requirements  
Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name: \_\_\_\_\_ Firm Name: \_\_\_\_\_  
(Please Print or Type)

Address: \_\_\_\_\_

Signature of Person Authorized to Sign Bid \_\_\_\_\_ City, State, Zip Code: \_\_\_\_\_

Email Address: \_\_\_\_\_ Telephone No.: \_\_\_\_\_

Fax No.: \_\_\_\_\_

Please complete the following:

Prompt Payment Discount: \_\_\_\_\_% \_\_\_\_\_days. (If no discount is offered, Net 30 will apply.)

Please check the following blanks which apply to your company:

Ownership of firm (51% or more):

\_\_\_ Non-minority \_\_\_ Hispanic \_\_\_ African-American \_\_\_ Other Minority (specify) \_\_\_\_\_

\_\_\_ Female Owned \_\_\_ Handicapped Owned \_\_\_ Small Business (less than \$1 million annual receipts or 100 employees)

Indicate Status: \_\_\_ Partnership \_\_\_ Corporation \_\_\_ Sole Proprietorship \_\_\_ Other (specify) \_\_\_\_\_

Tax Identification Number: \_\_\_\_\_

Change bid opening date and time as follows:

**“3:00 p.m., September 11, 2012”**

**Replace PRICE SCHEDULED AS FOLLOWS:**

**PRICE SCHEDULE**

<b>Item</b>	<b>Description</b>	<b>UM</b>	<b>QTY</b>	<b>Unit Price</b>	<b>Extended Price</b>
<b>1</b>	OVERHEAD ROLLUP GARAGE DOOR FOR EASTSIDE SERVICE CENTER AS SPECIFIED ABOVE	<b>EA</b>	<b>25</b>	\$	\$
<b>2</b>	INSTALLATION OF OVERHEAD ROLLUP GARAGE DOOR AT THE EASTSIDE SERVICE CENTER	<b>EA</b>	<b>25</b>	\$	\$
<b>3</b>	OVERHEAD ROLLUP GARAGE DOOR FOR EASTSIDE SERVICE CENTER WELDING SHOP AS SPECIFIED ABOVE	<b>EA</b>	<b>1</b>	\$	\$
<b>4</b>	INSTALLATION OF OVERHEAD ROLLUP GARAGE DOOR AT THE EASTSIDE SERVICE CENTER WELDING SHOP	<b>EA</b>	<b>1</b>	\$	\$
<b>5</b>	OVERHEAD ROLLUP GARAGE DOOR FOR NORTHWEST SERVICE CENTER AS SPECIFIED ABOVE	<b>EA</b>	<b>1</b>	\$	\$
<b>6</b>	INSTALLATION OF OVERHEAD ROLLUP GARAGE DOOR AT THE NORTHWEST SERVICE CENTER	<b>EA</b>	<b>1</b>	\$	\$
<b>7</b>	REMOVAL AND DISPOSAL OF EXISTING DOORS AT THE EASTSIDE SERVICE CENTER	<b>EA</b>	<b>26</b>	\$	\$

**GRAND TOTAL** \$ \_\_\_\_\_

**ESTIMATED COMPLETION PERIOD**

Delivery will be completed within \_\_\_\_\_ calendar days after receipt of order. (If applicable)

**An additional door is being added to the scope, specifications are as follows:**

Overhead rollup garage door for Eastside Service Center Welding Shop

1. Approximate door dimensions 14 feet X 14 feet 2 inches
  - a. Bottom bar to consist of two (2) structural steel angles
  - b. Hood to be 24 gage galvanized steel
  - c. Flat slats to be 22 gage galvanized steel with light gray polyester enamel finish (Gray)
  - d. Steel angle guides
  - e. Finished to be baked-on primer. (Gray)
  - f. Bottom bar to have weather seal
  - g. No exterior guide or header seal
  - h. Installed reduction geared chain hoist
  - i. Mounting for optional electric door operator

To address items identified during the sight visit see below.

1. Sprinkler heads that are attached to current door rails will be removed/ relocated before the beginning of the door installation.
2. Successful vendor must submit a safety plan to include a hot work plan to SAWS Safety department for review before work is started.
3. Working hours, number of bays available each day and security of shop area are to be arranged with the Fleet Management Department.

**IT IS NECESSARY TO RETURN THIS ADDENDUM WITH YOUR BID.**