## SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT

Issued By: Karen Guerrero Date Issued: March 14, 2013

BID NO.: 13-1421

## FORMAL INVITATION FOR BIDS ANNUAL CONTRACT FOR PURCHASE AND DELIVERY OF 10 % SODIUM HYPOCHLORITE SOLUTION ADDENDUM 3

Sealed bids addressed to the Purchasing Director, San Antonio Water System, 2800 US Hwy 281 North, Administration Bldg., 5<sup>th</sup> Floor, P.O. Box 2449, San Antonio, TX 78298-2449 will be received until **3:00 p.m., March 19, 2013** and then publicly opened and read aloud for furnishing materials or services as described received herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids Specifications and General Requirements
Terms and Conditions of Invitation for Bids Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name:	Firm Name:
Signer's Name: (Please Print or Type)	
	Address:
Signature of Person Authorized to Sign Bid	City, State, Zip Code:
Email Address:	Telephone No.:
	Fax No.:
Please complete the following:	
Prompt Payment Discount:%days. (I	f no discount is offered, Net 30 will apply.)
Please check the following blanks which apply to your	company:
Ownership of firm (51% or more):	
Non-minorityHispanicAfrican-AmericanOther Minority (specify)	
Female OwnedHandicapped OwnedSmall Business (less than \$1 million annual receipts or 100 employees)	
Indicate Status:PartnershipCorporationSole ProprietorshipOther (specify)	
Tax Identification Number:	_

## IT IS NECESSARY TO RETURN THE ENTIRE SIGNED FORM WITH YOUR BID RESPONSE.

1. Page 13 of 28, Item n: This item request that NSF information be submitted. NSF certification is only required for products used to treat Drinking Water. As the bleach for this contract is not being used to treat drinking water...does it have to be NSF certified?

**Response:** Yes, even though the primary use is not in drinking water this will also be an emergency backup supply for the potable system therefore we will need the NSF information to be submitted.