#### SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT

Issued By: Anthony Rubin Date Issued: March 14, 2013

BID NO.: 13-1441

# FORMAL INVITATION FOR BIDS PURCHASE OF ONE MOTOR OPERATED BALL VALVE (MOV) AND ACCESSORIES ADDENDUM NO. 1

Sealed bids addressed to the Purchasing Director, San Antonio Water System, 2800 US Hwy 281 North, P.O. Box 2449, San Antonio, TX 78298-2449 will be received until **3:00 p.m.**, **March 20, 2013** and then publicly opened and read aloud for furnishing materials or services as described received herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids Specifications and General Requirements
Terms and Conditions of Invitation for Bids Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name:	Firm Name:
(Please Print or Type)	
	Address:
Signature of Person Authorized to Sign Bid	City, State, Zip Code:
Email Address:	Telephone No.:
	Fax No.:
Please complete the following:  Prompt Payment Discount:%days. (	(If no discount is offered, Net 30 will apply.)
Please check the following blanks which apply to your	company:
Ownership of firm (51% or more):	
Non-minorityHispanicAfrican-Ame	ericanOther Minority (specify)
Female OwnedHandicapped OwnedSmall	Business (less than \$1 million annual receipts or 100 employees)
Indicate Status:PartnershipCorporation	Sole ProprietorshipOther (specify)
Tax Identification Number:	

The following are a list of questions submitted during the question submittal period and from the Mandatory prebid meeting.

## Question

1. Are ALL valves to open counter clockwise?

**Answer:** Open right (90° full open/close) Clock Wise CW sequence on the actuator & ball-valve (To eliminate any water hammer).

## Question

2. Are S.S bolts required for this project?

Answer: Yes; Awarded bidder to use all new S.S locking washers; flat-washers nuts and bolts.

#### IT IS NOT NECESSARY TO RETURN THIS ADDENDUM WITH YOUR BID.