

100-20

SPECIFICATION FOR LIQUID CHLORINE

REVISED DECEMBER 2011

1. **SCOPE**

This specification covers liquid chlorine.

2. **GENERAL REQUIREMENTS**

- a) Liquid chlorine shall conform to AWWA Specification B301-04, or latest revision thereof.
- b) Liquid chlorine shall be furnished in 150 pound or 2,000 pound containers, as specified.

Previous Specification Date:

OCTOBER 1992

MARCH 2007

DECEMBER 2011