



**SAN ANTONIO WATER SYSTEM
STEIN TO SALADO INTERCONNECTION DSP PROJECT
JOB # 12-7210
Solicitation No. B-12-060-MR
ADDENDUM NO. 3**

October 16, 2012

This addendum, applicable to work designed above, is an amendment to the bidding and specification documents and as such shall be a part of and included in the Contract. Acknowledge receipt of this addendum by entering the addendum number and issue date in the spaces provided on all submitted copies of the bid.

1.0 TO CHANGE REQUIREMENTS ON STEEL PIPE:

1. Any Steel Pipe and Materials for steel pipe called out on this project shall conform to SAWS Material Specification for Steel Pipe 05-30. Please be sure to follow items #2 and #3 under 3. Materials A. Pipe regarding AWWA C200 and working pressure of 150 psi with an additional 50% for surge pressure. Minimum wall thickness shall be 0.375".

2.0 TO ADD NOTE TO STRUCTURAL PLANS:

1. After welding is completed, welded surface shall be wire brushed to remove all scale and debris. Welded surface shall then receive a coat of lead free and chromate free primer (Sherwin Williams "Kromik" or SAWS approved equal). After primer has dried, apply a coat of Rust-inhibitive paint in accordance with manufacturer's directions.

3.0 TO CHANGE BID OPENING TIME:

Invitation to Bidders – Please note the following changes to the "Invitation to Bidders":

- a. Bid Opening – the time of the Bid Opening has been changed from 10:00 A.M., October 17, 2012 to October 19, 2012 at 10:00 A.M. Location of the Bid Opening per the Invitation to Bidders remains unchanged.



10-16-12

ACKNOWLEDGEMENT BY BIDDER

Each bidder is requested to acknowledge receipt of this Addendum No. 3 by his/her signature affixed hereto and to file same and attach with his/her bid.

The undersigned acknowledges receipt of this Addendum No. 3 along with the bid submitted herewith is in accordance with the information and stipulations set forth.

Date

Signature