



**W-9: Upper Leon Creek and W-52 Culebra Creek Capacity Relief
Contractor Outreach Meeting
ADDENDUM 1
October 13, 2023**

To Respondent of Record:

RESPONSES TO QUESTIONS

1. On W-52 sheets 2, 33, 40, and 41 a 108" diameter polymer concrete manhole (STA 63+83.27) is specified.

A 108" structure isn't typical or common and we would request to change this to 120" as we produce many 120" diameter structures and have the forms and hardware readily available to build that size.

Response: The design will be updated to specify a 120" diameter manhole.

END OF ADDENDUM 1

This Addendum is one (1) page in its entirety.