



NOTE:

1. The concrete shall be 4000 psi, min, and reinforced with No. 3 bar, as shown.
2. The concrete bricks are considered anchorage blocks for fire hydrants with various uses.
3. Brick dimensions are A-A = 8"x 2", B-B = 8"x 4", and C-C = 4"x 2".

PROPERTY OF <b>SAN ANTONIO WATER SYSTEM</b> SAN ANTONIO, TEXAS	<b>THRUST BLOCKS FOR          FIRE HYDRANTS</b>	APPROVED	REVISED
		APRIL 2013	
		<b>DD-839-01</b>	