

SAN ANTONIO WATER SYSTEM PURCHASING DEPARTMENT

Issued By: D. Anthony Rubin
BID NO.: 13-1454

Date Issued: April 17, 2013

FORMAL ADDENDUM FOR BID
CONTRACT FOR REHABILITATION OF WELL NO. 5 AND WELL NO. 16
ADDENDUM NO. 3

Sealed bids addressed to the Purchasing Director, San Antonio Water System, 2800 US Hwy 281 North, Administration Bldg., 5th Floor, P.O. Box 2449, San Antonio, TX 78298-2449 will be received until **3:00 p.m., April 19, 2013** and then publicly opened and read aloud for furnishing materials or services as described received herein below,

The San Antonio Water System Purchasing Department is willing to assist any bidder(s) in the interpretation of bid provisions or explanation of how bid forms are to be completed. Assistance may be received by visiting the Purchasing Office in the SAWS Main Office, 2800 US Hwy 281 North, San Antonio, TX 78212, or by calling (210) 233-3819.

This invitation includes the following:

Invitation for Bids
Terms and Conditions of Invitation for Bids

Specifications and General Requirements
Price Schedule

The undersigned, by his/her signature, represents that he/she is authorized to bind the Bidder to fully comply with the Specifications and General Requirements for the amount(s) shown on the accompanying bid sheet(s). By signing below, Bidder has read the entire document and agreed to the terms therein.

Signer's Name: _____ Firm Name: _____
(Please Print or Type)

Address: _____

Signature of Person Authorized to Sign Bid _____ City, State, Zip Code: _____

Email Address: _____ Telephone No.: _____

Fax No.: _____

Please complete the following:

Prompt Payment Discount: _____% _____ days. (If no discount is offered, Net 30 will apply.)

Please check the following blanks which apply to your company:

Ownership of firm (51% or more):

Non-minority Hispanic African-American Other Minority (specify) _____

Female Owned Handicapped Owned Small Business (less than \$1 million annual receipts or 100 employees)

Indicate Status: Partnership Corporation Sole Proprietorship Other (specify) _____

Tax Identification Number: _____

Questions or comments concerning rehabilitation of wells #5 & #16

Question 11: Page 17 of 28, Item #11, well development by pumping; this item does not pertain to rehabilitations of water wells. This is a guarantee generally associated with construction of new wells. The well's specific capacity and sand content was established during the drilling of the well. Any changes in specific capacity or sand content are not the responsibility of the contractor since we are following your program. Will this be removed?

Answer 11: Delete requirement for the "sand guarantee" and for specific reference to original design pump rates of approx. 1400 gpm. Item 11 changed to read as follow:

ITEM 11- WELL REDEVELOPMENT BY PUMPING

Each well shall be considered thoroughly developed when specific capacity (g.p.m. per foot of drawdown) remains relatively constant [±5 percent], and each well is considered sufficiently developed by the Owner. Additionally, the ph of the well water after development pumping must be at levels equal to ±.5 of the static ph levels measured prior to rehabilitation.

THIS ADDENDUM DOES NOT NEED TO BE RETURNED.