



Multiple Sewershed Package 17B
Solicitation Number: CO-00442
Job No.: 21-4525

ADDENDUM 2
April 19, 2022

To Bidder of Record:

This addendum, applicable to work referenced above, is an amendment to the bid proposal, plans and specifications and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the Addendum number and issue date on the space provided in submitted copies of the bid proposal.

RESPONSES TO QUESTIONS

1. The following information is needed: Line 118 - 5855 ft 8" no DR or OD specified

Answer: Please refer section 900.4.1.g of SAWS specification Item No. 900 ["RECONSTRUCTION OF SANITARY SEWER BY PIPE BURSTING REPLACEMENT PROCESS" \(2017 version\)](#) for the SDR requirements of this line item.

Please use Iron Pipe Size (IPS) standard outside diameters for HDPE pipe where not otherwise specified as required by section 2.h of the SAWS published ["SPECIFICATIONS FOR HIGH DENSITY POLYETHYLENE PIPE \(HDPE\)" \(Revised 2011\)](#).

2. The following information is needed: Line 119 - 1199 ft 8" DR 13.5 no OD specified

Answer: Please use Iron Pipe Size (IPS) standard outside diameters for HDPE pipe where not otherwise specified as required by section 2.h of the SAWS published ["SPECIFICATIONS FOR HIGH DENSITY POLYETHYLENE PIPE \(HDPE\)" \(Revised 2011\)](#).

3. The following information is needed: Line 120 - 580ft 8" DR 17 no OD specified

Answer: Ductile Iron Pipe Size (DIPS) is specified for this line item. Please use standard DIPS outside diameters.

4. Also, because Gray pipe is not available right now, would it be acceptable to use Black Pipe with Green stripes ?

Answer: SAWS will allow black HDPE pipe with green stripes for this project in substitution of the light-colored grey HDPE pipe specified in Item No. 900 ["RECONSTRUCTION OF SANITARY SEWER BY PIPE BURSTING REPLACEMENT PROCESS" \(2017 version\)](#). All other language in this Item No. 900 shall remain in full force.

CHANGES TO SPECIFICATIONS

1. SPECIAL CONDITIONS. Section 4.12 of the Special Conditions titled *"REQUESTS FOR CHANGES TO HDPE MATERIAL"* is hereby modified to read as follows:


"The Contractor may, at no additional cost to the Owner, substitute DR-11 HDPE with a pressure rating greater or equal to 160 PSI where DR-13.5, 160 PSI HDPE is specified in this contract.

The Contractor may also, at no additional cost to the Owner, substitute HDPE pipe that is black with green stripes in color where light-colored grey HDPE pipe material is specified in this contract.

All other proposed changes will require approval by the ENGINEER after contract award. "

END OF ADDENDUM

This Addendum is two (2) page in its entirety.



Alan Swartz

04/19/2022

Alan D. Swartz, PE
Plummer (TBPE No. F-13)