

SAN ANTONIO WATER SYSTEM
WATER RESOURCES INTEGRATION PROGRAM
TWIN OAKS WEST PUMP STATION PHASE I
SAWS JOB NO. 13-8611-220
SOLICITATION NO. B-14-013-DD

ADDENDUM NO. 1
August 11, 2014

To Bidder of Record:

This addendum, applicable to work designed above, is an amendment to the bidding documents and such will be a part of and included in the Contract. Each bidder shall acknowledge receipt of this addendum by entering the addendum number in the space provided in the Price Proposal.

A. QUESTIONS SUBMITTED TO SAWS

1. Reference Roof Plan on Drawing No. STO-02 (sheet 36 of 113). Our steel supplier has indicated that the "32 KCS w/5" Joist Seat" is not a valid joist description. They have indicated that the largest KCS joist is 30-inches
RESPONSE: This will be revised to "30 KCS w/5" Joist Seat" in Addendum No. 1.
2. There is a "PSI" company Bore Report that is referenced in the specifications. Can you direct me as to who I may call to get a copy of it?
RESPONSE: Instructions on obtaining the geotechnical report are included below as part of Addendum No. 1.

B. DRAWINGS.

1. Sheet STO-02 (36 of 113).
 - a. On the roof plan, change "32 KCS w/5" Joist Seat" to "30 KCS w/5" Joist Seat".

C. BIDDING AND CONTRACT REQUIREMENTS.

1. SPECIAL CONDITIONS.
 - a. Page 2, Article 4. Add the following article to the end of the section:

"4. GEOTECHNICAL REPORT. A Geotechnical Report has been developed for SAWS on this project and upon request will be made available for review by Contractors for information purposes only. (See Article 22 in Section 01015 for additional information.) Please contact Diana W. Dwyer via email at Diana.Dwyer@saws.org. SAWS will require execution of a SAWS disclaimer form by the Contractor as a condition of and prior to review of the report.

