

**SAN ANTONIO WATER SYSTEM  
CIBOLO CREEK SEWERSHED FLOW DIVERSION PROJECT  
SAWS PROJECT NO. 11-2511  
SOLICITATION NO. CO-00004  
ADDENDUM NO. 3**

**July 21, 2015**

This addendum, applicable to work designated above, is an amendment to the proposal and specification documents and as such shall be a part of and included in the Contract. Acknowledge receipt of this addendum by entering the addendum number and issue date in the spaces provided on all submitted copies of the proposal.

**1.0 Addenda Purpose**

The purpose of this addendum is to issue a revision to the Contract Documents, plans and specifications for Cibolo Creek Sewershed Flow Diversion Project (SAWS Job No. 11-2511).

**2.0 Modifications to Part II – TECHNICAL SPECIFICATIONS**

**A. SECTION 16600 – PART 1.3(A). ADD the following:**

“7. UL 142 Listed fuel storage system for minimum 24-hour operation at generator full load output in a dual wall sub-base fuel tank. Tank to be provided with leak alarm system.”

**B. SECTION 16600 – PART 1.3(B). ADD the following:**

“7. UL 142 Listed fuel storage system for minimum 24-hour operation at generator full load output in a dual wall sub-base fuel tank. Tank to be provided with leak alarm system.”

Date

*V. Ryan Sowa*

Signature



Kimley-Horn and Associates, Inc.  
Texas Registered Engineering Firm F-928  
601 NW Loop 410, Ste. 350  
San Antonio, TX 78216