

System Controls & Instrumentation, Ltd

11218 IH-10 E.
Converse, TX 78109
Phone: 210-661-9901
Fax: 210-666-5575

1108 Quail Hollow
Laredo, TX 78045
Phone: 956-725-1239
Fax: 956-726-1774

TECL # 18461

RESUBMITTAL Data for:

SAWS Leon Creek

Short Circuit & Overcurrent Device
Coordination Analysis



by Schneider Electric

Schneider Electric Engineering Services, LLC

2365 Harrodsburg Road, Suite B325
Lexington, KY 40504
(859) 296-3646

DATE: July 12, 2011

TO: Danny Burt / Dothan Field Office

FROM: Shibani Mishra / Schneider Electric Engineering Services, LLC

SUBJECT: SAWS-Leon Creek WRC
San Antonio, TX
F.O.# 25827923
Project# 10660

Dear Danny,

Electronic copies of the report for a Schneider Electric Engineering Services, LLC analysis performed for this site are being sent to your attention.

I appreciate the opportunity to have worked with you on this project. If you have questions, concerns, or require further assistance, please do not hesitate to contact me.

Regards,

Shibani Mishra

Leon Creek Water Recycling Center Improvements Phase II
Short Circuit Study-Resubmittal
Review Comments

1. Please evaluate based on short circuit ratings of the equipment buses as well as the protective devices. The bus rating may be lower than the device ratings.
2. From 5kV Motor Control Center submittal #43, the fuse is rated 9R and the CT ratio is 400:5. This is the latest MCC submittal received and does not match the proposed in this submittal and it is not understood why.
3. Please coordinate with Owner to gain access to equipment and include ratings in study.
4. Contract drawings and feeder sizes are based on 600AT. Please coordinate breaker settings with feeder and transformer.
5. This issue does not seem resolved. As stated previously, it appears that both 500kVA transformers AEL-XFMR-01A and AEL-XFMR-01B are contributing to the available short circuit at buses AEL-PDP-11A, AEL-PDP-11B, and AEL-PDP-12. As stated previously, the key interlock prevents this condition. Please revise.
6. Per specifications and MCC submittal the overload relay is Trip Class 20, please revise.
7. Please coordinate breaker with full load current of proposed pump. Contract drawings show a 100A breaker.
8. Please coordinate with CPS for actual impedance values for service transformers.
9. Please include MCC feeder cables. Coordinate size, length, etc. with contractor.
10. Transformer secondary conductors may be an unlimited length when in compliance with Article 240.21.C.4. Per specification section 16460.2.10 fuses shall be furnished by the manufacturer based on the results of the short circuit and coordination study. The manufacturer shall furnish the protective device of the appropriate characteristics that shall be the most suitable for the proper protection and coordination of the system.
11. Coordinate motor starting characteristics with motor manufacturer.

Leon Creek Water Recycling Center Improvements Phase II
Specification 16040
Manufacturer's Services
1.08A C, D, E, F,G, H, and I

SQD Responses to Study Review Comments
Dated July 8th, 2011

1. We evaluate the limiting factor (bus, breaker, or otherwise) in our studies. If the bus of the panel had a lesser rating, it would have been noted in the analysis.
2. Per the as built drawings we supplied a 12R fuse and a 250:5 CT
3. Access to the existing SWB-1 was requested to SAWS and denied to SCI and the GC.
4. We have revised to 600AT as confirmed and per the As Built drawings.
5. Updated SC calculation, panels AEL-PDP-11A and 11B are fed from AEL-XFMR-01A only, with AEL-XFMR-01B out of service.
6. Overload relay with trip Class 20 used.
7. The motor was confirmed to be 60HP. We supplied a MCP 150A. We size our MCP's based on NEC tables. The 150A MCP is good for 30-100HP. The 100A MCP stops at 50HP. Refer to Section 3.2.3 on setting Inst on MCPs
8. CPS provided a range for the %Z of 5.32 – 6.18. We are using 5.32 for worst case scenario.
9. Included.
10. Violations have been removed.
11. 60AT FA breakers to be supplied to remove the overlap.

Notes: The report hereby included addresses Paragraph C, D, E (in regards to the recommended/proposed motor protective relay settings – see Appendix D Setpoint File for Multilin SR469 Relays), F, G, H (Settings have been uploaded by SQD Field Technicians, and I. The remainder of Section E can not be performed until the flicker limit has been obtained from CPS – Requests have been made for this information.

Regards,
Danny Burt
Project Services Manager
Square D Company

**SHORT-CIRCUIT &
OVERCURRENT DEVICE COORDINATION ANALYSES**

**SAWS-Leon Creek WRC
San Antonio, TX**

Prepared by
Antony C. Parsons, Ph.D., P.E.,
&
Shibani Mishra
Schneider Electric Engineering Services, LLC
Firm F#10107

Schneider Electric Engineering Services, LLC Job Numbers Q2C: 25827923 Project: 10660	-	January 21, 2011
	Rev. 1	June 17, 2011
	Rev. 2	July 11, 2011
	Rev. 3	-

ELECTRICAL CONTRACTOR
DISTRIBUTOR
SQUARE D FIELD ENGINEER

SAWS Leon Creek WRC
Graybar Elect. Co.
Luis Chaparro/San Antonio

FILE: Saws Leon Creek



Antony C. Parsons, P.E.
7-12-11

The following power systems engineering report was prepared by Schneider Electric Engineering Services, LLC utilizing industry-accepted standards, practices, methodologies, and analysis tools. Data used in this analysis was acquired by Schneider Electric Engineering Services, LLC and provided by others, through onsite discovery, published information, equipment nameplates, manufacturer ratings, testing, analysis, or other means. Schneider Electric Engineering Services, LLC assumes no responsibility for inaccuracies in data provided by others. The study is intended for use by qualified individuals to facilitate the installation, operation, maintenance, and safety of the electrical power system depicted. Modification of equipment, changes to system configuration, adjustment of protective device settings, or failure to properly maintain equipment may invalidate these results.

TABLE OF CONTENTS

1 EXECUTIVE SUMMARY5

1.1 Introduction5

1.2 Scope of Work.....6

1.3 Results and Recommendations.....7

2 SHORT-CIRCUIT ANALYSIS8

2.1 General Procedure.....8

2.2 Data Used in the Calculations10

2.2.1 Power Company Data.....10

2.2.2 Cable Data10

2.2.3 Transformer Data.....10

2.2.4 Motor Contribution To Short-Circuit Current.....11

2.3 Short-Circuit Analysis Results and Recommendations13

2.4 Short-Circuit Evaluation Table.....14

3 OVERCURRENT DEVICE COORDINATION ANALYSIS 19

3.1 General Procedure.....19

3.2 Specific Procedure20

3.2.1 Short-Circuit Current Considerations20

3.2.2 Molded Case Breaker Coordination20

3.2.3 Motor Control Center Instantaneous Trip Breakers21

3.2.4 Low-Voltage Ground Fault Relay Settings23

3.2.5 Transformer Protective Devices24

3.2.6 Cable Protection25

3.2.7 Selective Coordination and the 2008 NEC.....25

3.2.8 Assumptions26

3.3 Analysis of Results and Recommendations27

3.3.1 TCC Plot Remarks.....27

3.4 Overcurrent Device Setting Table29

3.5 Time-Current Coordination Graphs - Recommended Settings.....33

APPENDIX A: ABBREVIATIONS AND TRADEMARKS49

APPENDIX B: SHORT CIRCUIT INPUT TABULATIONS51

APPENDIX C: SHORT CIRCUIT OUTPUT TABULATIONS78

APPENDIX D: REFERENCES.....97

APPENDIX E: SYSTEM STUDY ONE-LINE DIAGRAMS.....104

1 EXECUTIVE SUMMARY

1.1 Introduction

This report documents the results of a Schneider Electric Engineering Services, LLC analysis for the SAWS-Leon Creek WRC in San Antonio, TX. All studies were performed using the Power*Tools for Windows Software, version 6.5.1.4.

System one-line description was obtained from the project design drawings. Cable and Utility data was supplied by the contractor. Square D equipment details were obtained from factory records. Abbreviations and trademarks referenced throughout this report are also listed in an appendix.

The system short-circuit analysis evaluates the adequacy of the distribution equipment shown on the enclosed one-line diagrams to withstand or to interrupt the calculated maximum available short-circuit current at its location.

The overcurrent device time-current coordination analysis determines the suggested settings and, where appropriate, the ampere ratings and types for the electrical power system protective devices to achieve the desired system protection and electrical service continuity goals.

This report supersedes and invalidates results from any study, performed by Schneider Electric Engineering Services, LLC or any other entity, for the scope of equipment being reviewed.

Electrical system changes within the facility or in the utility system can have a significant impact on the results of this power system analysis, which is a “snapshot” of as-found system conditions. As such, it is recommended that this analysis be re-evaluated on a regular basis, not to exceed 5 years, to account for electrical system changes. Failure to properly maintain equipment may invalidate these results.

1.2 Scope of Work

The scope of this study is limited to that equipment shown on the study one-line diagrams located in the back of the report and present in the bill of material. Unless specifically required by job specifications, branch circuit utilization equipment, as defined per NEC Article 100, was not included in this study (this may consist of small equipment, 100A and less, such as: safety switches, industrial control panels, and enclosed starters/drives). Note that the existing generator feeding HEL-ATS-01 has not been evaluated. Additional generator breaker and submittal data will be required if emergency side evaluation is required for HEL-ATS-01.

1.3 Results and Recommendations

Short-circuit:

The results of the short-circuit analysis show that the equipment considered in the study is adequately rated for the projected fault current levels.

For further discussion regarding these results, please refer to the Short Circuit Analysis Results and Recommendations section.

Coordination:

The coordination study showed that for the most part, an acceptable level of selectivity was achieved among devices in the system except for 005.tcc, 006.tcc, 007.tcc, 008.tcc, 010.tcc, 011.tcc and 013.tcc. If selective coordination according to NEC 700 is required, further analysis beyond the scope of this study will be necessary. In general, additional levels of distribution make it difficult to achieve selective coordination according to NEC 700 without oversized electrical equipment (ampacity and physical footprint). Larger equipment and changes to the cable and conduit layout may have an impact on the architectural design.

Note that the settings for motor overload relay shown on 09.tcc and 15.tcc are typical; in the field, they should actually be set per motor FLA.

The breakers and relays in the system should be set to the recommended levels. For further discussion regarding these results, please refer to the Time Current Coordination Analysis of Results and Recommendations.

Refer to each subsequent “Analysis of Results and Recommendations” section for further details. If these issues are addressed by equipment, conductor, or device settings changes, the power system study results may need to be re-evaluated in a revision to this study.

2 SHORT-CIRCUIT ANALYSIS

2.1 General Procedure

An electrical system short-circuit analysis is used for the following:

- 1) To compare the calculated maximum fault current with the interrupting ratings of overcurrent protective devices such as fuses and circuit breakers.
- 2) To investigate applicable short-circuit series ratings and the protection of electrical equipment by current-limiting devices.
- 3) To verify the adequacy of other equipment, such as switches and equipment bussing, to withstand the effects of the calculated maximum fault current levels.
- 4) To assist in the selection and/or determination of settings for relays, fuses and circuit breakers.

This analysis was made utilizing SKM Power Tools software. The software was programmed to calculate the maximum available three-phase, RMS symmetrical, short-circuit amperes at each piece of equipment in the system. The calculation procedures are based on recommendations included in ANSI/IEEE standards C37.13, C37.010, and C37.5.

The AFAULT module of the Power*Tools software simulates a bolted three-phase fault at each point of consideration in the system and calculates the maximum available short-circuit current at that point without any reduction due to current-limiting overcurrent devices which may be present. (However, the effects of current-limiting devices are considered when determining the adequacy of the equipment.) The calculated short-circuit values are RMS symmetrical amperes and are comparable with the RMS symmetrical short-circuit ratings of electrical equipment.

Electrical distribution equipment must be able to withstand and/or interrupt the most severe fault duty that it may be subjected to at its location in the system. In particular, NEC Section 110.9 requires circuit breakers to have a rating sufficient for interrupting the maximum available fault current present at their line side terminals. For locations where calculated fault currents exceed the ratings of the equipment, recommendations for corrective actions are provided.

Equipment short-circuit withstand and interrupting ratings are expressed in symmetrical RMS current. However, fault currents are not purely symmetrical in practice, as system inductance introduces a degree of asymmetry for at least the first few cycles of a fault. The magnitude and duration of this asymmetrical component depends on several factors, including characteristics of system components (conductors, transformers, and loads) and the exact point on the current waveform that the fault begins—the level of asymmetry even differs from phase to phase in a three-phase system. Because of the uncertainty in asymmetry for a given fault event, the capability of devices to interrupt asymmetrical fault current is based on the maximum possible asymmetrical fault current level at the point of application. The more inductive the circuit, as measured by the calculated system X/R ratio, the more asymmetrical the fault current can be. If the calculated X/R level exceeds a certain level, then the increased asymmetrical duty must be taken into account when breaker ratings are assessed.

Low-voltage circuit breakers and fuses are tested to establish their interrupting ratings based on a circuit with a fixed X/R ratio, as defined in the various product standards (UL and ANSI). For example, an ANSI low-voltage power circuit breaker is tested in a circuit with an X/R ratio of

6.591. If such a breaker is applied at a system bus with a calculated X/R ratio of 6.591 or less and the calculated RMS symmetrical fault current is within the symmetrical interrupting rating of the breaker, then it is assumed that the breaker is also able to interrupt and withstand the asymmetrical current resulting from a fault at that location. If a low voltage breaker is applied at a location with an X/R ratio greater than that of the design test circuit, the calculated fault current must be multiplied by an adjustment factor that accounts for this. This resultant “fault duty,” which is greater than the calculated fault current, is then compared to the breaker’s interrupting rating in order to determine if the breaker is adequately rated. Different classes of low-voltage breakers have different test X/R values, and each type has its own set of multiplication factors. Design test circuit power factors and associated X/R ratios are as shown in **Table 1**. The SKM low-voltage short-circuit output report shows the calculated fault duty levels calculated at each bus, and when these values differ from the calculated short-circuit current levels, they are used in the device evaluation tables. See IEEE 1015-1997, *IEEE Recommended Practice for Applying Low-Voltage Circuit Breakers Used in Industrial and Commercial Power Systems*, for additional details.

Table 1: Summary of Test Power Factor and X/R Values for LV Devices.

Device	pf	X/R Ratio
Power circuit breaker, unfused	0.15	6.591
Power circuit breaker, fused	0.20	4.899
Molded case breaker, interrupting rating greater than 20000 A	0.15-0.20	6.591-4.899
Molded case breaker, interrupting rating 10001 to 20000 A	0.25-0.30	3.9-3.18
Molded case breaker, interrupting rating 10000 A and less	0.45-0.50	2.0-1.732

For power circuit breakers, the power factors are taken from ANSI/IEEE C37.13. For molded case breakers, the power factors are taken from NEMA standard AB1. Since the NEMA standard specifies a range of test circuit power factors, the highest value (lowest X/R ratio) is used to determine the multiplying factor. This produces the most conservative (largest) factor.

The included one-line diagrams are a simplified version of the system drawings, showing only those parts of the electrical system under consideration. The various circuit locations on the diagrams have been labeled with bus identification numbers so input data could be supplied to the computer and the computer output could be readily interpreted.

2.2 Data Used in the Calculations

2.2.1 Power Company Data

CPS Energy has advised that their system is capable of delivering a maximum available three-phase short-circuit current of 1233A at 13800V with an X/R ratio of 2.42. This short-circuit current determined the starting point for the analysis and is provided from existing circuit B421 out of Chavaneaux Rd. Substation. CPS Energy provides an additional maximum available three-phase short-circuit current of 2912A at 13800V with an X/R ratio of 2.339. This new fault current will be fed from future circuit A522 out of Mauermann Rd Substation which will replace the existing Chavaneaux Rd. Substation.

For worst case short circuit condition one set of parallel service transformer is considered in service and the ties are closed in for both the existing and future cases. The panelboards AEL-PDP-11A and AEL-PDP-11B are fed from AEL-XFMR-01A, with ties closed and main breaker on AEL-PDP-11B open.

2.2.2 Cable Data

The "FEEDER INPUT DATA" computer printouts list the conductor (cable and/or busway) data used for each circuit segment. Included are lengths, number per phase, size, conductor material, cable insulation type, conduit material and resistance and reactance values. Also, conductor lengths, number per phase, and size and conductor material are recorded on the one-line diagrams.

Resistance values are based on 25 degrees Celsius (room temperature) rather than the full load temperature usually shown in descriptive literature since short-circuits can occur when the circuit is initially energized or lightly loaded as well as when fully loaded. The resistance and reactance values are typical values obtained from a study of data from various conductor manufactures. Values are tabulated according to whether several single conductors or one multiple conductor is used and whether the conduit is steel, aluminum or plastic.

2.2.3 Transformer Data

Square D nameplate transformer percent impedance and typical X/R ratio values were used for all transformers. The exact R and X component values used are shown on the "TRANSFORMER INPUT DATA" printouts.

2.2.4 Motor Contribution To Short-Circuit Current

Motor contribution to the short-circuit current is taken into account in this short-circuit analysis. During the first few cycles of a fault, running motors act as generators and produce a current which will combine with the source short-circuit current flowing to the fault as illustrated in **Figure 1**. Sources may be, but are not limited to, the Power Company, local generators, or both.




Figure 1: Example motor contribution.

Connected motors shown on the study one-line were assumed to be running at the time of the fault. Motors fed by adjustable speed drives equipped with bypass contactors were considered to contribute to system fault currents as well. However, motors fed by drives without bypass contactors were not considered since they do not contribute to fault current. Redundant motors shown on the study one-line were also assumed to be running at the time of the fault unless operating controls prohibit these conditions.

A motor's contribution to a fault *at its terminals* is equal to the full-load ampere (FLA) rating of the motor divided by its per-unit subtransient reactance, similar to the contribution from a generator. However, at the upstream switchboard, panelboard, or motor-control center, the fault contribution from the individual motors is reduced by the impedance of the motor branch circuit conductors. Since data on motor subtransient reactances and branch-circuit conductor lengths is often difficult to obtain, assumptions regarding the motors' subtransient reactances are typically made when the system model is built.

For calculation of low-voltage fault duty, the contribution from induction motors and synchronous motors in the system are considered. For small induction motors (less than 50 hp) where the impedance of the installation (i.e., motor and conductor) is not known, an equivalent subtransient reactance of 0.25 pu, resulting in a fault contribution of 4 times rated current, is assumed. Larger motors (50 hp and above) have an assumed subtransient reactance of 0.2 pu, resulting in a fault contribution of 5 times rated current. This is consistent with recommendations in IEEE Std. 141, *IEEE Recommended Practice for Electric Power Distribution for Industrial Plants* (the IEEE Red Book).

If applicable, multiplying factors are adjusted per Table 7 of ANSI/IEEE C37.010, *IEEE Application Guide for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis for medium/high voltage fault duty*. The table also shows contributions from induction motors less than 50 hp to be neglected.

The motor short-circuit contribution is determined and included in the computer short-circuit analysis so that the results should represent the highest short-circuit current to which the equipment might be subjected.

Unless otherwise indicated in the "CONTRIBUTION DATA" computer printouts, some motor loads are modeled as lumped induction motors connected directly to the low voltage buses using the recommended subtransient reactance values from C37.010, C37.13, and IEEE Std. 141. These

modeled values appear on the "CONTRIBUTION DATA" and the "FAULT REPORT" computer printouts.

2.3 Short-Circuit Analysis Results and Recommendations

After making the calculations, the distribution equipment was checked to determine its adequacy to interrupt or withstand the effects of the calculated maximum short-circuit current at its location. For some solidly-grounded systems, like close-coupled unit substations and generator gear, it is possible the bolted three-phase fault current is not the maximum fault current. The power systems engineer performing the study considered applicable buses and has reported bolted line-to-ground fault current when required. The results are listed in the "SHORT-CIRCUIT EVALUATION TABLE".

For worst case short circuit condition one set of parallel service transformer is considered in service and the ties are closed for both the existing and future cases. The panelboards AEL-PDP-11A and AEL-PDP-11B are fed from AEL-XFMR-01A, with ties closed and main breaker on AEL-PDP-11B open.

Listed in the tables are the calculated short-circuit currents at each piece of equipment and the ratings of the lowest rated device in the equipment enclosure. Comparing the two sets of values shows that all of the equipment examined is either adequate by itself or when used in series with another circuit breaker or protected by a line side current-limiting fuse or circuit breaker.

If applicable, equipment using series ratings that are shown in the short-circuit evaluation table must meet field labeling requirements per NEC Sections 110.22 and 240.86(B). There are two types of markings which must be present; the first requires series combination ratings to be marked on equipment by the manufacture. The second equipment marking must be readily visible and state the following:

CAUTION – SERIES COMBINATION SYSTEM RATED _____ AMPERES.
IDENTIFIED REPLACEMENT COMPONENTS REQUIRED.

This labeling serves as a warning to those who may install new breakers or replace existing breakers at the given location in the future, alerting them to the fact that a specific device type must be used in order to ensure that the series rating is maintained.

The short-circuit evaluation table shows buses with #N/A in the "NOTES" column. This is defined at the bottom of the table as #N/A = Number not available. Some of these buses do not require evaluation and may correspond to equipment such as transformer windings or motor terminals.

Input data and short-circuit output data pages are included in separate appendices.

2.4 Short-Circuit Evaluation Table



by **Schneider Electric**
 SQUARE D ENGINEERING SERVICES

**SHORT-CIRCUIT
 EVALUATION TABLE**

**SAWS LEON CREEK WRC
 SAN ANTONIO, TX
 D-ML-10-660-1,2
 EXISTING UTILITY SERVICE**

BUS NO.	EQUIP. DESCRIPTION PER SYSTEM ONE LINE DIAGRAM(S)	NOMINAL L-L VOLTS	LOWEST RATED DEVICE IN EQUIPMENT ENCLOSURE		MAXIMUM AVAILABLE SCA OR DUTY	X/R RATIO	LINE SIDE MAXIMUM DEVICE	LINE SIDE SERIES RATING	NOTES	
			TYPE	AIC OR WCR					EVALUATION	#
001	AMC-MCC-01A	4160.0		42,000	7,290	9.388			#N/A	
002	LC-AASBC01	4160.0		#N/A	7,219	8.922			#N/A	
003	LC-AASBC02	4160.0		#N/A	7,219	8.922			#N/A	
005	AEL-PDP-11A	480.0	SCCR14	14,000	10,434	4.844			Adequate	
006	AIS-LCP-01	480.0	SCCR14	14,000	8,209	2.331			Adequate	
007	AIS-LCP-02	480.0	SCCR14	14,000	8,209	2.331			Adequate	
008L	AEL-ATS-01	480.0	SCCR22	22,000	9,012	3.976			Adequate	
009	AEL-PDP-12	480.0	SCCR14	14,000	8,739	3.364			Adequate	
010	AEL-LP-11	208.0	QOB(1P)/15-30A	10,000	5,178	0.719			Adequate	
011	AEL-CPP-11	208.0	QOB(1P)/15-30A	10,000	1,640	2.398			Adequate	
012	AEL-MPC-01	208.0	QOB(1P)/15-30A	10,000	1,471	2.027			Adequate	
013	AEL-MPC-02	208.0	QOB(1P)/15-30A	10,000	1,301	1.650			Adequate	
014	AMC-MCC-01B	4160.0		42,000	7,278	9.374			#N/A	
015	AEL-PDP-11B	480.0	SCCR14	14,000	10,433	4.844			Adequate	
016	AIS-LCP-03	480.0	SCCR14	14,000	8,208	2.330			Adequate	
017	AIS-LCP-04	480.0	SCCR14	14,000	8,208	2.330			Adequate	
018	LC-AASBC03	4160.0		#N/A	7,208	8.911			#N/A	
019	LC-AASBC04	4160.0		#N/A	7,208	8.911			#N/A	
100	PLANT MAIN SWBD SWB-1	4160.0		100,000	2,659	3.607			#N/A	
101	FUSE CUT-OUTS	4160.0		#N/A	2,659	3.607			#N/A	
102	HV44	4160.0		#N/A	2,579	3.206			#N/A	
103L	HEL-ATS-01	480.0	SCCR22	22,000	6,870	3.849			Adequate	
104	MCC-1	480.0	SCCR42	42,000	6,560	3.590			Adequate	
105	HEL-PDP-01	480.0	SCCR14	14,000	5,412	1.763			Adequate	
106	HEL-LP-01	208.0	QOB(1P)/15-30A	10,000	2,238	1.117			Adequate	
107	HEL-CPP-01	208.0	QOB(1P)/15-30A	10,000	784	2.023			Adequate	
108	PELXFM PRI	4160.0		#N/A	2,617	3.425			#N/A	
109	PMC-MCC-02	480.0	SCCR42	42,000	7,232	3.804			Adequate	
110	AEL-PDP-02	480.0	SCCR14	14,000	4,482	1.121			Adequate	
111	FUSE CUT-OUTS	4160.0		#N/A	2,637	3.539			#N/A	
112	PMC-MCC-01	480.0	SCCR42	42,000	5,227	4.284			Adequate	
113	AEL-PDP-01	480.0	SCCR14	14,000	3,012	1.046			Adequate	
114	PEL-PDP-01	480.0	SCCR14	14,000	4,186	1.638			Adequate	
115	SEL-PDP-11	480.0	SCCR14	14,000	5,488	4.019			Adequate	
116	SEL-LP-12	240.0	QOB(1P)/15-30A	10,000	2,236	2.972			Adequate	

#N/A = Number not available.



by **Schneider Electric**
 SQUARE D ENGINEERING SERVICES

**SHORT-CIRCUIT
 EVALUATION TABLE**

SAWS LEON CREEK WRC
 SAN ANTONIO, TX
 D-ML-10-660-1,2
 EXISTING UTILITY SERVICE

BUS NO.	EQUIP. DESCRIPTION PER SYSTEM ONE LINE DIAGRAM(S)	NOMINAL L-L VOLTS	LOWEST RATED DEVICE IN EQUIPMENT ENCLOSURE		MAXIMUM AVAILABLE SCA OR DUTY	X/R RATIO	LINE SIDE MAXIMUM DEVICE	LINE SIDE SERIES RATING	NOTES	
			TYPE	AIC OR WCR					EVALUATION	#
117	SEL-CPP-11	208.0	QOB(1P)/15-30A	10,000	792	2.104			Adequate	

#N/A = Number not available.



by **Schneider Electric**
 SQUARE D ENGINEERING SERVICES

SHORT-CIRCUIT
 EVALUATION TABLE

SAWS LEON CREEK WRC
 SAN ANTONIO, TX
 D-ML-10-660-1,2
 FUTURE UTILITY SERVICE

BUS NO.	EQUIP. DESCRIPTION PER SYSTEM ONE LINE DIAGRAM(S)	NOMINAL L-L VOLTS	LOWEST RATED DEVICE IN EQUIPMENT ENCLOSURE		MAXIMUM AVAILABLE SCA OR DUTY	X/R RATIO	LINE SIDE MAXIMUM DEVICE	LINE SIDE SERIES RATING	NOTES	
			TYPE	AIC OR WCR					EVALUATION	#
001	AMC-MCC-01A	4160.0		42,000	10,089	8.525			#N/A	
002	LC-AASBC01	4160.0		#N/A	9,951	7.954			#N/A	
003	LC-AASBC02	4160.0		#N/A	9,951	7.954			#N/A	
005	AEL-PDP-11A	480.0	SCCR14	14,000	10,767	4.736	MG		Adequate	
006	AIS-LCP-01	480.0	SCCR14	14,000	8,469	2.268			Adequate	
007	AIS-LCP-02	480.0	SCCR14	14,000	8,469	2.268			Adequate	
008L	AEL-ATS-01	480.0	SCCR22	22,000	9,333	3.881			Adequate	
009	AEL-PDP-12	480.0	SCCR14	14,000	8,976	3.282			Adequate	
010	AEL-LP-11	208.0	QOB(1P)/15-30A	10,000	5,213	0.710			Adequate	
011	AEL-CPP-11	208.0	QOB(1P)/15-30A	10,000	1,642	2.393			Adequate	
012	AEL-MPC-01	208.0	QOB(1P)/15-30A	10,000	1,473	2.023			Adequate	
013	AEL-MPC-02	208.0	QOB(1P)/15-30A	10,000	1,304	1.647			Adequate	
014	AMC-MCC-01B	4160.0		42,000	10,064	8.496			#N/A	
015	AEL-PDP-11B	480.0	SCCR14	14,000	10,766	4.736	MG		Adequate	
016	AIS-LCP-03	480.0	SCCR14	14,000	8,468	2.268			Adequate	
017	AIS-LCP-04	480.0	SCCR14	14,000	8,468	2.268			Adequate	
018	LC-AASBC03	4160.0		#N/A	9,927	7.932			#N/A	
019	LC-AASBC04	4160.0		#N/A	9,927	7.932			#N/A	
100	PLANT MAIN SWBD SWB-1	4160.0		100,000	4,057	4.486			#N/A	
101	FUSE CUT-OUTS	4160.0		#N/A	4,057	4.486			#N/A	
102	HV44	4160.0		#N/A	3,882	3.618			#N/A	
103L	HEL-ATS-01	480.0	SCCR22	22,000	7,651	4.061			Adequate	
104	MCC-1	480.0	SCCR42	42,000	7,270	3.737			Adequate	
105	HEL-PDP-01	480.0	SCCR14	14,000	5,882	1.709			Adequate	
106	HEL-LP-01	208.0	QOB(1P)/15-30A	10,000	2,269	1.105			Adequate	
107	HEL-CPP-01	208.0	QOB(1P)/15-30A	10,000	788	2.020			Adequate	
108	PELXFM PRI	4160.0		#N/A	3,964	4.050			#N/A	
109	PMC-MCC-02	480.0	SCCR42	42,000	7,977	3.951			Adequate	
110	AEL-PDP-02	480.0	SCCR14	14,000	4,735	1.068			Adequate	
111	FUSE CUT-OUTS	4160.0		#N/A	4,009	4.318			#N/A	
112	PMC-MCC-01	480.0	SCCR42	42,000	5,650	4.504			Adequate	
113	AEL-PDP-01	480.0	SCCR14	14,000	3,136	1.008			Adequate	
114	PEL-PDP-01	480.0	SCCR14	14,000	4,450	1.593			Adequate	
115	SEL-PDP-11	480.0	SCCR14	14,000	5,960	4.141			Adequate	
116	SEL-LP-12	240.0	QOB(1P)/15-30A	10,000	2,266	2.973			Adequate	

#N/A = Number not available.



by Schneider Electric
 SQUARE D ENGINEERING SERVICES

**SHORT-CIRCUIT
 EVALUATION TABLE**

**SAWS LEON CREEK WRC
 SAN ANTONIO, TX
 D-ML-10-660-1,2
 FUTURE UTILITY SERVICE**

BUS NO.	EQUIP. DESCRIPTION PER SYSTEM ONE LINE DIAGRAM(S)	NOMINAL L-L VOLTS	LOWEST RATED DEVICE IN EQUIPMENT ENCLOSURE		MAXIMUM AVAILABLE SCA OR DUTY	X/R RATIO	LINE SIDE MAXIMUM DEVICE	LINE SIDE SERIES RATING	NOTES	
			TYPE	AIC OR WCR					EVALUATION	#
117	SEL-CPP-11	208.0	QOB(1P)/15-30A	10,000	795	2.101			Adequate	

#N/A = Number not available.

3 OVERCURRENT DEVICE COORDINATION ANALYSIS

3.1 General Procedure

An overcurrent device time-current coordination analysis is an organized effort to determine the settings and, where appropriate, the ampere ratings and types for the over-current protective devices in an electrical system. The objective of the coordination analysis is to effect a time-current coordination among the devices, thereby achieving the desired system protection and electrical service continuity goals.

Maximum protection requires that the overcurrent protective devices be rated, selected, and adjusted to allow the normal load currents to flow while instantaneously opening the circuit when abnormal currents flow.

However, maximum service continuity requires that the overcurrent protective devices be rated, selected, and adjusted so that only the overcurrent protective device nearest the fault opens and isolates the faulted circuit from the system, permitting the rest of the system to remain in operation. Protective devices farther from the fault location should therefore essentially act as backup protection for the devices nearer to the fault, allowing the fault to be cleared with a minimum of disruption to the system. This is referred to as “selective coordination” between the protective devices. This may allow longer duration faults when the fault point is nearer the service entrance; however, such faults are not as common, and setting the protective devices to operate in this manner is generally more desirable than deenergizing most or all of the system for a fault near one of the loads.

Selecting and setting the overcurrent devices is a procedure where the time-current characteristic curves of the various devices in series are compared with one another on a log-log graph. This procedure should take into account boundaries defined by load currents, short-circuit currents, and ANSI and NEC requirements.

Selective coordination usually will be obtained when the log-log plots of time-current characteristics show sufficient clear space or no overlap between the curves for the protective devices operating in series. Coordination will often stop short of complete selectivity when an acceptable compromise is reached between the various boundaries imposed on the selecting and setting procedure.

The CAPTOR module of the SKM Power*Tools software was used to complete the device coordination analysis. As shown on the one-line diagrams, each overcurrent protective device or motor under consideration by the program has been assigned an identification number so that the computer output could be readily interpreted.

3.2 Specific Procedure

3.2.1 Short-Circuit Current Considerations

All protective device characteristic curves shown on the time-current graphs end at the calculated maximum short-circuit current at that device.

3.2.2 Molded Case Breaker Coordination

A molded case circuit breaker will trip with no intentional time delay for short-circuit currents above its instantaneous trip setting. Because of this, molded case breakers in series can only be selectively coordinated with each other if there is sufficient impedance between them so that the maximum available short-circuit current at the downstream breaker is less than the instantaneous trip setting of the upstream breaker. In **Figure 2**, breaker “C” illustrates this principle.




Figure 2: Example molded case breaker coordination.

There is enough cable impedance to limit the maximum available short-circuit current at “C” to less than the instantaneous trip setting of either “A” or “B”. When molded case breakers are in series without sufficient impedance between them to permit complete coordination, e.g., a panel main breaker and one of the branch devices in the panel, the time-current curves will overlap in the high-current instantaneous trip region. This is illustrated by the overlap between the curves for

devices “A” and “B” in **Figure 2**. Most molded case breakers exhibit some degree of current limitation that will often result in selective operation in the overlap region. Time-current coordination curves included in this report do not match the results from Square D’s data bulletin (0100DB0501R3). The software used to generate the curves is incapable of accounting for the dynamic impedance the system has when two or more devices in series “see” a fault. The data bulletin takes the dynamic impedance introduced by the downstream device into account. Greater separation between the instantaneous settings may increase the likelihood that the two devices will operate selectively. The potential lack of coordination is generally not considered critical and can be avoided only by adopting a different and, in general, less economically practical design especially when the following are considered:

- Most faults occur in equipment such as motors, lighting panels, and process control panels which typically are located at the end of branch circuits, significantly reducing fault level and thereby reducing or eliminating the possibility of non-selective operation.
- Lower magnitude arcing faults in rotating machinery and lighting panels are statistically more common than bolted three-phase faults.
- Ground faults are more common than three-phase faults.
- Maximum fault current is a random event depending on point-on-wave of the fault occurrence and other factors.
- The device cutoff points on time-current coordination graphs are based on bolted fault current levels which correspond to zero impedance. Typical fault current impedance is usually greater than zero so the actual fault current seen by overcurrent devices can be less than what is shown on the time-current coordination graphs.

Recommended breaker trip settings are given in the "OVERCURRENT DEVICE SETTING TABLE – LV CIRCUIT BREAKERS". In addition, an illustration of the actual magnetic trip adjustment dials for Square D circuit breakers is included in the REFERENCES section to aid the setting process.

3.2.3 Motor Control Center Instantaneous Trip Breakers

Specific settings are not suggested for the motor control center instantaneous trip circuit breakers, otherwise referred to as motor circuit protectors (MCPs). Instead, Schneider Electric Engineering Services, LLC assumes that they have been previously field adjusted per the following:

- The setting should be field adjusted just high enough to allow the motor to start without tripping the breaker and not exceed the NEC Article 430 guidelines for best protection.

Square D offers two different types of MCPs with one being a traditional type and another which is an electronic version, refer Figure 3 below. Each one is discussed further, but both may or may not actually exist in this particular project.

Specific settings are not suggested for the motor control center MAG-GARD instantaneous trip circuit breakers. Instead, Schneider Electric Engineering Services, LLC recommends that they be field adjusted. All MAG-GARD breakers are automatically set at LO when shipped from the factory. The setting may need to be adjusted for proper motor startup. For best protection, it is suggested the final setting be field adjusted just high enough to allow the motor to start without tripping the breaker. However, when using this setting procedure, it should not be assumed a breaker tripped because of normal motor starting current - a fault or overload may indeed exist. Furthermore, the number of motor starts attempted within any time period should not exceed the

motor manufacturer's recommendations. The final setting should not exceed the NEC guidelines given in Article 430.

Settings for the motor control center PowerPact electronic MCPs are shipped with default settings corresponding to the minimum FLA and **Auto 1**; however, these should be field adjusted based on the characteristics of the motor being protected.




Figure 3: Example of MCP setting dial.

Schneider Electric Engineering Services, LLC recommends that the FLA dial (Figure 3) be set to match the nameplate data of the motor. If it does not match up exactly, then choose the next closest lower value. Additionally, the instantaneous dial ($I_m \times FLA$) can be set using either Auto settings or Manual mode.

- Manual mode settings can be chosen for traditional motor protection from 600% to 1300% times the selected FLA and should follow the same approach described for MAG-GARD circuit breakers.
- **Auto 1** can be used for Standard type NEMA and IEC motors whereas **Auto 2** can be used for Energy Efficient motors as indicated in Figure 3. Both of the Auto settings provide a dampening means to accommodate transient motor inrush currents and at the same time not resulting in an overly high adjustment. The maximum percentage of full-load current for Auto 1 will not exceed 1300%, whereas Auto 2 will not exceed 1700%.

3.2.4 Low-Voltage Ground Fault Relay Settings

The main ground fault time setting was chosen to selectively coordinate with the appropriate load side devices. The ground fault current pickup setting was chosen to selectively coordinate with small load side branch breakers rated 20A and smaller with the consideration that most of the exposure to ground faults would likely occur in the electrical system downstream of these numerous small breakers.

Selective coordination with larger downstream breakers does not exist for any ground fault current exceeding the pickup setting but less than the magnetic setting of the load side breaker. This is unavoidable because the larger load side protective devices are not equipped with ground fault protection. **Figure 4** illustrates this.




Figure 4: Example ground fault coordination (current scale X 10).

As shown in **Figure 4**, the main ground fault device A selectively coordinates with the small branch breaker C but not with the larger feeder breaker B for ground fault currents in the range of 640A-1,900A as indicated.

All ground fault settings are tabulated in the appropriate overcurrent device setting tables.

3.2.5 Transformer Protective Devices

If in the project scope, medium- and/or low-voltage transformer primary overcurrent protective devices were checked for compliance with NEC Article 450. Also, medium voltage protective devices, primary, secondary and secondary feeder, were evaluated with respect to the applicable ANSI/IEEE Through Fault Guides (C57.12.59 for dry and cast resin type and C57.109 for liquid immersed type) and the Appendix for ANSI/IEEE C37.91. Transformer standards define low-voltage transformers as having a primary voltage less than or equal to 600V. Transformer full load currents and magnetizing inrush currents were also considered.

If a transformer is subject to a through fault, thermal damage occurs to conductors and insulation due to resistive heating. Mechanical damage occurs to windings and structural components due to large magnetic forces associated with the fault current. In general, smaller transformers are assigned a single damage characteristic that accounts for both thermal and mechanical damage. Larger transformers are assigned a two-part characteristic with a thermal characteristic and a more restrictive mechanical characteristic. For the most conservative protection, the thermal-mechanical limits should be used. In many cases, it may be acceptable to use only the thermal characteristic, especially if the transformer is not subject to frequent through faults. Transformers connected to overhead secondary feeders should be considered to be subject to frequent through faults.

To evaluate through fault protection according to the ANSI Guides, the applicable curve was plotted representing a transformer's projected damage threshold for the cumulative effects of through faults. However, this ANSI through fault curve must be reduced for certain unbalanced secondary faults, because even though full short-circuit current is flowing in one or more secondary windings, the primary overcurrent device experiences less current.

Secondary line-to-neutral faults on delta-wye connected transformers produce only 0.577 of the maximum 3-phase fault current in the primary overcurrent device while one secondary winding experiences the full short-circuit current as illustrated in **Figure 5** below. Therefore, to account for this fault condition, the ANSI through fault curve has been adjusted by a factor of 0.577. Both curves (three phase line-to-line and single phase line-to-neutral) are plotted on the time-current graphs.




Figure 5: Delta-Wye 3-PH and L-N fault current per unit values.

Since the through fault curves represent a transformer's projected damage threshold for the cumulative mechanical and thermal effects of through faults, all applicable primary and secondary

overcurrent devices were checked to ensure interruption before these through fault curves were reached.

Further, to avoid nuisance interruptions, the primary overcurrent devices were also checked to ensure they will carry the transformers rated full load and equivalent magnetic inrush currents which are plotted on the time-current graphs.

Because of the restrictions mentioned above, complete selective coordination between the transformer primary and secondary main devices may not exist for transformers examined as shown by the overlapping of their characteristics on the time-current graphs. However, this is judged acceptable, because the opening of either device results in the same extent of service interruption.

3.2.6 Cable Protection

Feeder overcurrent protective devices were reviewed to verify the protection of their load side cables as shown on the one-line diagrams in accordance with NEC Article 240. If the adjustable low-voltage protective devices are set as suggested in this report, then the cables reviewed will be properly protected, unless noted otherwise in the *NEC Compliance Issues* section.

The above analysis does not include any aspects of cable ampacity adjustment factors such as derating for conduit fill, elevated ambient temperature, and so on allowed by the NEC.

It should be noted that if a low voltage phase conductor is properly sized per NEC 240, then it is not possible to damage the phase conductor during short-circuits below the AIC rating of the breaker protecting the phase conductor. UL tests to verify the short-circuit rating of a circuit breaker are performed considering 75°C cable. The corresponding phase conductor is sized according to the NEC and must pass the fault tests without compromising its integrity. Therefore, the ICEA cable withstand curves have not been included on the time-current coordination graphs.

3.2.7 Selective Coordination and the 2008 NEC

In some situations, even though individual devices are not coordinated, the system may still be considered to be well-coordinated. For example, where two devices are in series with no loads connected between them, operation of either/both devices interrupts power to the exact same portion of the power system. The system may be considered to be coordinated even though the two devices, strictly speaking, do not coordinate with one another.

Selective coordination, while always desirable, is not required by the NEC except in certain situations:

- In health-care facilities, per NEC 517.17(C): “Ground-fault protection for operation of the service and feeder disconnecting means shall be fully selective such that the feeder device, but not the service device, shall open on ground faults on the load side of the feeder device.”
- In elevator circuits when more than one elevator motor is fed by a single feeder. See NEC 620.62.
- In emergency and legally-required standby power systems (including those in hospitals and other health-care facilities where so required), per NEC 700.27 and NEC 701.18.

The requirements for selective coordination in emergency and legally-required standby systems, call for each overcurrent device to be “selectively coordinated with all supply side overcurrent protective devices.” This requirement can be problematic for system designers because it recognizes only device coordination and not system coordination. Special consideration of selective coordination (beyond the traditional coordination study) must be given when the system is initially designed, since for both fusible and circuit-breaker based systems, designs that are otherwise NEC compliant may not meet the selective coordination requirements of the NEC.

Compliance with NEC articles 517.17 (Health Care Facilities), 700.27 (Emergency Systems), and 701.18 (Legally Required Standby Systems) may require interpretation and approval by the local authority having jurisdiction.

3.2.8 Assumptions

The following assumptions were made:

1. The plant main distribution switchboard fuse data was assumed, as noted on the one-lines, since the site device data was not available due to lock out and restricted access.
2. Breakers for panelboards AEL-MPC-01 and AEL-MPC-02 do not match with the one line drawing 32E16.

3.3 Analysis of Results and Recommendations

The basic results of an overcurrent device coordination analysis are the time-current coordination graphs which are plotted to illustrate the degree of selective coordination achieved in the system. Fifteen graphs are included in this report. Settings for all devices which have adjustable characteristics are summarized in the appropriate overcurrent device setting tables. Smaller devices with fixed time-current characteristics are not shown on the graphs unless they directly affect the setting of an adjustable upstream device or are protective devices for transformers rated 15 kVA and larger.

For a digital relay, a setpoint file is provided in Appendix D. Before a setpoint file is downloaded to a relay, the setpoint file in the relay needs to be backed up even if the relay is new. The backed up setpoint file needs to be readily available until relay commissioning confirms proper operation.

To generate the time-current graphs, a computer program was used which allows the power system engineer to determine optimum coordination, after first insuring that loading and protection requirements are satisfied. The engineer's objective is to determine the best coordination for the entire system. This approach necessitates tradeoffs in selectivity for some parts of the system to achieve maximum coordination in more critical areas. Regions in which coordination has been sacrificed are as previously discussed involving transformer primary and secondary main devices, high current regions of molded case breakers, etc.

3.3.1 TCC Plot Remarks

The following comments refer to the graphs shown in the Time Current Coordination Graphs section of this report.

Time-current coordination graph 005 HELPD01.tcc shows device numbers 105-01 and 105-02 as well as other devices. As shown by the graph, these devices do not selectively coordinate well. If achieving selective coordination is absolutely required for this particular circuit, then we recommend upgrading device 105-01 to a solid-state type. These devices have been adjusted to obtain the highest level of selectivity possible for the protection level required.

Time-current coordination graph 006 HELLP01.tcc shows device numbers 106-01 and 106-02 as well as other devices. As shown by the graph, these devices do not selectively coordinate well. If achieving selective coordination is absolutely required for this particular circuit, then we recommend upgrading device 106-01 to a thermal magnetic breaker, LA 125ATrip. These devices have been adjusted to obtain the highest level of selectivity possible for the protection level required.

Time-current coordination graph 007 HELCPP01.tcc shows device numbers 105-03, 107-01 and 107-02. As shown by the graph, device numbers 105-03 and 107-01 does not selectively coordinate well with device number 107-02. However, these devices are sized at nearly the same trip level so this situation is unavoidable. These devices have been adjusted to obtain the highest level of selectivity possible for the protection level required.

Time-current coordination graph 008 AELPDP02.tcc shows device numbers 109-02, 110-01 and 110-02 as well as other devices. As shown by the graph, these devices do not selectively coordinate well. If achieving selective coordination is absolutely required for this particular circuit, then we recommend increasing the device 109-02 plug size from 100A to 200A, and use a

LTPU of 0.5. The devices 110-01 and 110-02 are sized at nearly the same trip level so this situation is unavoidable. These devices have been adjusted to obtain the highest level of selectivity possible for the protection level required.

Time-current coordination graph 010 AELPDP01.tcc shows device numbers 112-02, 113-01 and 113-02. As shown by the graph, device numbers 112-02 and 113-01 does not selectively coordinate well with device number 113-02. However, these devices are sized at nearly the same trip level so this situation is unavoidable. These devices have been adjusted to obtain the highest level of selectivity possible for the protection level required.

Time-current coordination graph 011 PELPDP01.tcc shows device numbers 112-03, 114-01 and 114-02. As shown by the graph, these devices do not selectively coordinate well. However, these devices are non adjustable, hence no settings are available to obtain the highest level of selectivity possible for the protection level required.

Time-current coordination graph 013 SELCPP11.tcc shows device numbers 115-03, 117-01 and 117-02. As shown by the graph, device numbers 115-03 and 117-01 does not selectively coordinate well with device number 117-02. However, these devices are sized at nearly the same trip level so this situation is unavoidable. These devices have been adjusted to obtain the highest level of selectivity possible for the protection level required.

3.4 Overcurrent Device Setting Table



by Schneider Electric
SQUARE D ENGINEERING SERVICES

DEVICE SETTING TABLE
LV CIRCUIT BREAKERS

SAWS LEON CREEK WRC
SAN ANTONIO, TX
D-ML-10-660-1,2

BUS NUMBER & NAME	DEVICE NUMBER & NAME DEVICE TYPE	MANUFACTURER DESCRIPTION	BUS VOLTS DEV. VOLTS	FRAME SENSOR PLUG	SETTINGS
005 AEL-PDP-11A	005-01 Thermal Magnetic	SQUARE D MG w/ ET1.0, 2-10x Inst. 300-800A	480.0V 600V	800.0A 600.0A	Thermal Curve INST 8 (4800A) INST OVERRIDE Fixed (12000A)
005 AEL-PDP-11A	005-05 Thermal Magnetic	SQUARE D LA (10/04) 125-400A, 2-3 poles	480.0V 600V	400.0A 400.0A	Thermal Curve INST (LO-HI) LO (2000A)
005 AEL-PDP-11A	005-06 Thermal Magnetic	SQUARE D LC 300-600A	480.0V 600V	600.0A 600.0A	Thermal Curve INST HI (4200A)
009 AEL-PDP-12	009-01 Thermal Magnetic	SQUARE D MG w/ ET1.0, 2-10x Inst. 300-800A	480.0V 600V	800.0A 400.0A	Thermal Curve INST 5 (2000A) INST OVERRIDE Fixed (12000A)
015 AEL-PDP-11B	015-01 Thermal Magnetic	SQUARE D MG w/ ET1.0, 2-10x Inst. 300-800A	480.0V 600V	800.0A 600.0A	Thermal Curve INST 8 (4800A) INST OVERRIDE Fixed (12000A)
015 AEL-PDP-11B	015-02 Thermal Magnetic	SQUARE D LC 300-600A	480.0V 600V	600.0A 600.0A	Thermal Curve INST HI (4200A)
015 AEL-PDP-11B	015-03 Thermal Magnetic	SQUARE D LA (10/04) 125-400A, 2-3 poles	480.0V 600V	400.0A 400.0A	Thermal Curve INST (LO-HI) LO (2000A)
105 HEL-PDP-01	105-01 Thermal Magnetic	SQUARE D LA (10/04) 125-400A, 2-3 poles	480.0V 600V	150.0A 150.0A	Thermal Curve INST (LO-HI) HI (1500A)
109 PMC-MCC-02	109-01 Static Trip	SQUARE D Powerpact P-Frame, 5.0 & 6.0 A/P/H LSI, 250-1200A	480.0V 600V	1200.0A 600.0A	Phase LTPU (A):LTD 1 (600A); 4 STPU 3 (1800A) STD 0.2 (I ² t Out) INST (PJ, PL 400-1200) 6 (3600A) Ground Ig H (540A) tg 0.4 (I ² t Out)
109 PMC-MCC-02	109-02 Static Trip	SQUARE D LX / LXI, Series 2B/3B LSI, 250/400AS	480.0V 600V	250.0A 250.0A 100.0A	LTPU 0.8 (80A) LTD 6 STPU 8 (800A) STD 0.2 (I ² t In) INST 8.0 (800A) INST OVERRIDE Fixed (7000A)



Schneider Electric
SQUARE D ENGINEERING SERVICES

DEVICE SETTING TABLE
LV CIRCUIT BREAKERS

SAWS LEON CREEK WRC
SAN ANTONIO, TX
D-ML-10-660-1,2

BUS NUMBER & NAME	DEVICE NUMBER & NAME DEVICE TYPE	MANUFACTURER DESCRIPTION	BUS VOLTS DEV. VOLTS	FRAME SENSOR PLUG	SETTINGS
115 SEL-PDP-11	115-01 Thermal Magnetic	SQUARE D LA (10/04) 125-400A, 2-3 poles	480.0V 600V	400.0A 400.0A	Thermal Curve INST (LO-HI) 2 (2564A)



by Schneider Electric
SQUARE D ENGINEERING SERVICES


DEVICE SETTING TABLE
RELAYS

SAWS LEON CREEK WRC
SAN ANTONIO, TX
D-ML-10-660-1,2

BUS NUMBER & NAME	DEVICE NUMBER & NAME DEVICE TYPE	MANUFACTURER DESCRIPTION	BUS VOLTS DEV. VOLTS	CT RATIO	SETTINGS
001 AMC-MCC-01A	001-02 R Static Relay	MULTILIN SR469 Motor Relay 5A CT Sec	4160.0V 230000V	250/5	O/L PU 1.15 (125.69A) O/L Curves 2
001 AMC-MCC-01A	001-02 RG Static Relay	MULTILIN SR469 Motor Relay 5A CT Sec	4160.0V 230000V	50/5	GFPU(5A CT Sec) 0.3 (15A) GF Delay 0.01
001 AMC-MCC-01A	001-03 R Static Relay	MULTILIN SR469 Motor Relay 5A CT Sec	4160.0V 230000V	250/5	O/L PU 1.15 (125.69A) O/L Curves 2
001 AMC-MCC-01A	001-03 RG Static Relay	MULTILIN SR469 Motor Relay 5A CT Sec	4160.0V 230000V	50/5	GFPU(5A CT Sec) 0.3 (15A) GF Delay 0.01
014 AMC-MCC-01B	014-03 R Static Relay	MULTILIN SR469 Motor Relay 5A CT Sec	4160.0V 230000V	250/5	O/L PU 1.15 (125.69A) O/L Curves 2
014 AMC-MCC-01B	014-03 RG Static Relay	MULTILIN SR469 Motor Relay 5A CT Sec	4160.0V 230000V	50/5	GFPU(5A CT Sec) 0.3 (15A) GF Delay 0.01
014 AMC-MCC-01B	014-04 R Static Relay	MULTILIN SR469 Motor Relay 5A CT Sec	4160.0V 230000V	250/5	O/L PU 1.15 (125.69A) O/L Curves 2
014 AMC-MCC-01B	014-04 RG Static Relay	MULTILIN SR469 Motor Relay 5A CT Sec	4160.0V 230000V	50/5	GFPU(5A CT Sec) 0.3 (15A) GF Delay 0.01


3.5 Time-Current Coordination Graphs - Recommended Settings

CURRENT IN AMPERES




Name: 001 AEL-LP11.tcc	Current Scale x 10	Reference Voltage: 480
January 24, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

CURRENT IN AMPERES




Name: 002 AEL-PDP-11A.tcc	Current Scale x 10	Reference Voltage: 4160
January 24, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

CURRENT IN AMPERES




Name: 003 LC-AASBC01.tcc Current Scale x 10 Reference Voltage: 4160
 June 17, 2011 ML10660 SAWS LEON CREEK SAN ANTONIO, TX Square D

CURRENT IN AMPERES




Name: 004 AEL-CPP11.tcc	Current Scale x 10	Reference Voltage: 480
January 24, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

CURRENT IN AMPERES



Name: 005 HELPDP01.tcc	Current Scale x 10	Reference Voltage: 480
January 24, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

CURRENT IN AMPERES



Name: 105-02
 Manufacturer: SQUARE D
 Type: FA
 Frame/Model: FA
 Trip: 60.0 A
 Voltage: 480.0 V
 Settings: Phase Fixed

Name: 106-01
 Manufacturer: SQUARE D
 Type: HD
 Frame/Model: HD
 Trip: 125.0 A
 Voltage: 208.0 V
 Settings: Phase Fixed


Name: 106-02
 Manufacturer: SQUARE D
 Type: QO, 1,2-Pole
 Frame/Model: QO, 1,2-POLE
 Trip: 60.0 A
 Voltage: 208.0 V
 Settings: Phase Fixed

Name: HEL-XFMR-LP1
 Nominal kVA: 30.0 kVA
 Pri Voltage: 480 V
 Sec Voltage: 208 V
 Z = 2.7200 %
 InrushFactor 11.5

TX INRUSH


Name: 006 HELLP01.tcc	Current Scale x 10	Reference Voltage: 480
January 24, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

CURRENT IN AMPERES




Name: 007 HELCPP01.tcc	Current Scale x 10	Reference Voltage: 208
January 24, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

CURRENT IN AMPERES




Name: 008 AELPDP02.tcc	Current Scale x 10	Reference Voltage: 480
January 24, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

CURRENT IN AMPERES



Name: 009 LCDDMP01.tcc	Current Scale x 10	Reference Voltage: 480
July 12, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

CURRENT IN AMPERES




Name: 112-02
 Manufacturer: SQUARE D
 Type: HJ
 Frame/Model: HJ
 Trip: 70.0 A
 Voltage: 480.0 V
 Settings: Phase Fixed

Name: 113-01
 Manufacturer: SQUARE D
 Type: FA
 Frame/Model: FA
 Trip: 70.0 A
 Voltage: 480.0 V
 Settings: Phase Fixed

Name: 113-02
 Manufacturer: SQUARE D
 Type: FA
 Frame/Model: FA
 Trip: 50.0 A
 Voltage: 480.0 V
 Settings: Phase Fixed

Name: 010 AELPDP01.tcc	Current Scale x 10	Reference Voltage: 480
January 24, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

CURRENT IN AMPERES



Name: 011 PELPDP01.tcc

Current Scale x 10


Reference Voltage: 480

January 24, 2011

ML10660 SAWS LEON CREEK SAN ANTONIO, TX


Square D

CURRENT IN AMPERES




Name: 012 SELLP12.tcc	Current Scale x 10	Reference Voltage: 480
January 24, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

CURRENT IN AMPERES




Name: 013 SELCPP11.tcc	Current Scale x 10	Reference Voltage: 208
January 24, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

CURRENT IN AMPERES



Name: 014G PMCMCC02 MAIN.tcc	Current Scale x 10	Reference Voltage: 480
July 12, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

CURRENT IN AMPERES



Name: 15 AIS-LCP-01.tcc	Current Scale x 10	Reference Voltage: 480
July 12, 2011	ML10660 SAWS LEON CREEK SAN ANTONIO, TX	Square D

APPENDIX A: ABBREVIATIONS AND TRADEMARKS

Organizations and Standards

ANSI	- American National Standards Institute
IEEE	- Institute of Electrical and Electronics Engineers
ICEA	- Insulated Cable Engineers Association
NEC	- National Electrical Code (NFPA No. 70)
NEMA	- National Electrical Manufacturers Association
UL	- Underwriters' Laboratories, Inc.

Other Abbreviations

A	- Amperes (RMS symmetrical)
AFIE	- Arc Flash Incident Energy (cal/cm ²)
AIC	- Amperes Interrupting Capacity (Three-Phase RMS sym.)
ASD	- Adjustable Speed ac Drive
ATPV	- Protective Clothing Arc Rating
ATS	- Automatic Transfer Switch
C/B	- Circuit Breaker
CHP	- Combined Horsepower
CFLA	- Combined Full Load Amperes
CT	- Current Transformer
FLA	- Full Load Amperes
FPB	- Flash Protection Boundary
HP	- Horsepower
I _L	- Max. Demand Load Current at PCC
I _{sc}	- Short-Circuit Current at PCC
kVA	- Kilovolt-Ampere
kVAm	- Kilovolt-Amperes of Motor Short Circuit contribution
kW	- Kilowatt
L-L	- Line-To-Line
LRA	- Locked-Rotor Amperes
L.V.	- Low Voltage
LSIG.	- L = Long Time, S = Short time, I = Instantaneous, G = Ground fault protection
MCC	- Motor Control Center
MCS	- Molded Case Switch
Mohms	- Milliohms
M.V.	- Medium Voltage
OCPD	- Overcurrent Protective Device
O.L.	- Overload
PCC	- Point of Common Coupling
PF	- Power Factor
PPE	- Personal Protective Equipment
PWM	- Pulse Width Modulated
R	- Resistance
RMS	- Root-Mean-Square
SCA	- Short-Circuit Amperes
SCAm	- Short-Circuit Amperes of Motor Contribution
SCCR	- Short-Circuit Current Rating
S.F.	- Service Factor
sym.	- Symmetrical
TCC.	- Time Current Coordination graph
TCR	- Trip Current Rating
TDD	- Total Demand Distortion
THD	- Total Harmonic Distortion
V	- Line-To-Line Volts (RMS sym.)
WCR	- Withstand Current Rating
X	- Reactance
Z	- Impedance
%Z	- Percent Impedance

Trademarks

BOLT-LOC, ECONOPAK, EZ METER-PAK, GROUND SENSOR, I-LIMITER, I-LINE, ISO-FLEX, MAG-GARD, MICROLOGIC, MINI POWER-ZONE, OMEGAPAK, POWER-CAST, POWER STYLE, POWER ZONE, QF, QO, QWIK-GARD, SORGEL, SPEED-D, SQUARE D, VACARC and WATCHDOG are registered trademarks of Square D Company. I-75,000, METER-PAK, and PZ-8 are trademarks of Square D Company.

Company Abbreviations

Allen-Bradley	A-B
Allis-Chalmers	A-C
ASEA Brown Boveri	ABB
Automatic Switch Co	ASCO
Basler	BAS
Bussmann	BUSS
Challenger	CHA
Cooper	COOP
Cutler – Hammer	C-H
Economy Fuse	ECON
Federal Pacific Electric	FPE
G & W Electric	G&W
General Electric	GE
Gould Shawmut	GS
I-T-E Imperial	ITE
Kearney	KEA
Klockner	KLO
Littlefuse	LIT
McGraw Edison	ME
Merlin Gerin	MG
Powell	POW
Reliance	REL
RTE Corp.	RTE
Russelectric	RUSS
S & C Electric	S&C
Schweitzer Engr. Labs	SEL
Siemens	SIE
Square D	SQD
Thomas Betts	T-B
Toshiba	TOS
Westinghouse	WEST
Zenith	Z

APPENDIX B: SHORT CIRCUIT INPUT TABULATIONS

ML10660
SAWS LEON CREEK WRC
SAN ANTONIO, TX
EXISTING UTILITY

Jul 12, 2011 14:51:27

Page 1

ALL PU VALUES ARE EXPRESSED ON A 100 MVA BASE.

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
AASBC01-P	001 AMC-MCC-01A	002 LC-AASBC01	1	4160	65.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.0193 + J 0.0178	PU		
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.0308 + J 0.0453	PU		
AASBC02-P	001 AMC-MCC-01A	003 LC-AASBC02	1	4160	65.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.0193 + J 0.0178	PU		
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.0308 + J 0.0453	PU		
AASBC03-P	014 AMC-MCC-01B	018 LC-AASBC03	1	4160	65.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.0193 + J 0.0178	PU		
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.0308 + J 0.0453	PU		
AASBC04-P	014 AMC-MCC-01B	019 LC-AASBC04	1	4160	65.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.0193 + J 0.0178	PU		
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.0308 + J 0.0453	PU		
AEL-CPP11-P	009 AEL-PDP-12	BUS-0066	1	480	35.0 FEET	8	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.6404 + J 0.0475	Ohms/1000 ft		9.73 + J 0.7216	PU		
	Z0 Impedance: 2.02 + J 0.1170	Ohms/1000 ft		30.66 + J 1.78	PU		
AEL-H1-P	005 AEL-PDP-11A	BUS-0059	1	480	30.0 FEET	10	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 1.02 + J 0.0463	Ohms/1000 ft		13.26 + J 0.6029	PU		
	Z0 Impedance: 3.21 + J 0.1140	Ohms/1000 ft		41.77 + J 1.48	PU		
AEL-H2-P	015 AEL-PDP-11B	BUS-0077	1	480	30.0 FEET	10	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 1.02 + J 0.0463	Ohms/1000 ft		13.26 + J 0.6029	PU		
	Z0 Impedance: 3.21 + J 0.1140	Ohms/1000 ft		41.77 + J 1.48	PU		
AEL-LP11-P	009 AEL-PDP-12	BUS-0063	1	480	30.0 FEET	4	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.2590 + J 0.0441	Ohms/1000 ft		3.37 + J 0.5742	PU		
	Z0 Impedance: 0.8163 + J 0.1086	Ohms/1000 ft		10.63 + J 1.41	PU		
AEL-MPC1-P	009 AEL-PDP-12	BUS-0069	1	480	360.0 FEET	2	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1640 + J 0.0420	Ohms/1000 ft		25.63 + J 6.56	PU		
	Z0 Impedance: 0.5168 + J 0.1034	Ohms/1000 ft		80.76 + J 16.16	PU		

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
AEL-MPC2-P	009 AEL-PDP-12	BUS-0071	1	480	690.0 FEET	2	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1640 + J 0.0420	Ohms/1000 ft		49.11 + J 12.58	PU		
	Z0 Impedance: 0.5168 + J 0.1034	Ohms/1000 ft		154.79 + J 30.98	PU		
AEL-PDP1-F	112 PMC-MCC-01	113 AEL-PDP-01	1	480	410.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft		23.01 + J 6.09	PU		
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft		36.58 + J 15.48	PU		
AEL-PDP11-T	005 AEL-PDP-11A	015 AEL-PDP-11B	2	480	0.100 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0220 + J 0.0303	Ohms/1000 ft		0.00048 + J 0.00066	PU		
	Z0 Impedance: 0.0350 + J 0.0771	Ohms/1000 ft		0.00076 + J 0.0017	PU		
AEL-PDP11A-F	BUS-0089	005 AEL-PDP-11A	2	480	60.0 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0220 + J 0.0303	Ohms/1000 ft		0.2865 + J 0.3945	PU		
	Z0 Impedance: 0.0350 + J 0.0771	Ohms/1000 ft		0.4555 + J 1.00	PU		
AEL-PDP12-F	008L AEL-ATS-01	009 AEL-PDP-12	2	480	65.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0511 + J 0.0314	Ohms/1000 ft		0.7208 + J 0.4429	PU		
	Z0 Impedance: 0.0812 + J 0.0799	Ohms/1000 ft		1.15 + J 1.13	PU		
AEL-PDP2-F	109 PMC-MCC-02	110 AEL-PDP-02	1	480	250.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft		14.03 + J 3.71	PU		
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft		22.31 + J 9.44	PU		
AEL-TSE-F	015 AEL-PDP-11B	BUS-0061	2	480	30.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0511 + J 0.0314	Ohms/1000 ft		0.3327 + J 0.2044	PU		
	Z0 Impedance: 0.0812 + J 0.0799	Ohms/1000 ft		0.5286 + J 0.5202	PU		
AEL-TSN-F	005 AEL-PDP-11A	BUS-0062	2	480	60.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0511 + J 0.0314	Ohms/1000 ft		0.6654 + J 0.4089	PU		
	Z0 Impedance: 0.0812 + J 0.0799	Ohms/1000 ft		1.06 + J 1.04	PU		
AEL-XFMR-01A-F	001 AMC-MCC-01A	BUS-0007	1	4160	45.0 FEET	6	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.4154 + J 0.0674	Ohms/1000 ft		0.1080 + J 0.0175	PU		
	Z0 Impedance: 0.6604 + J 0.1715	Ohms/1000 ft		0.1717 + J 0.0446	PU		

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
AEL-XFMR-01B-F	014 AMC-MCC-01B	BUS-0015	1	4160	60.0 FEET	6	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.4154 + J 0.0674	Ohms/1000 ft		0.1440 + J 0.0234			PU
	Z0 Impedance: 0.6604 + J 0.1715	Ohms/1000 ft		0.2290 + J 0.0594			PU
AIS-LCP1-P	005 AEL-PDP-11A	006 AIS-LCP-01	1	480	60.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft		3.37 + J 0.8906			PU
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft		5.35 + J 2.27			PU
AIS-LCP2-P	005 AEL-PDP-11A	007 AIS-LCP-02	1	480	60.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft		3.37 + J 0.8906			PU
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft		5.35 + J 2.27			PU
AIS-LCP3-P	015 AEL-PDP-11B	016 AIS-LCP-03	1	480	60.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft		3.37 + J 0.8906			PU
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft		5.35 + J 2.27			PU
AIS-LCP4-P	015 AEL-PDP-11B	017 AIS-LCP-04	1	480	60.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft		3.37 + J 0.8906			PU
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft		5.35 + J 2.27			PU
AMC-MCC01-TF	001 AMC-MCC-01A	014 AMC-MCC-01B	4	4160	65.0 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0234 + J 0.0414	Ohms/1000 ft		0.0022 + J 0.0039			PU
	Z0 Impedance: 0.0372 + J 0.1053	Ohms/1000 ft		0.0035 + J 0.0099			PU
AMC-MCC01A-F	BUS-0003	001 AMC-MCC-01A	4	4160	0.100 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0234 + J 0.0414	Ohms/1000 ft		0.00001 + J 0.00001			PU
	Z0 Impedance: 0.0372 + J 0.1053	Ohms/1000 ft		0.00001 + J 0.00002			PU
CBL-0061	BUS-0082	100 PLANT MAIN SWBD SWB-1	4	4160	1.000 FEET	500	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0244 + J 0.0379	Ohms/1000 ft		0.00004 + J 0.00005			PU
	Z0 Impedance: 0.0769 + J 0.0933	Ohms/1000 ft		0.00011 + J 0.00013			PU
CPS-XFMR01A-F	BUS-0002	BUS-0003	4	4160	140.0 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0234 + J 0.0414	Ohms/1000 ft		0.0047 + J 0.0084			PU
	Z0 Impedance: 0.0372 + J 0.1053	Ohms/1000 ft		0.0075 + J 0.0213			PU

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CPS-XFMR02A-F	BUS-0001	BUS-0003	4	4160	140.0 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0234 + J 0.0414 Ohms/1000 ft	0.0047 + J 0.0084 PU					
	Z0 Impedance: 0.0372 + J 0.1053 Ohms/1000 ft	0.0075 + J 0.0213 PU					
HEL-ATSNF	BUS-0081	BUS-0033	2	480	75.0 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0220 + J 0.0303 Ohms/1000 ft	0.3581 + J 0.4932 PU					
	Z0 Impedance: 0.0350 + J 0.0771 Ohms/1000 ft	0.5697 + J 1.25 PU					
HEL-CPP1-F	BUS-0048	107 HEL-CPP-01	1	208	20.0 FEET	6	Copper
	Duct Material: Non-Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.4100 + J 0.0349 Ohms/1000 ft	18.95 + J 1.61 PU					
	Z0 Impedance: 0.6518 + J 0.0888 Ohms/1000 ft	30.13 + J 4.10 PU					
HEL-LP1-F	BUS-0045	106 HEL-LP-01	1	208	15.0 FEET	1	Copper
	Duct Material: Non-Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1303 + J 0.0342 Ohms/1000 ft	4.52 + J 1.19 PU					
	Z0 Impedance: 0.2071 + J 0.0870 Ohms/1000 ft	7.18 + J 3.02 PU					
HEL-PDP01-F	104 MCC-1	105 HEL-PDP-01	1	480	110.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1293 + J 0.0342 Ohms/1000 ft	6.17 + J 1.63 PU					
	Z0 Impedance: 0.2056 + J 0.0870 Ohms/1000 ft	9.81 + J 4.15 PU					
HEL-XFMR-CPP-1	105 HEL-PDP-01	BUS-0047	1	480	30.0 FEET	8	Copper
	Duct Material: Non-Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.6404 + J 0.0380 Ohms/1000 ft	8.34 + J 0.4948 PU					
	Z0 Impedance: 1.02 + J 0.0967 Ohms/1000 ft	13.26 + J 1.26 PU					
HEL-XFMR-LP-1	105 HEL-PDP-01	BUS-0044	1	480	40.0 FEET	8	Copper
	Duct Material: Non-Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.6404 + J 0.0380 Ohms/1000 ft	11.12 + J 0.6597 PU					
	Z0 Impedance: 1.02 + J 0.0967 Ohms/1000 ft	17.68 + J 1.68 PU					
HEL-XFMR01-F	102 HV44	BUS-0032	1	4160	360.0 FEET	1/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.1032 + J 0.0529 Ohms/1000 ft	0.2147 + J 0.1100 PU					
	Z0 Impedance: 0.1641 + J 0.1345 Ohms/1000 ft	0.3414 + J 0.2799 PU					
HV44	101 FUSE CUT-OUTS	102 HV44	1	4160	350.0 FEET	1/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.1032 + J 0.0529 Ohms/1000 ft	0.2087 + J 0.1070 PU					
	Z0 Impedance: 0.1641 + J 0.1345 Ohms/1000 ft	0.3319 + J 0.2720 PU					

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
MCC1-F	103L HEL-ATS-01	104 MCC-1	2	480	110.0 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0220 + J 0.0303	Ohms/1000 ft		0.5252 + J 0.7233	PU		
	Z0 Impedance: 0.0350 + J 0.0771	Ohms/1000 ft		0.8350 + J 1.84	PU		
OE-WH	100 PLANT MAIN SWBD SWB-1	111 FUSE CUT-OUTS	1	4160	125.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.0372 + J 0.0342	PU		
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.0592 + J 0.0870	PU		
OE-WL	100 PLANT MAIN SWBD SWB-1	101 FUSE CUT-OUTS	1	4160	0.100 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.00003 + J 0.00003	PU		
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.00005 + J 0.00007	PU		
PEL-PDP-F	112 PMC-MCC-01	114 PEL-PDP-01	1	480	140.0 FEET	2	Copper
	Duct Material: Non-Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1640 + J 0.0336	Ohms/1000 ft		9.97 + J 2.04	PU		
	Z0 Impedance: 0.2607 + J 0.0855	Ohms/1000 ft		15.84 + J 5.19	PU		
PEL-XFMR02-F	101 FUSE CUT-OUTS	108 PELXFM PRI	1	4160	210.0 FEET	2/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0819 + J 0.0509	Ohms/1000 ft		0.0994 + J 0.0618	PU		
	Z0 Impedance: 0.1302 + J 0.1296	Ohms/1000 ft		0.1580 + J 0.1573	PU		
PMC-MCC-02	BUS-0088	109 PMC-MCC-02	2	480	150.0 FEET	350	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0333 + J 0.0388	Ohms/1000 ft		1.08 + J 1.26	PU		
	Z0 Impedance: 0.1050 + J 0.0956	Ohms/1000 ft		3.42 + J 3.11	PU		
SEL-CPP11-F	BUS-0055	117 SEL-CPP-11	1	208	20.0 FEET	6	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.4100 + J 0.0349	Ohms/1000 ft		18.95 + J 1.61	PU		
	Z0 Impedance: 0.6518 + J 0.0888	Ohms/1000 ft		30.13 + J 4.11	PU		
SEL-LP12-F	BUS-0052	116 SEL-LP-12	1	240	12.0 FEET	3/0	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0643 + J 0.0320	Ohms/1000 ft		1.34 + J 0.6667	PU		
	Z0 Impedance: 0.1022 + J 0.0814	Ohms/1000 ft		2.13 + J 1.70	PU		
SEL-PDP-F	BUS-0079	115 SEL-PDP-11	2	480	75.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0511 + J 0.0314	Ohms/1000 ft		0.8317 + J 0.5111	PU		
	Z0 Impedance: 0.0812 + J 0.0799	Ohms/1000 ft		1.32 + J 1.30	PU		

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
SEL-XFMR01-F	BUS-0082	BUS-0078	2	4160	125.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474 Ohms/1000 ft	0.0186 + J 0.0171 PU					
	Z0 Impedance: 0.0819 + J 0.1205 Ohms/1000 ft	0.0296 + J 0.0435 PU					
SEL-XFMRCPP11-F	115 SEL-PDP-11	BUS-0054	1	480	20.0 FEET	10	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 1.02 + J 0.0371 Ohms/1000 ft	8.84 + J 0.3220 PU					
	Z0 Impedance: 1.62 + J 0.0944 Ohms/1000 ft	14.05 + J 0.8194 PU					
SEL-XFMRLP12-F	115 SEL-PDP-11	BUS-0051	1	480	12.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1293 + J 0.0342 Ohms/1000 ft	0.6734 + J 0.1781 PU					
	Z0 Impedance: 0.2056 + J 0.0870 Ohms/1000 ft	1.07 + J 0.4531 PU					
T-PS1-F	111 FUSE CUT-OUTS	BUS-0080	1	4160	0.100 FEET	2/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0819 + J 0.0509 Ohms/1000 ft	0.00005 + J 0.00003 PU					
	Z0 Impedance: 0.1302 + J 0.1296 Ohms/1000 ft	0.00008 + J 0.00007 PU					

TRANSFORMER INPUT DATA

TRANSFORMER NOMINAL NAME	PRIMARY RECORD NO NAME	VOLTS L-L	* SECONDARY RECORD NO NAME	VOLTS L-L	FULL-LOAD KVA	KVA
AEL-XFMR-01A	BUS-0007	D 4160.00	BUS-0089	YG 480.00	500.00	500.00
	Pos. Seq. Z%: 1.13 + J 5.64	(Zpu 2.26 + j 11.28)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
AEL-XFMR-CPP11	BUS-0066	D 480.00	011 AEL-CPP-11	YG 208.00	30.00	30.00
	Pos. Seq. Z%: 1.72 + J 4.69	(Zpu 57.42 + j 156.4)	Shell Type			
	Zero Seq. Z%: 1.72 + J 4.69	(Sec 57.42 + j 156.4 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
AEL-XFMR-LP11	BUS-0063	D 480.00	010 AEL-LP-11	YG 208.00	45.00	45.00
	Pos. Seq. Z%: 1.62 + J 0.778	(Zpu 36.06 + j 17.31)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
CPS-XFMR-01	CPS ENERGY	D 13800.0	100 PLANT MAIN SWBD SWB-1	YG 4160.00	2500.00	2500.00
	Pos. Seq. Z%: 0.526 + J 5.29	(Zpu 0.210 + j 2.12)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
CPS-XFMR-01A	BUS-0085	D 13800.0	BUS-0002	YG 4160.00	2500.00	2500.00
	Pos. Seq. Z%: 0.529 + J 5.29	(Zpu 0.211 + j 2.12)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
CPS-XFMR-02A	BUS-0084	D 13800.0	BUS-0001	YG 4160.00	2500.00	2500.00
	Pos. Seq. Z%: 0.529 + J 5.29	(Zpu 0.211 + j 2.12)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					

TRANSFORMER INPUT DATA

TRANSFORMER NOMINAL NAME	PRIMARY RECORD NO NAME	VOLTS L-L	* SECONDARY RECORD NO NAME	VOLTS L-L	FULL-LOAD KVA	KVA
HEL-XFMR-01	BUS-0032	D 4160.00	BUS-0081	YG 480.00	500.00	500.00
	Pos. Seq. Z%: 1.13 + J 5.64	(Zpu 2.26 + j 11.28)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
HEL-XFMR-CPP1	BUS-0047	D 480.00	BUS-0048	YG 208.00	15.00	15.00
	Pos. Seq. Z%: 1.88 + J 4.63	(Zpu 125.1 + j 308.9)	Shell Type			
	Zero Seq. Z%: 1.88 + J 4.63	(Sec 125.1 + j 308.9 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
HEL-XFMR-LP1	BUS-0044	D 480.00	BUS-0045	YG 208.00	30.00	30.00
	Pos. Seq. Z%: 1.68 + J 2.14	(Zpu 56.09 + j 71.23)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
MPZ XFM-01	BUS-0069	D 480.00	012 AEL-MPC-01	YG 208.00	30.00	30.00
	Pos. Seq. Z%: 1.72 + J 4.69	(Zpu 57.42 + j 156.4)	Shell Type			
	Zero Seq. Z%: 1.72 + J 4.69	(Sec 57.42 + j 156.4 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
MPZ XFM-02	BUS-0071	D 480.00	013 AEL-MPC-02	YG 208.00	30.00	30.00
	Pos. Seq. Z%: 1.72 + J 4.69	(Zpu 57.42 + j 156.4)	Shell Type			
	Zero Seq. Z%: 1.72 + J 4.69	(Sec 57.42 + j 156.4 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
PEL-XFMR-02	108 PELXFM PRI	D 4160.00	BUS-0088	YG 480.00	500.00	500.00
	Pos. Seq. Z%: 1.13 + J 5.64	(Zpu 2.26 + j 11.28)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					

TRANSFORMER INPUT DATA

TRANSFORMER NOMINAL NAME	PRIMARY RECORD NO NAME	VOLTS L-L	* SECONDARY RECORD NO NAME	VOLTS L-L	FULL-LOAD KVA	KVA
SEL-XFMR-01	BUS-0078	D 4160.00	BUS-0079	YG 480.00	300.00	300.00
	Pos. Seq. Z%: 1.19 + J 5.37	(Zpu 3.98 + j 17.90)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
SEL-XFMR-CPP11	BUS-0054	D 480.00	BUS-0055	YG 208.00	15.00	15.00
	Pos. Seq. Z%: 1.88 + J 4.63	(Zpu 125.1 + j 308.9)	Shell Type			
	Zero Seq. Z%: 1.88 + J 4.63	(Sec 125.1 + j 308.9 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
SEL-XFMR-LP12	BUS-0051	D 480.00	BUS-0052	YG 240.00	50.00	50.00
	Pos. Seq. Z%: 1.61 + J 4.74	(Zpu 32.11 + j 94.71)	Shell Type			
	Zero Seq. Z%: 1.61 + J 4.74	(Sec 32.11 + j 94.71 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
T-PS1	BUS-0080	D 4160.00	112 PMC-MCC-01	YG 480.00	300.00	300.00
	Pos. Seq. Z%: 1.19 + J 5.37	(Zpu 3.98 + j 17.90)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					

GENERATION CONTRIBUTION DATA

BUS NAME	CONTRIBUTION NAME	VOLTAGE		MVA	X*d	X/R
		L-L				
BUS-0084	UTILITY 2	13800.0		29.47		
	Three Phase Contribution:	1233.00	AMPS	2.42		
	Pos Sequence Impedance (100 MVA Base)	1.30 + J		3.14	PU	
	Zero Sequence Impedance (100 MVA Base)	10000000 + J		10000000	PU	
BUS-0085	UTILITY 1	13800.0		29.47		
	Three Phase Contribution:	1233.00	AMPS	2.42		
	Pos Sequence Impedance (100 MVA Base)	1.30 + J		3.14	PU	
	Zero Sequence Impedance (100 MVA Base)	10000000 + J		10000000	PU	
CPS ENERGY	CPS UTI1	13800.0		29.47		
	Three Phase Contribution:	1233.00	AMPS	2.42		
	Pos Sequence Impedance (100 MVA Base)	1.30 + J		3.14	PU	
	Zero Sequence Impedance (100 MVA Base)	10000000 + J		10000000	PU	

MOTOR CONTRIBUTION DATA

BUS NAME	CONTRIBUTION NAME	VOLTAGE L-L	BASE kVA	X"d	X/R	Motor Number
002 LC-AASBC01	AIR BLOWER-01	4160	787.37	0.2	24.2	1.00
	Pos Sequence Impedance (100 MVA Base)	1.05 + j	25.40 PU			
003 LC-AASBC02	AIR BLOWER-02	4160	787.37	0.2	24.2	1.00
	Pos Sequence Impedance (100 MVA Base)	1.05 + j	25.40 PU			
006 AIS-LCP-01	AIS-LCP-01	480	33.30	0.25	6.00	1.00
	Pos Sequence Impedance (100 MVA Base)	125.13 + j	750.75 PU			
007 AIS-LCP-02	AIS-LCP-02	480	33.30	0.25	6.00	1.00
	Pos Sequence Impedance (100 MVA Base)	125.13 + j	750.75 PU			
016 AIS-LCP-03	AIS-LCP-03	480	33.30	0.25	6.00	1.00
	Pos Sequence Impedance (100 MVA Base)	125.13 + j	750.75 PU			
017 AIS-LCP-04	AIS-LCP-04	480	33.30	0.25	6.00	1.00
	Pos Sequence Impedance (100 MVA Base)	125.13 + j	750.75 PU			
018 LC-AASBC03	AIR BLOWER-03	4160	787.37	0.2	24.2	1.00
	Pos Sequence Impedance (100 MVA Base)	1.05 + j	25.40 PU			
019 LC-AASBC04	AIR BLOWER-04	4160	787.37	0.2	24.2	1.00
	Pos Sequence Impedance (100 MVA Base)	1.05 + j	25.40 PU			
105 HEL-PDP-01	T. LOAD HEL-PDP01	480	7.00	0.25	6.00	1.00
	Pos Sequence Impedance (100 MVA Base)	595.24 + j	3571.43 PU			
109 PMC-MCC-02	LC-DDMP02	480	50.00	0.2	5.30	1.00
	Pos Sequence Impedance (100 MVA Base)	75.47 + j	400.00 PU			

MOTOR CONTRIBUTION DATA

BUS NAME	CONTRIBUTION NAME	VOLTAGE L-L	BASE kVA	X"d	X/R	Motor Number
109 PMC-MCC-02	T. LOAD PMC-MCC-02 Pos Sequence Impedance (100 MVA Base)	480 260.42 + j 1562.50 PU	16.00	0.25	6.00	1.00
109 PMC-MCC-02	LC-DDMP01 Pos Sequence Impedance (100 MVA Base)	480 75.47 + j 400.00 PU	50.00	0.2	5.30	1.00
110 AEL-PDP-02	T. LOAD AEL-PDP02 Pos Sequence Impedance (100 MVA Base)	480 462.96 + j 2777.78 PU	9.00	0.25	6.00	1.00
112 PMC-MCC-01	T. LOAD PMC-MCC-01 Pos Sequence Impedance (100 MVA Base)	480 252.53 + j 1515.15 PU	16.50	0.25	6.00	1.00
113 AEL-PDP-01	T. LOAD AEL-PDP01 Pos Sequence Impedance (100 MVA Base)	480 694.44 + j 4166.67 PU	6.00	0.25	6.00	1.00
114 PEL-PDP-01	T. LOAD PEL-PDP01 Pos Sequence Impedance (100 MVA Base)	480 694.44 + j 4166.67 PU	6.00	0.25	6.00	1.00
115 SEL-PDP-11	T. LOAD SEL-PDP-11 Pos Sequence Impedance (100 MVA Base)	480 53.57 + j 535.70 PU	31.58	0.1692	10.0	1.00
BUS-0059	AEL-H-01 Pos Sequence Impedance (100 MVA Base)	480 313.28 + j 1879.70 PU	13.30	0.25	6.00	1.00
BUS-0077	AEL-H-02 Pos Sequence Impedance (100 MVA Base)	480 313.28 + j 1879.70 PU	13.30	0.25	6.00	1.00

ML10660
SAWS LEON CREEK WRC
SAN ANTONIO, TX
FUTURE UTILITY
Jul 12, 2011 14:47:35

Page 1

ALL PU VALUES ARE EXPRESSED ON A 100 MVA BASE.

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
AASBC01-P	001 AMC-MCC-01A	002 LC-AASBC01	1	4160	65.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.0193 + J 0.0178	PU		
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.0308 + J 0.0453	PU		
AASBC02-P	001 AMC-MCC-01A	003 LC-AASBC02	1	4160	65.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.0193 + J 0.0178	PU		
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.0308 + J 0.0453	PU		
AASBC03-P	014 AMC-MCC-01B	018 LC-AASBC03	1	4160	65.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.0193 + J 0.0178	PU		
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.0308 + J 0.0453	PU		
AASBC04-P	014 AMC-MCC-01B	019 LC-AASBC04	1	4160	65.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.0193 + J 0.0178	PU		
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.0308 + J 0.0453	PU		
AEL-CPP11-P	009 AEL-PDP-12	BUS-0066	1	480	35.0 FEET	8	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.6404 + J 0.0475	Ohms/1000 ft		9.73 + J 0.7216	PU		
	Z0 Impedance: 2.02 + J 0.1170	Ohms/1000 ft		30.66 + J 1.78	PU		
AEL-H1-P	005 AEL-PDP-11A	BUS-0059	1	480	30.0 FEET	10	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 1.02 + J 0.0463	Ohms/1000 ft		13.26 + J 0.6029	PU		
	Z0 Impedance: 3.21 + J 0.1140	Ohms/1000 ft		41.77 + J 1.48	PU		
AEL-H2-P	015 AEL-PDP-11B	BUS-0077	1	480	30.0 FEET	10	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 1.02 + J 0.0463	Ohms/1000 ft		13.26 + J 0.6029	PU		
	Z0 Impedance: 3.21 + J 0.1140	Ohms/1000 ft		41.77 + J 1.48	PU		
AEL-LP11-P	009 AEL-PDP-12	BUS-0063	1	480	30.0 FEET	4	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.2590 + J 0.0441	Ohms/1000 ft		3.37 + J 0.5742	PU		
	Z0 Impedance: 0.8163 + J 0.1086	Ohms/1000 ft		10.63 + J 1.41	PU		
AEL-MPC1-P	009 AEL-PDP-12	BUS-0069	1	480	360.0 FEET	2	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1640 + J 0.0420	Ohms/1000 ft		25.63 + J 6.56	PU		
	Z0 Impedance: 0.5168 + J 0.1034	Ohms/1000 ft		80.76 + J 16.16	PU		

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
AEL-MPC2-P	009 AEL-PDP-12	BUS-0071	1	480	690.0 FEET	2	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1640 + J 0.0420	Ohms/1000 ft		49.11 + J 12.58	PU		
	Z0 Impedance: 0.5168 + J 0.1034	Ohms/1000 ft		154.79 + J 30.98	PU		
AEL-PDP1-F	112 PMC-MCC-01	113 AEL-PDP-01	1	480	410.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft		23.01 + J 6.09	PU		
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft		36.58 + J 15.48	PU		
AEL-PDP11-T	005 AEL-PDP-11A	015 AEL-PDP-11B	2	480	0.100 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0220 + J 0.0303	Ohms/1000 ft		0.00048 + J 0.00066	PU		
	Z0 Impedance: 0.0350 + J 0.0771	Ohms/1000 ft		0.00076 + J 0.0017	PU		
AEL-PDP11A-F	BUS-0089	005 AEL-PDP-11A	2	480	60.0 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0220 + J 0.0303	Ohms/1000 ft		0.2865 + J 0.3945	PU		
	Z0 Impedance: 0.0350 + J 0.0771	Ohms/1000 ft		0.4555 + J 1.00	PU		
AEL-PDP12-F	008L AEL-ATS-01	009 AEL-PDP-12	2	480	65.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0511 + J 0.0314	Ohms/1000 ft		0.7208 + J 0.4429	PU		
	Z0 Impedance: 0.0812 + J 0.0799	Ohms/1000 ft		1.15 + J 1.13	PU		
AEL-PDP2-F	109 PMC-MCC-02	110 AEL-PDP-02	1	480	250.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft		14.03 + J 3.71	PU		
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft		22.31 + J 9.44	PU		
AEL-TSE-F	015 AEL-PDP-11B	BUS-0061	2	480	30.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0511 + J 0.0314	Ohms/1000 ft		0.3327 + J 0.2044	PU		
	Z0 Impedance: 0.0812 + J 0.0799	Ohms/1000 ft		0.5286 + J 0.5202	PU		
AEL-TSN-F	005 AEL-PDP-11A	BUS-0062	2	480	60.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0511 + J 0.0314	Ohms/1000 ft		0.6654 + J 0.4089	PU		
	Z0 Impedance: 0.0812 + J 0.0799	Ohms/1000 ft		1.06 + J 1.04	PU		
AEL-XFMR-01A-F	001 AMC-MCC-01A	BUS-0007	1	4160	45.0 FEET	6	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.4154 + J 0.0674	Ohms/1000 ft		0.1080 + J 0.0175	PU		
	Z0 Impedance: 0.6604 + J 0.1715	Ohms/1000 ft		0.1717 + J 0.0446	PU		

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
AEL-XFMR-01B-F	014 AMC-MCC-01B	BUS-0015	1	4160	60.0 FEET	6	Copper
	Duct Material: Plastic	Insulation Type: EPR	Insulation Class:				
	+/- Impedance: 0.4154 + J 0.0674	Ohms/1000 ft	0.1440 + J 0.0234 PU				
	Z0 Impedance: 0.6604 + J 0.1715	Ohms/1000 ft	0.2290 + J 0.0594 PU				
AIS-LCP1-P	005 AEL-PDP-11A	006 AIS-LCP-01	1	480	60.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft	3.37 + J 0.8906 PU				
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft	5.35 + J 2.27 PU				
AIS-LCP2-P	005 AEL-PDP-11A	007 AIS-LCP-02	1	480	60.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft	3.37 + J 0.8906 PU				
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft	5.35 + J 2.27 PU				
AIS-LCP3-P	015 AEL-PDP-11B	016 AIS-LCP-03	1	480	60.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft	3.37 + J 0.8906 PU				
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft	5.35 + J 2.27 PU				
AIS-LCP4-P	015 AEL-PDP-11B	017 AIS-LCP-04	1	480	60.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft	3.37 + J 0.8906 PU				
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft	5.35 + J 2.27 PU				
AMC-MCC01-TF	001 AMC-MCC-01A	014 AMC-MCC-01B	4	4160	65.0 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: EPR	Insulation Class:				
	+/- Impedance: 0.0234 + J 0.0414	Ohms/1000 ft	0.0022 + J 0.0039 PU				
	Z0 Impedance: 0.0372 + J 0.1053	Ohms/1000 ft	0.0035 + J 0.0099 PU				
AMC-MCC01A-F	BUS-0003	001 AMC-MCC-01A	4	4160	0.100 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: EPR	Insulation Class:				
	+/- Impedance: 0.0234 + J 0.0414	Ohms/1000 ft	0.00001 + J 0.00001 PU				
	Z0 Impedance: 0.0372 + J 0.1053	Ohms/1000 ft	0.00001 + J 0.00002 PU				
CBL-0061	BUS-0082	100 PLANT MAIN SWBD SWB-1	4	4160	1.000 FEET	500	Copper
	Duct Material: Magnetic	Insulation Type: THHN	Insulation Class:				
	+/- Impedance: 0.0244 + J 0.0379	Ohms/1000 ft	0.00004 + J 0.00005 PU				
	Z0 Impedance: 0.0769 + J 0.0933	Ohms/1000 ft	0.00011 + J 0.00013 PU				
CPS-XFMR01A-F	BUS-0002	BUS-0003	4	4160	140.0 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: EPR	Insulation Class:				
	+/- Impedance: 0.0234 + J 0.0414	Ohms/1000 ft	0.0047 + J 0.0084 PU				
	Z0 Impedance: 0.0372 + J 0.1053	Ohms/1000 ft	0.0075 + J 0.0213 PU				

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
CPS-XFMR02A-F	BUS-0001	BUS-0003	4	4160	140.0 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0234 + J 0.0414 Ohms/1000 ft	0.0047 + J 0.0084 PU					
	Z0 Impedance: 0.0372 + J 0.1053 Ohms/1000 ft	0.0075 + J 0.0213 PU					
HEL-ATSNF	BUS-0081	BUS-0033	2	480	75.0 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0220 + J 0.0303 Ohms/1000 ft	0.3581 + J 0.4932 PU					
	Z0 Impedance: 0.0350 + J 0.0771 Ohms/1000 ft	0.5697 + J 1.25 PU					
HEL-CPP1-F	BUS-0048	107 HEL-CPP-01	1	208	20.0 FEET	6	Copper
	Duct Material: Non-Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.4100 + J 0.0349 Ohms/1000 ft	18.95 + J 1.61 PU					
	Z0 Impedance: 0.6518 + J 0.0888 Ohms/1000 ft	30.13 + J 4.10 PU					
HEL-LP1-F	BUS-0045	106 HEL-LP-01	1	208	15.0 FEET	1	Copper
	Duct Material: Non-Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1303 + J 0.0342 Ohms/1000 ft	4.52 + J 1.19 PU					
	Z0 Impedance: 0.2071 + J 0.0870 Ohms/1000 ft	7.18 + J 3.02 PU					
HEL-PDP01-F	104 MCC-1	105 HEL-PDP-01	1	480	110.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1293 + J 0.0342 Ohms/1000 ft	6.17 + J 1.63 PU					
	Z0 Impedance: 0.2056 + J 0.0870 Ohms/1000 ft	9.81 + J 4.15 PU					
HEL-XFMR-CPP-1	105 HEL-PDP-01	BUS-0047	1	480	30.0 FEET	8	Copper
	Duct Material: Non-Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.6404 + J 0.0380 Ohms/1000 ft	8.34 + J 0.4948 PU					
	Z0 Impedance: 1.02 + J 0.0967 Ohms/1000 ft	13.26 + J 1.26 PU					
HEL-XFMR-LP-1	105 HEL-PDP-01	BUS-0044	1	480	40.0 FEET	8	Copper
	Duct Material: Non-Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.6404 + J 0.0380 Ohms/1000 ft	11.12 + J 0.6597 PU					
	Z0 Impedance: 1.02 + J 0.0967 Ohms/1000 ft	17.68 + J 1.68 PU					
HEL-XFMR01-F	102 HV44	BUS-0032	1	4160	360.0 FEET	1/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.1032 + J 0.0529 Ohms/1000 ft	0.2147 + J 0.1100 PU					
	Z0 Impedance: 0.1641 + J 0.1345 Ohms/1000 ft	0.3414 + J 0.2799 PU					
HV44	101 FUSE CUT-OUTS	102 HV44	1	4160	350.0 FEET	1/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.1032 + J 0.0529 Ohms/1000 ft	0.2087 + J 0.1070 PU					
	Z0 Impedance: 0.1641 + J 0.1345 Ohms/1000 ft	0.3319 + J 0.2720 PU					

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
MCC1-F	103L HEL-ATS-01	104 MCC-1	2	480	110.0 FEET	500	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0220 + J 0.0303	Ohms/1000 ft		0.5252 + J 0.7233	PU		
	Z0 Impedance: 0.0350 + J 0.0771	Ohms/1000 ft		0.8350 + J 1.84	PU		
OE-WH	100 PLANT MAIN SWBD SWB-1	111 FUSE CUT-OUTS	1	4160	125.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.0372 + J 0.0342	PU		
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.0592 + J 0.0870	PU		
OE-WL	100 PLANT MAIN SWBD SWB-1	101 FUSE CUT-OUTS	1	4160	0.100 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.00003 + J 0.00003	PU		
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.00005 + J 0.00007	PU		
PEL-PDP-F	112 PMC-MCC-01	114 PEL-PDP-01	1	480	140.0 FEET	2	Copper
	Duct Material: Non-Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1640 + J 0.0336	Ohms/1000 ft		9.97 + J 2.04	PU		
	Z0 Impedance: 0.2607 + J 0.0855	Ohms/1000 ft		15.84 + J 5.19	PU		
PEL-XFMR02-F	101 FUSE CUT-OUTS	108 PELXFM PRI	1	4160	210.0 FEET	2/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0819 + J 0.0509	Ohms/1000 ft		0.0994 + J 0.0618	PU		
	Z0 Impedance: 0.1302 + J 0.1296	Ohms/1000 ft		0.1580 + J 0.1573	PU		
PMC-MCC-02	BUS-0088	109 PMC-MCC-02	2	480	150.0 FEET	350	Copper
	Duct Material: Magnetic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0333 + J 0.0388	Ohms/1000 ft		1.08 + J 1.26	PU		
	Z0 Impedance: 0.1050 + J 0.0956	Ohms/1000 ft		3.42 + J 3.11	PU		
SEL-CPP11-F	BUS-0055	117 SEL-CPP-11	1	208	20.0 FEET	6	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.4100 + J 0.0349	Ohms/1000 ft		18.95 + J 1.61	PU		
	Z0 Impedance: 0.6518 + J 0.0888	Ohms/1000 ft		30.13 + J 4.11	PU		
SEL-LP12-F	BUS-0052	116 SEL-LP-12	1	240	12.0 FEET	3/0	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0643 + J 0.0320	Ohms/1000 ft		1.34 + J 0.6667	PU		
	Z0 Impedance: 0.1022 + J 0.0814	Ohms/1000 ft		2.13 + J 1.70	PU		
SEL-PDP-F	BUS-0079	115 SEL-PDP-11	2	480	75.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.0511 + J 0.0314	Ohms/1000 ft		0.8317 + J 0.5111	PU		
	Z0 Impedance: 0.0812 + J 0.0799	Ohms/1000 ft		1.32 + J 1.30	PU		

FEEDER INPUT DATA

CABLE NAME	FEEDER FROM NAME	FEEDER TO NAME	QTY /PH	VOLTS L-L	LENGTH	FEEDER SIZE	FEEDER TYPE
SEL-XFMR01-F	BUS-0082	BUS-0078	2	4160	125.0 FEET	4/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0515 + J 0.0474	Ohms/1000 ft		0.0186 + J 0.0171		PU	
	Z0 Impedance: 0.0819 + J 0.1205	Ohms/1000 ft		0.0296 + J 0.0435		PU	
SEL-XFMRCPP11-F	115 SEL-PDP-11	BUS-0054	1	480	20.0 FEET	10	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 1.02 + J 0.0371	Ohms/1000 ft		8.84 + J 0.3220		PU	
	Z0 Impedance: 1.62 + J 0.0944	Ohms/1000 ft		14.05 + J 0.8194		PU	
SEL-XFMRLP12-F	115 SEL-PDP-11	BUS-0051	1	480	12.0 FEET	1	Copper
	Duct Material: Plastic	Insulation Type: THHN		Insulation Class:			
	+/- Impedance: 0.1293 + J 0.0342	Ohms/1000 ft		0.6734 + J 0.1781		PU	
	Z0 Impedance: 0.2056 + J 0.0870	Ohms/1000 ft		1.07 + J 0.4531		PU	
T-PS1-F	111 FUSE CUT-OUTS	BUS-0080	1	4160	0.100 FEET	2/0	Copper
	Duct Material: Plastic	Insulation Type: EPR		Insulation Class:			
	+/- Impedance: 0.0819 + J 0.0509	Ohms/1000 ft		0.00005 + J 0.00003		PU	
	Z0 Impedance: 0.1302 + J 0.1296	Ohms/1000 ft		0.00008 + J 0.00007		PU	

TRANSFORMER INPUT DATA

TRANSFORMER NOMINAL NAME	PRIMARY RECORD NO NAME	VOLTS L-L	* SECONDARY RECORD NO NAME	VOLTS L-L	FULL-LOAD KVA	KVA
AEL-XFMR-01A	BUS-0007	D 4160.00	BUS-0089	YG 480.00	500.00	500.00
	Pos. Seq. Z%: 1.13 + J 5.64	(Zpu 2.26 + j 11.28)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
AEL-XFMR-CPP11	BUS-0066	D 480.00	011 AEL-CPP-11	YG 208.00	30.00	30.00
	Pos. Seq. Z%: 1.72 + J 4.69	(Zpu 57.42 + j 156.4)	Shell Type			
	Zero Seq. Z%: 1.72 + J 4.69	(Sec 57.42 + j 156.4 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
AEL-XFMR-LP11	BUS-0063	D 480.00	010 AEL-LP-11	YG 208.00	45.00	45.00
	Pos. Seq. Z%: 1.62 + J 0.778	(Zpu 36.06 + j 17.31)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
CPS-XFMR-01	CPS ENERGY	D 13800.0	100 PLANT MAIN SWBD SWB-1	YG 4160.00	2500.00	2500.00
	Pos. Seq. Z%: 0.526 + J 5.29	(Zpu 0.210 + j 2.12)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
CPS-XFMR-01A	BUS-0085	D 13800.0	BUS-0002	YG 4160.00	2500.00	2500.00
	Pos. Seq. Z%: 0.529 + J 5.29	(Zpu 0.211 + j 2.12)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
CPS-XFMR-02A	BUS-0084	D 13800.0	BUS-0001	YG 4160.00	2500.00	2500.00
	Pos. Seq. Z%: 0.529 + J 5.29	(Zpu 0.211 + j 2.12)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					

TRANSFORMER INPUT DATA

TRANSFORMER NOMINAL NAME	PRIMARY RECORD NO NAME	VOLTS L-L	* SECONDARY RECORD NO NAME	VOLTS L-L	FULL-LOAD KVA	KVA
HEL-XFMR-01	BUS-0032	D 4160.00	BUS-0081	YG 480.00	500.00	500.00
	Pos. Seq. Z%: 1.13 + J 5.64	(Zpu 2.26 + j 11.28)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
HEL-XFMR-CPP1	BUS-0047	D 480.00	BUS-0048	YG 208.00	15.00	15.00
	Pos. Seq. Z%: 1.88 + J 4.63	(Zpu 125.1 + j 308.9)	Shell Type			
	Zero Seq. Z%: 1.88 + J 4.63	(Sec 125.1 + j 308.9 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
HEL-XFMR-LP1	BUS-0044	D 480.00	BUS-0045	YG 208.00	30.00	30.00
	Pos. Seq. Z%: 1.68 + J 2.14	(Zpu 56.09 + j 71.23)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
MPZ XFM-01	BUS-0069	D 480.00	012 AEL-MPC-01	YG 208.00	30.00	30.00
	Pos. Seq. Z%: 1.72 + J 4.69	(Zpu 57.42 + j 156.4)	Shell Type			
	Zero Seq. Z%: 1.72 + J 4.69	(Sec 57.42 + j 156.4 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
MPZ XFM-02	BUS-0071	D 480.00	013 AEL-MPC-02	YG 208.00	30.00	30.00
	Pos. Seq. Z%: 1.72 + J 4.69	(Zpu 57.42 + j 156.4)	Shell Type			
	Zero Seq. Z%: 1.72 + J 4.69	(Sec 57.42 + j 156.4 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
PEL-XFMR-02	108 PELXFM PRI	D 4160.00	BUS-0088	YG 480.00	500.00	500.00
	Pos. Seq. Z%: 1.13 + J 5.64	(Zpu 2.26 + j 11.28)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					

TRANSFORMER INPUT DATA

TRANSFORMER NOMINAL NAME	PRIMARY RECORD NO NAME	VOLTS L-L	* SECONDARY RECORD NO NAME	VOLTS L-L	FULL-LOAD KVA	KVA
SEL-XFMR-01	BUS-0078	D 4160.00	BUS-0079	YG 480.00	300.00	300.00
	Pos. Seq. Z%: 1.19 + J 5.37	(Zpu 3.98 + j 17.90)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
SEL-XFMR-CPP11	BUS-0054	D 480.00	BUS-0055	YG 208.00	15.00	15.00
	Pos. Seq. Z%: 1.88 + J 4.63	(Zpu 125.1 + j 308.9)	Shell Type			
	Zero Seq. Z%: 1.88 + J 4.63	(Sec 125.1 + j 308.9 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
SEL-XFMR-LP12	BUS-0051	D 480.00	BUS-0052	YG 240.00	50.00	50.00
	Pos. Seq. Z%: 1.61 + J 4.74	(Zpu 32.11 + j 94.71)	Shell Type			
	Zero Seq. Z%: 1.61 + J 4.74	(Sec 32.11 + j 94.71 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					
T-PS1	BUS-0080	D 4160.00	112 PMC-MCC-01	YG 480.00	300.00	300.00
	Pos. Seq. Z%: 1.19 + J 5.37	(Zpu 3.98 + j 17.90)	Shell Type			
	Zero Seq. Z%: 0.000 + J 0.000	(Sec 0.000 + j 0.000 Pri Open)				
	Taps Pri. 0.000 % Sec. 0.000 % Phase Shift (Pri. Leading Sec.): 30.00 Deg.					

GENERATION CONTRIBUTION DATA

BUS NAME	CONTRIBUTION NAME	VOLTAGE		X*d	X/R
		L-L	MVA		
BUS-0084	UTIL-0007	13800.0	69.60		
	Three Phase Contribution:	2912.00 AMPS	2.34		
	Pos Sequence Impedance (100 MVA Base)	0.5648 + J	1.32 PU		
	Zero Sequence Impedance (100 MVA Base)	10000000 + J	10000000 PU		
BUS-0085	UTIL-0008	13800.0	69.60		
	Three Phase Contribution:	2912.00 AMPS	2.34		
	Pos Sequence Impedance (100 MVA Base)	0.5648 + J	1.32 PU		
	Zero Sequence Impedance (100 MVA Base)	10000000 + J	10000000 PU		
CPS ENERGY	CPS UTI2	13800.0	69.60		
	Three Phase Contribution:	2912.00 AMPS	2.34		
	Pos Sequence Impedance (100 MVA Base)	0.5648 + J	1.32 PU		
	Zero Sequence Impedance (100 MVA Base)	10000000 + J	10000000 PU		

MOTOR CONTRIBUTION DATA

BUS NAME	CONTRIBUTION NAME	VOLTAGE L-L	BASE kVA	X"d	X/R	Motor Number
002 LC-AASBC01	AIR BLOWER-01	4160	787.37	0.2	24.2	1.00
	Pos Sequence Impedance (100 MVA Base)	1.05 + j	25.40 PU			
003 LC-AASBC02	AIR BLOWER-02	4160	787.37	0.2	24.2	1.00
	Pos Sequence Impedance (100 MVA Base)	1.05 + j	25.40 PU			
006 AIS-LCP-01	AIS-LCP-01	480	33.30	0.25	6.00	1.00
	Pos Sequence Impedance (100 MVA Base)	125.13 + j	750.75 PU			
007 AIS-LCP-02	AIS-LCP-02	480	33.30	0.25	6.00	1.00
	Pos Sequence Impedance (100 MVA Base)	125.13 + j	750.75 PU			
016 AIS-LCP-03	AIS-LCP-03	480	33.30	0.25	6.00	1.00
	Pos Sequence Impedance (100 MVA Base)	125.13 + j	750.75 PU			
017 AIS-LCP-04	AIS-LCP-04	480	33.30	0.25	6.00	1.00
	Pos Sequence Impedance (100 MVA Base)	125.13 + j	750.75 PU			
018 LC-AASBC03	AIR BLOWER-03	4160	787.37	0.2	24.2	1.00
	Pos Sequence Impedance (100 MVA Base)	1.05 + j	25.40 PU			
019 LC-AASBC04	AIR BLOWER-04	4160	787.37	0.2	24.2	1.00
	Pos Sequence Impedance (100 MVA Base)	1.05 + j	25.40 PU			
105 HEL-PDP-01	T. LOAD HEL-PDP01	480	7.00	0.25	6.00	1.00
	Pos Sequence Impedance (100 MVA Base)	595.24 + j	3571.43 PU			
109 PMC-MCC-02	LC-DDMP02	480	50.00	0.2	5.30	1.00
	Pos Sequence Impedance (100 MVA Base)	75.47 + j	400.00 PU			

MOTOR CONTRIBUTION DATA

BUS NAME	CONTRIBUTION NAME	VOLTAGE L-L	BASE kVA	X"d	X/R	Motor Number
109 PMC-MCC-02	T. LOAD PMC-MCC-02 Pos Sequence Impedance (100 MVA Base)	480 260.42 + j 1562.50 PU	16.00	0.25	6.00	1.00
109 PMC-MCC-02	LC-DDMP01 Pos Sequence Impedance (100 MVA Base)	480 75.47 + j 400.00 PU	50.00	0.2	5.30	1.00
110 AEL-PDP-02	T. LOAD AEL-PDP02 Pos Sequence Impedance (100 MVA Base)	480 462.96 + j 2777.78 PU	9.00	0.25	6.00	1.00
112 PMC-MCC-01	T. LOAD PMC-MCC-01 Pos Sequence Impedance (100 MVA Base)	480 252.53 + j 1515.15 PU	16.50	0.25	6.00	1.00
113 AEL-PDP-01	T. LOAD AEL-PDP01 Pos Sequence Impedance (100 MVA Base)	480 694.44 + j 4166.67 PU	6.00	0.25	6.00	1.00
114 PEL-PDP-01	T. LOAD PEL-PDP01 Pos Sequence Impedance (100 MVA Base)	480 694.44 + j 4166.67 PU	6.00	0.25	6.00	1.00
115 SEL-PDP-11	T. LOAD SEL-PDP-11 Pos Sequence Impedance (100 MVA Base)	480 53.57 + j 535.70 PU	31.58	0.1692	10.0	1.00
BUS-0059	AEL-H-01 Pos Sequence Impedance (100 MVA Base)	480 313.28 + j 1879.70 PU	13.30	0.25	6.00	1.00
BUS-0077	AEL-H-02 Pos Sequence Impedance (100 MVA Base)	480 313.28 + j 1879.70 PU	13.30	0.25	6.00	1.00

APPENDIX C: SHORT CIRCUIT OUTPUT TABULATIONS

ML10660
SAWS LEON CREEK WRC
SAN ANTONIO, TX
EXISTING UTILITY
Jul 12, 2011 14:51:27

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====						
001 AMC-MCC-01A	3P Duty: 7.290 KA AT -78.08 DEG (52.53 MVA)	X/R:	9.39			
	VOLTAGE: 4160. EQUIV. IMPEDANCE= 0.0681 + J 0.3224 OHMS					
AASBC02-P	003 LC-AASBC02	0.546 KA		ANG:	92.40	
AASBC01-P	002 LC-AASBC01	0.546 KA		ANG:	92.40	
AEL-XFMR-01A-F	BUS-0007	0.081 KA		ANG:	99.94	
AMC-MCC01A-F	BUS-0003	5.070 KA		ANG:	-73.96	
AMC-MCC01-TF	014 AMC-MCC-01B	1.091 KA		ANG:	92.41	
002 LC-AASBC01	3P Duty: 7.219 KA AT -77.71 DEG (52.02 MVA)	X/R:	8.92			
	VOLTAGE: 4160. EQUIV. IMPEDANCE= 0.0708 + J 0.3251 OHMS					
	CONTRIBUTIONS: AIR BLOWER-01					
AASBC01-P	001 AMC-MCC-01A	6.682 KA		ANG:	-76.90	
003 LC-AASBC02	3P Duty: 7.219 KA AT -77.71 DEG (52.02 MVA)	X/R:	8.92			
	VOLTAGE: 4160. EQUIV. IMPEDANCE= 0.0708 + J 0.3251 OHMS					
	CONTRIBUTIONS: AIR BLOWER-02					
AASBC02-P	001 AMC-MCC-01A	6.682 KA		ANG:	-76.90	
005 AEL-PDP-11A	3P Duty: 9.403 KA AT -77.58 DEG (7.82 MVA)	X/R:	4.84			
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0063 + J 0.0288 OHMS					
	LOW VOLTAGE POWER CIRCUIT BREAKER 9.403 KA					
	MOLDED CASE CIRCUIT BREAKER < 20KA 10.434 KA					
	MOLDED CASE CIRCUIT BREAKER > 20KA 9.403 KA					
AIS-LCP2-P	007 AIS-LCP-02	0.158 KA		ANG:	99.70	
AIS-LCP1-P	006 AIS-LCP-01	0.158 KA		ANG:	99.70	
AEL-H1-P	BUS-0059	0.063 KA		ANG:	99.85	
AEL-PDP11A-F	BUS-0089	8.647 KA		ANG:	-257.34	
AEL-PDP11-T	015 AEL-PDP-11B	0.378 KA		ANG:	99.73	
006 AIS-LCP-01	3P Duty: 8.209 KA AT -65.85 DEG (6.82 MVA)	X/R:	2.33			
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0138 + J 0.0308 OHMS					
	LOW VOLTAGE POWER CIRCUIT BREAKER 8.209 KA					
	MOLDED CASE CIRCUIT BREAKER < 10KA 8.891 KA					
	MOLDED CASE CIRCUIT BREAKER < 20KA 8.209 KA					
	MOLDED CASE CIRCUIT BREAKER > 20KA 8.209 KA					
	CONTRIBUTIONS: AIS-LCP-01					
AIS-LCP1-P	005 AEL-PDP-11A	8.056 KA		ANG:	-65.57	
007 AIS-LCP-02	3P Duty: 8.209 KA AT -65.85 DEG (6.82 MVA)	X/R:	2.33			
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0138 + J 0.0308 OHMS					

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====					
LOW VOLTAGE POWER CIRCUIT BREAKER	8.209 KA				
MOLDED CASE CIRCUIT BREAKER < 10KA	8.891 KA				
MOLDED CASE CIRCUIT BREAKER < 20KA	8.209 KA				
MOLDED CASE CIRCUIT BREAKER > 20KA	8.209 KA				
CONTRIBUTIONS: AIS-LCP-02		0.158 KA	ANG:	-80.54	
AIS-LCP2-P	005 AEL-PDP-11A	8.056 KA	ANG:	-65.57	
008L AEL-ATS-01	3P Duty: 9.012 KA AT -75.16 DEG (7.49 MVA)	X/R:	3.98		
VOLTAGE:	480. EQUIV. IMPEDANCE= 0.0079 + J 0.0297 OHMS				
LOW VOLTAGE POWER CIRCUIT BREAKER	9.012 KA				
MOLDED CASE CIRCUIT BREAKER < 20KA	9.547 KA				
MOLDED CASE CIRCUIT BREAKER > 20KA	9.012 KA				
AUTO-0001	BUS-0062	9.012 KA	ANG:	104.84	
009 AEL-PDP-12	3P Duty: 8.609 KA AT -72.77 DEG (7.16 MVA)	X/R:	3.36		
VOLTAGE:	480. EQUIV. IMPEDANCE= 0.0095 + J 0.0307 OHMS				
LOW VOLTAGE POWER CIRCUIT BREAKER	8.609 KA				
MOLDED CASE CIRCUIT BREAKER < 20KA	8.739 KA				
MOLDED CASE CIRCUIT BREAKER > 20KA	8.609 KA				
AEL-PDP12-F	008L AEL-ATS-01	8.609 KA	ANG:	-72.77	
010 AEL-LP-11	3P Duty: 5.178 KA AT -35.63 DEG (1.87 MVA)	X/R:	0.72		
VOLTAGE:	208. EQUIV. IMPEDANCE= 0.0189 + J 0.0135 OHMS				
LOW VOLTAGE POWER CIRCUIT BREAKER	5.178 KA				
MOLDED CASE CIRCUIT BREAKER < 10KA	5.178 KA				
MOLDED CASE CIRCUIT BREAKER < 20KA	5.178 KA				
MOLDED CASE CIRCUIT BREAKER > 20KA	5.178 KA				
AEL-XFMR-LP11	BUS-0063	5.178 KA	ANG:	-215.63	
011 AEL-CPP-11	3P Duty: 1.502 KA AT -67.31 DEG (0.54 MVA)	X/R:	2.40		
VOLTAGE:	208. EQUIV. IMPEDANCE= 0.0308 + J 0.0738 OHMS				
LOW VOLTAGE POWER CIRCUIT BREAKER	1.502 KA				
MOLDED CASE CIRCUIT BREAKER < 10KA	1.640 KA				
MOLDED CASE CIRCUIT BREAKER < 20KA	1.502 KA				
MOLDED CASE CIRCUIT BREAKER > 20KA	1.502 KA				
AEL-XFMR-CPP11	BUS-0066	1.502 KA	ANG:	112.69	
012 AEL-MPC-01	3P Duty: 1.411 KA AT -63.70 DEG (0.51 MVA)	X/R:	2.03		
VOLTAGE:	208. EQUIV. IMPEDANCE= 0.0377 + J 0.0763 OHMS				
LOW VOLTAGE POWER CIRCUIT BREAKER	1.411 KA				
MOLDED CASE CIRCUIT BREAKER < 10KA	1.471 KA				
MOLDED CASE CIRCUIT BREAKER < 20KA	1.411 KA				
MOLDED CASE CIRCUIT BREAKER > 20KA	1.411 KA				
MPZ XFM-01	BUS-0069	1.411 KA	ANG:	116.30	

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====						
013 AEL-MPC-02	3P Duty: 1.301 KA AT -58.75 DEG (0.47 MVA)	X/R:	1.65			
	VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0479 + J 0.0789 OHMS					
	LOW VOLTAGE POWER CIRCUIT BREAKER 1.301 KA					
	MOLDED CASE CIRCUIT BREAKER < 10KA 1.301 KA					
	MOLDED CASE CIRCUIT BREAKER < 20KA 1.301 KA					
	MOLDED CASE CIRCUIT BREAKER > 20KA 1.301 KA					
	MPZ XFM-02 BUS-0071	1.301 KA		ANG:	-238.75	
014 AMC-MCC-01B	3P Duty: 7.278 KA AT -78.05 DEG (52.44 MVA)	X/R:	9.37			
	VOLTAGE: 4160. EQUIV. IMPEDANCE= 0.0683 + J 0.3229 OHMS					
	AASBC04-P 019 LC-AASBC04	0.546 KA		ANG:	92.40	
	AASBC03-P 018 LC-AASBC03	0.546 KA		ANG:	92.40	
	AMC-MCC01-TF 001 AMC-MCC-01A	6.205 KA		ANG:	-76.38	
015 AEL-PDP-11B	3P Duty: 9.402 KA AT -77.58 DEG (7.82 MVA)	X/R:	4.84			
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0063 + J 0.0288 OHMS					
	LOW VOLTAGE POWER CIRCUIT BREAKER 9.402 KA					
	MOLDED CASE CIRCUIT BREAKER < 20KA 10.433 KA					
	MOLDED CASE CIRCUIT BREAKER > 20KA 9.402 KA					
	AIS-LCP4-P 017 AIS-LCP-04	0.158 KA		ANG:	99.70	
	AIS-LCP3-P 016 AIS-LCP-03	0.158 KA		ANG:	99.70	
	AEL-H2-P BUS-0077	0.063 KA		ANG:	99.85	
	AEL-PDP11-T 005 AEL-PDP-11A	9.024 KA		ANG:	-77.46	
016 AIS-LCP-03	3P Duty: 8.208 KA AT -65.85 DEG (6.82 MVA)	X/R:	2.33			
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0138 + J 0.0308 OHMS					
	LOW VOLTAGE POWER CIRCUIT BREAKER 8.208 KA					
	MOLDED CASE CIRCUIT BREAKER < 10KA 8.891 KA					
	MOLDED CASE CIRCUIT BREAKER < 20KA 8.208 KA					
	MOLDED CASE CIRCUIT BREAKER > 20KA 8.208 KA					
	CONTRIBUTIONS: AIS-LCP-03	0.158 KA		ANG:	-80.54	
	AIS-LCP3-P 015 AEL-PDP-11B	8.055 KA		ANG:	-65.56	
017 AIS-LCP-04	3P Duty: 8.208 KA AT -65.85 DEG (6.82 MVA)	X/R:	2.33			
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0138 + J 0.0308 OHMS					
	LOW VOLTAGE POWER CIRCUIT BREAKER 8.208 KA					
	MOLDED CASE CIRCUIT BREAKER < 10KA 8.891 KA					
	MOLDED CASE CIRCUIT BREAKER < 20KA 8.208 KA					
	MOLDED CASE CIRCUIT BREAKER > 20KA 8.208 KA					
	CONTRIBUTIONS: AIS-LCP-04	0.158 KA		ANG:	-80.54	
	AIS-LCP4-P 015 AEL-PDP-11B	8.055 KA		ANG:	-65.56	
018 LC-AASBC03	3P Duty: 7.208 KA AT -77.68 DEG (51.93 MVA)	X/R:	8.91			

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====						
	VOLTAGE: 4160.	EQUIV. IMPEDANCE=	0.0711 + J	0.3256	OHMS	
	CONTRIBUTIONS: AIR BLOWER-03					0.546 KA ANG: -87.64
	AASBC03-P	014 AMC-MCC-01B				6.671 KA ANG: -76.87
019 LC-AASBC04		3P Duty: 7.208 KA AT	-77.68 DEG (51.93 MVA)	X/R: 8.91	
	VOLTAGE: 4160.	EQUIV. IMPEDANCE=	0.0711 + J	0.3256	OHMS	
	CONTRIBUTIONS: AIR BLOWER-04					0.546 KA ANG: -87.64
	AASBC04-P	014 AMC-MCC-01B				6.671 KA ANG: -76.87
100 PLANT MAIN SWBD SWB-1		3P Duty: 2.659 KA AT	-74.29 DEG (19.16 MVA)	X/R: 3.61	
	VOLTAGE: 4160.	EQUIV. IMPEDANCE=	0.2447 + J	0.8696	OHMS	
	CPS-XFMR-01	CPS ENERGY				2.539 KA ANG: -254.00
	OE-WH	111 FUSE CUT-OUTS				0.015 KA ANG: 99.61
	CBL-0061	BUS-0082				0.025 KA ANG: 96.02
	OE-WL	101 FUSE CUT-OUTS				0.080 KA ANG: 100.78
101 FUSE CUT-OUTS		3P Duty: 2.659 KA AT	-74.29 DEG (19.16 MVA)	X/R: 3.61	
	VOLTAGE: 4160.	EQUIV. IMPEDANCE=	0.2447 + J	0.8696	OHMS	
	PEL-XFMR02-F	108 PELXFM PRI				0.076 KA ANG: 100.84
	HV44	102 HV44				0.004 KA ANG: 99.58
	OE-WL	100 PLANT MAIN SWBD SWB-1				2.579 KA ANG: -74.13
102 HV44		3P Duty: 2.579 KA AT	-72.46 DEG (18.58 MVA)	X/R: 3.21	
	VOLTAGE: 4160.	EQUIV. IMPEDANCE=	0.2807 + J	0.8881	OHMS	
	HEL-XFMR01-F	BUS-0032				0.004 KA ANG: 99.57
	HV44	101 FUSE CUT-OUTS				2.575 KA ANG: -72.45
103L HEL-ATS-01		3P Duty: 6.870 KA AT	-75.36 DEG (5.71 MVA)	X/R: 3.85	
	VOLTAGE: 480.	EQUIV. IMPEDANCE=	0.0102 + J	0.0390	OHMS	
	LOW VOLTAGE POWER CIRCUIT BREAKER	6.870 KA				
	MOLDED CASE CIRCUIT BREAKER < 10KA	8.519 KA				
	MOLDED CASE CIRCUIT BREAKER < 20KA	7.220 KA				
	MOLDED CASE CIRCUIT BREAKER > 20KA	6.870 KA				
	AUTO-0002	BUS-0033				6.837 KA ANG: -75.34
	MCC1-F	104 MCC-1				0.033 KA ANG: 99.56
104 MCC-1		3P Duty: 6.560 KA AT	-74.36 DEG (5.45 MVA)	X/R: 3.59	
	VOLTAGE: 480.	EQUIV. IMPEDANCE=	0.0114 + J	0.0407	OHMS	
	LOW VOLTAGE POWER CIRCUIT BREAKER	6.560 KA				
	MOLDED CASE CIRCUIT BREAKER < 10KA	7.992 KA				
	MOLDED CASE CIRCUIT BREAKER < 20KA	6.773 KA				
	MOLDED CASE CIRCUIT BREAKER > 20KA	6.560 KA				
	MCC1-F	103L HEL-ATS-01				6.527 KA ANG: -74.32
	HEL-PDP01-F	105 HEL-PDP-01				0.033 KA ANG: 99.55

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

```

=====
105 HEL-PDP-01          3P Duty:  5.412 KA AT  -60.20 DEG (  4.50 MVA) X/R:   1.76
VOLTAGE:   480.  EQUIV. IMPEDANCE=  0.0255 + J  0.0444 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER  5.412 KA
MOLDED CASE CIRCUIT BREAKER < 10KA  5.436 KA
MOLDED CASE CIRCUIT BREAKER < 20KA  5.412 KA
MOLDED CASE CIRCUIT BREAKER > 20KA  5.412 KA
CONTRIBUTIONS:  T.LOAD HEL-PDP01          0.033 KA    ANG:  -80.54
HEL-PDP01-F          104 MCC-1          5.380 KA    ANG:  -60.08

106 HEL-LP-01          3P Duty:  2.238 KA AT  -48.14 DEG (  0.81 MVA) X/R:   1.12
VOLTAGE:   208.  EQUIV. IMPEDANCE=  0.0358 + J  0.0400 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER  2.238 KA
MOLDED CASE CIRCUIT BREAKER < 10KA  2.238 KA
MOLDED CASE CIRCUIT BREAKER < 20KA  2.238 KA
MOLDED CASE CIRCUIT BREAKER > 20KA  2.238 KA
HEL-LP1-F          BUS-0045          2.238 KA    ANG:  -48.14

107 HEL-CPP-01          3P Duty:  0.753 KA AT  -63.68 DEG (  0.27 MVA) X/R:   2.02
VOLTAGE:   208.  EQUIV. IMPEDANCE=  0.0707 + J  0.1429 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER  0.753 KA
MOLDED CASE CIRCUIT BREAKER < 10KA  0.785 KA
MOLDED CASE CIRCUIT BREAKER < 20KA  0.753 KA
MOLDED CASE CIRCUIT BREAKER > 20KA  0.753 KA
HEL-CPP1-F          BUS-0048          0.753 KA    ANG:  -63.68

108 PELXFM PRI          3P Duty:  2.617 KA AT  -73.49 DEG ( 18.86 MVA) X/R:   3.43
VOLTAGE:  4160.  EQUIV. IMPEDANCE=  0.2608 + J  0.8798 OHMS
PEL-XFMR-02          BUS-0088          0.076 KA    ANG:  100.81
PEL-XFMR02-F          101 FUSE CUT-OUTS          2.542 KA    ANG:  -73.32

109 PMC-MCC-02          3P Duty:  7.232 KA AT  -75.05 DEG (  6.01 MVA) X/R:   3.80
VOLTAGE:   480.  EQUIV. IMPEDANCE=  0.0099 + J  0.0370 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER  7.232 KA
MOLDED CASE CIRCUIT BREAKER < 10KA  8.941 KA
MOLDED CASE CIRCUIT BREAKER < 20KA  7.577 KA
MOLDED CASE CIRCUIT BREAKER > 20KA  7.232 KA
CONTRIBUTIONS:  T.LOAD PMC-MCC-02          0.076 KA    ANG:  -80.54
                  LC-DDMP02          0.295 KA    ANG:  -79.32
                  LC-DDMP01          0.295 KA    ANG:  -79.32
AEL-PDP2-F          110 AEL-PDP-02          0.043 KA    ANG:  99.73
PMC-MCC-02          BUS-0088          6.525 KA    ANG: -254.56

110 AEL-PDP-02          3P Duty:  4.482 KA AT  -47.57 DEG (  3.73 MVA) X/R:   1.12

```

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====						
VOLTAGE:	480.	EQUIV. IMPEDANCE=	0.0417 + J 0.0456	OHMS		
LOW VOLTAGE POWER CIRCUIT BREAKER			4.482	KA		
MOLDED CASE CIRCUIT BREAKER < 10KA			4.482	KA		
MOLDED CASE CIRCUIT BREAKER < 20KA			4.482	KA		
MOLDED CASE CIRCUIT BREAKER > 20KA			4.482	KA		
CONTRIBUTIONS: T.LOAD AEL-PDP02			0.043	KA	ANG:	-80.54
AEL-PDP2-F	109	PMC-MCC-02	4.446	KA	ANG:	-47.27
111 FUSE CUT-OUTS	3P Duty:	2.637 KA AT	-74.00 DEG (19.00 MVA)	X/R:	3.54
VOLTAGE:	4160.	EQUIV. IMPEDANCE=	0.2510 + J 0.8755	OHMS		
T-PS1-F		BUS-0080	0.015	KA	ANG:	99.61
OE-WH		100 PLANT MAIN SWBD SWB-1	2.622	KA	ANG:	-73.96
112 PMC-MCC-01	3P Duty:	5.227 KA AT	-76.78 DEG (4.35 MVA)	X/R:	4.28
VOLTAGE:	480.	EQUIV. IMPEDANCE=	0.0121 + J 0.0516	OHMS		
LOW VOLTAGE POWER CIRCUIT BREAKER			5.227	KA		
MOLDED CASE CIRCUIT BREAKER < 10KA			6.653	KA		
MOLDED CASE CIRCUIT BREAKER < 20KA			5.639	KA		
MOLDED CASE CIRCUIT BREAKER > 20KA			5.227	KA		
CONTRIBUTIONS: T.LOAD PMC-MCC-01			0.078	KA	ANG:	-80.54
PEL-PDP-F	114	PEL-PDP-01	0.028	KA	ANG:	99.59
AEL-PDP1-F	113	AEL-PDP-01	0.028	KA	ANG:	99.76
T-PS1		BUS-0080	5.093	KA	ANG:	-256.68
113 AEL-PDP-01	3P Duty:	3.012 KA AT	-45.61 DEG (2.50 MVA)	X/R:	1.05
VOLTAGE:	480.	EQUIV. IMPEDANCE=	0.0644 + J 0.0658	OHMS		
LOW VOLTAGE POWER CIRCUIT BREAKER			3.012	KA		
MOLDED CASE CIRCUIT BREAKER < 10KA			3.012	KA		
MOLDED CASE CIRCUIT BREAKER < 20KA			3.012	KA		
MOLDED CASE CIRCUIT BREAKER > 20KA			3.012	KA		
CONTRIBUTIONS: T.LOAD AEL-PDP01			0.028	KA	ANG:	-80.54
AEL-PDP1-F	112	PMC-MCC-01	2.989	KA	ANG:	-45.30
114 PEL-PDP-01	3P Duty:	4.186 KA AT	-58.29 DEG (3.48 MVA)	X/R:	1.64
VOLTAGE:	480.	EQUIV. IMPEDANCE=	0.0348 + J 0.0563	OHMS		
LOW VOLTAGE POWER CIRCUIT BREAKER			4.186	KA		
MOLDED CASE CIRCUIT BREAKER < 10KA			4.186	KA		
MOLDED CASE CIRCUIT BREAKER < 20KA			4.186	KA		
MOLDED CASE CIRCUIT BREAKER > 20KA			4.186	KA		
CONTRIBUTIONS: T.LOAD PEL-PDP01			0.028	KA	ANG:	-80.54
PEL-PDP-F	112	PMC-MCC-01	4.159	KA	ANG:	-58.14
115 SEL-PDP-11	3P Duty:	5.167 KA AT	-75.47 DEG (4.30 MVA)	X/R:	4.02
VOLTAGE:	480.	EQUIV. IMPEDANCE=	0.0135 + J 0.0519	OHMS		

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====					
	LOW VOLTAGE POWER CIRCUIT BREAKER	5.167 KA			
	MOLDED CASE CIRCUIT BREAKER < 10KA	6.476 KA			
	MOLDED CASE CIRCUIT BREAKER < 20KA	5.489 KA			
	MOLDED CASE CIRCUIT BREAKER > 20KA	5.167 KA			
	CONTRIBUTIONS: T.LOAD SEL-PDP-11		0.223 KA	ANG:	-84.29
	SEL-PDP-F	BUS-0079	4.947 KA	ANG:	-255.07
116 SEL-LP-12	3P Duty: 1.930 KA AT -71.30 DEG (0.80 MVA)		X/R:	2.97	
	VOLTAGE: 240. EQUIV. IMPEDANCE= 0.0230 + J 0.0680 OHMS				
	LOW VOLTAGE POWER CIRCUIT BREAKER	1.930 KA			
	MOLDED CASE CIRCUIT BREAKER < 10KA	2.236 KA			
	MOLDED CASE CIRCUIT BREAKER < 20KA	1.930 KA			
	MOLDED CASE CIRCUIT BREAKER > 20KA	1.930 KA			
	SEL-LP12-F	BUS-0052	1.930 KA	ANG:	-71.30
117 SEL-CPP-11	3P Duty: 0.752 KA AT -64.54 DEG (0.27 MVA)		X/R:	2.10	
	VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0687 + J 0.1443 OHMS				
	LOW VOLTAGE POWER CIRCUIT BREAKER	0.752 KA			
	MOLDED CASE CIRCUIT BREAKER < 10KA	0.791 KA			
	MOLDED CASE CIRCUIT BREAKER < 20KA	0.752 KA			
	MOLDED CASE CIRCUIT BREAKER > 20KA	0.752 KA			
	SEL-CPP11-F	BUS-0055	0.752 KA	ANG:	-64.54
BUS-0082	3P Duty: 2.659 KA AT -74.29 DEG (19.16 MVA)		X/R:	3.61	
	VOLTAGE: 4160. EQUIV. IMPEDANCE= 0.2447 + J 0.8696 OHMS				
	SEL-XFMR01-F	BUS-0078	0.025 KA	ANG:	-83.98
	CBL-0061	100 PLANT MAIN SWBD SWB-1	2.634 KA	ANG:	-74.19
CPS ENERGY	3P Duty: 1.268 KA AT -67.91 DEG (30.30 MVA)		X/R:	2.52	
	VOLTAGE: 13800. EQUIV. IMPEDANCE= 2.3640 + J 5.8237 OHMS				
	CONTRIBUTIONS: CPS UTI1		1.233 KA	ANG:	-67.55
	CPS-XFMR-01	100 PLANT MAIN SWBD SWB-1	0.036 KA	ANG:	-80.43

F A U L T S T U D Y S U M M A R Y
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

BUS RECORD NO NAME	V O L T A G E A V A I L A B L E			F A U L T D U T I E S (KA)	
	L-L	3 PHASE	X/R	LINE/GRND	X/R
001 AMC-MCC-01A	4160.	7.290	9.39		
002 LC-AASBC01	4160.	7.219	8.92		
003 LC-AASBC02	4160.	7.219	8.92		
005 AEL-PDP-11A	480.	9.403	4.84		
006 AIS-LCP-01	480.	8.209	2.33		
007 AIS-LCP-02	480.	8.209	2.33		
008L AEL-ATS-01	480.	9.012	3.98		
009 AEL-PDP-12	480.	8.609	3.36		
010 AEL-LP-11	208.	5.178	0.72		
011 AEL-CPP-11	208.	1.502	2.40		
012 AEL-MPC-01	208.	1.411	2.03		
013 AEL-MPC-02	208.	1.301	1.65		
014 AMC-MCC-01B	4160.	7.278	9.37		
015 AEL-PDP-11B	480.	9.402	4.84		
016 AIS-LCP-03	480.	8.208	2.33		
017 AIS-LCP-04	480.	8.208	2.33		
018 LC-AASBC03	4160.	7.208	8.91		
019 LC-AASBC04	4160.	7.208	8.91		
100 PLANT MAIN SWBD SWB-1	4160.	2.659	3.61		
101 FUSE CUT-OUTS	4160.	2.659	3.61		
102 HV44	4160.	2.579	3.21		
103L HEL-ATS-01	480.	6.870	3.85		
104 MCC-1	480.	6.560	3.59		
105 HEL-PDP-01	480.	5.412	1.76		
106 HEL-LP-01	208.	2.238	1.12		
107 HEL-CPP-01	208.	0.753	2.02		
108 PELXFM PRI	4160.	2.617	3.43		
109 PMC-MCC-02	480.	7.232	3.80		
110 AEL-PDP-02	480.	4.482	1.12		
111 FUSE CUT-OUTS	4160.	2.637	3.54		
112 PMC-MCC-01	480.	5.227	4.28		
113 AEL-PDP-01	480.	3.012	1.05		
114 PEL-PDP-01	480.	4.186	1.64		
115 SEL-PDP-11	480.	5.167	4.02		
116 SEL-LP-12	240.	1.930	2.97		
117 SEL-CPP-11	208.	0.752	2.10		
BUS-0082	4160.	2.659	3.61		
CPS ENERGY	13800.	1.268	2.52		

69 FAULTED BUSES, 89 BRANCHES, 22 CONTRIBUTIONS

*** SHORT CIRCUIT STUDY COMPLETE ***

ML10660
SAWS LEON CREEK WRC
SAN ANTONIO, TX
FUTURE UTILITY
Jul 12, 2011 14:47:37

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====						
001 AMC-MCC-01A	3P Duty: 10.089 KA AT -79.48 DEG (72.69 MVA)	X/R:	8.53			
	VOLTAGE: 4160. EQUIV. IMPEDANCE= 0.0435 + J 0.2341 OHMS					
AASBC02-P	003 LC-AASBC02	0.546 KA		ANG:	92.40	
AASBC01-P	002 LC-AASBC01	0.546 KA		ANG:	92.40	
AEL-XFMR-01A-F	BUS-0007	0.081 KA		ANG:	99.94	
AMC-MCC01A-F	BUS-0003	7.854 KA		ANG:	-77.23	
AMC-MCC01-TF	014 AMC-MCC-01B	1.091 KA		ANG:	92.41	
002 LC-AASBC01	3P Duty: 9.951 KA AT -78.92 DEG (71.70 MVA)	X/R:	7.95			
	VOLTAGE: 4160. EQUIV. IMPEDANCE= 0.0464 + J 0.2369 OHMS					
	CONTRIBUTIONS: AIR BLOWER-01	0.546 KA		ANG:	-87.64	
AASBC01-P	001 AMC-MCC-01A	9.411 KA		ANG:	-78.41	
003 LC-AASBC02	3P Duty: 9.951 KA AT -78.92 DEG (71.70 MVA)	X/R:	7.95			
	VOLTAGE: 4160. EQUIV. IMPEDANCE= 0.0464 + J 0.2369 OHMS					
	CONTRIBUTIONS: AIR BLOWER-02	0.546 KA		ANG:	-87.64	
AASBC02-P	001 AMC-MCC-01A	9.411 KA		ANG:	-78.41	
005 AEL-PDP-11A	3P Duty: 9.752 KA AT -77.68 DEG (8.11 MVA)	X/R:	4.74			
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0061 + J 0.0278 OHMS					
	LOW VOLTAGE POWER CIRCUIT BREAKER 9.752 KA					
	MOLDED CASE CIRCUIT BREAKER < 20KA 10.767 KA					
	MOLDED CASE CIRCUIT BREAKER > 20KA 9.752 KA					
AIS-LCP2-P	007 AIS-LCP-02	0.158 KA		ANG:	99.70	
AIS-LCP1-P	006 AIS-LCP-01	0.158 KA		ANG:	99.70	
AEL-H1-P	BUS-0059	0.063 KA		ANG:	99.85	
AEL-PDP11A-F	BUS-0089	8.996 KA		ANG:	-257.46	
AEL-PDP11-T	015 AEL-PDP-11B	0.378 KA		ANG:	99.73	
006 AIS-LCP-01	3P Duty: 8.469 KA AT -65.55 DEG (7.04 MVA)	X/R:	2.27			
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0135 + J 0.0298 OHMS					
	LOW VOLTAGE POWER CIRCUIT BREAKER 8.469 KA					
	MOLDED CASE CIRCUIT BREAKER < 10KA 9.104 KA					
	MOLDED CASE CIRCUIT BREAKER < 20KA 8.469 KA					
	MOLDED CASE CIRCUIT BREAKER > 20KA 8.469 KA					
	CONTRIBUTIONS: AIS-LCP-01	0.158 KA		ANG:	-80.54	
AIS-LCP1-P	005 AEL-PDP-11A	8.316 KA		ANG:	-65.27	
007 AIS-LCP-02	3P Duty: 8.469 KA AT -65.55 DEG (7.04 MVA)	X/R:	2.27			
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0135 + J 0.0298 OHMS					

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====					
	LOW VOLTAGE POWER CIRCUIT BREAKER	8.469 KA			
	MOLDED CASE CIRCUIT BREAKER < 10KA	9.104 KA			
	MOLDED CASE CIRCUIT BREAKER < 20KA	8.469 KA			
	MOLDED CASE CIRCUIT BREAKER > 20KA	8.469 KA			
	CONTRIBUTIONS: AIS-LCP-02		0.158 KA	ANG:	-80.54
	AIS-LCP2-P	005 AEL-PDP-11A	8.316 KA	ANG:	-65.27
008L AEL-ATS-01	3P Duty: 9.333 KA AT -75.18 DEG (7.76 MVA)		X/R:	3.88	
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0076 + J 0.0287 OHMS				
	LOW VOLTAGE POWER CIRCUIT BREAKER	9.333 KA			
	MOLDED CASE CIRCUIT BREAKER < 20KA	9.828 KA			
	MOLDED CASE CIRCUIT BREAKER > 20KA	9.333 KA			
	AUTO-0001	BUS-0062	9.333 KA	ANG:	104.82
009 AEL-PDP-12	3P Duty: 8.901 KA AT -72.70 DEG (7.40 MVA)		X/R:	3.28	
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0093 + J 0.0297 OHMS				
	LOW VOLTAGE POWER CIRCUIT BREAKER	8.901 KA			
	MOLDED CASE CIRCUIT BREAKER < 20KA	8.976 KA			
	MOLDED CASE CIRCUIT BREAKER > 20KA	8.901 KA			
	AEL-PDP12-F	008L AEL-ATS-01	8.901 KA	ANG:	-72.70
010 AEL-LP-11	3P Duty: 5.213 KA AT -35.32 DEG (1.88 MVA)		X/R:	0.71	
	VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0188 + J 0.0133 OHMS				
	LOW VOLTAGE POWER CIRCUIT BREAKER	5.213 KA			
	MOLDED CASE CIRCUIT BREAKER < 10KA	5.213 KA			
	MOLDED CASE CIRCUIT BREAKER < 20KA	5.213 KA			
	MOLDED CASE CIRCUIT BREAKER > 20KA	5.213 KA			
	AEL-XFMR-LP11	BUS-0063	5.213 KA	ANG:	144.68
011 AEL-CPP-11	3P Duty: 1.505 KA AT -67.30 DEG (0.54 MVA)		X/R:	2.39	
	VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0308 + J 0.0736 OHMS				
	LOW VOLTAGE POWER CIRCUIT BREAKER	1.505 KA			
	MOLDED CASE CIRCUIT BREAKER < 10KA	1.643 KA			
	MOLDED CASE CIRCUIT BREAKER < 20KA	1.505 KA			
	MOLDED CASE CIRCUIT BREAKER > 20KA	1.505 KA			
	AEL-XFMR-CPP11	BUS-0066	1.505 KA	ANG:	112.70
012 AEL-MPC-01	3P Duty: 1.414 KA AT -63.67 DEG (0.51 MVA)		X/R:	2.02	
	VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0377 + J 0.0761 OHMS				
	LOW VOLTAGE POWER CIRCUIT BREAKER	1.414 KA			
	MOLDED CASE CIRCUIT BREAKER < 10KA	1.473 KA			
	MOLDED CASE CIRCUIT BREAKER < 20KA	1.414 KA			
	MOLDED CASE CIRCUIT BREAKER > 20KA	1.414 KA			
	MPZ XFM-01	BUS-0069	1.414 KA	ANG:	116.33

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====						
013 AEL-MPC-02	3P Duty: 1.304 KA AT -58.72 DEG (0.47 MVA)	X/R:	1.65			
	VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0478 + J 0.0787 OHMS					
	LOW VOLTAGE POWER CIRCUIT BREAKER 1.304 KA					
	MOLDED CASE CIRCUIT BREAKER < 10KA 1.304 KA					
	MOLDED CASE CIRCUIT BREAKER < 20KA 1.304 KA					
	MOLDED CASE CIRCUIT BREAKER > 20KA 1.304 KA					
	MPZ XFM-02 BUS-0071	1.304 KA	ANG:	121.28		
014 AMC-MCC-01B	3P Duty: 10.064 KA AT -79.44 DEG (72.52 MVA)	X/R:	8.50			
	VOLTAGE: 4160. EQUIV. IMPEDANCE= 0.0437 + J 0.2346 OHMS					
	AASBC04-P 019 LC-AASBC04	0.546 KA	ANG:	92.40		
	AASBC03-P 018 LC-AASBC03	0.546 KA	ANG:	92.40		
	AMC-MCC01-TF 001 AMC-MCC-01A	8.985 KA	ANG:	-78.45		
015 AEL-PDP-11B	3P Duty: 9.751 KA AT -77.68 DEG (8.11 MVA)	X/R:	4.74			
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0061 + J 0.0278 OHMS					
	LOW VOLTAGE POWER CIRCUIT BREAKER 9.751 KA					
	MOLDED CASE CIRCUIT BREAKER < 20KA 10.766 KA					
	MOLDED CASE CIRCUIT BREAKER > 20KA 9.751 KA					
	AIS-LCP4-P 017 AIS-LCP-04	0.158 KA	ANG:	99.70		
	AIS-LCP3-P 016 AIS-LCP-03	0.158 KA	ANG:	99.70		
	AEL-H2-P BUS-0077	0.063 KA	ANG:	99.85		
	AEL-PDP11-T 005 AEL-PDP-11A	9.373 KA	ANG:	-77.57		
016 AIS-LCP-03	3P Duty: 8.468 KA AT -65.55 DEG (7.04 MVA)	X/R:	2.27			
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0135 + J 0.0298 OHMS					
	LOW VOLTAGE POWER CIRCUIT BREAKER 8.468 KA					
	MOLDED CASE CIRCUIT BREAKER < 10KA 9.103 KA					
	MOLDED CASE CIRCUIT BREAKER < 20KA 8.468 KA					
	MOLDED CASE CIRCUIT BREAKER > 20KA 8.468 KA					
	CONTRIBUTIONS: AIS-LCP-03	0.158 KA	ANG:	-80.54		
	AIS-LCP3-P 015 AEL-PDP-11B	8.316 KA	ANG:	-65.27		
017 AIS-LCP-04	3P Duty: 8.468 KA AT -65.55 DEG (7.04 MVA)	X/R:	2.27			
	VOLTAGE: 480. EQUIV. IMPEDANCE= 0.0135 + J 0.0298 OHMS					
	LOW VOLTAGE POWER CIRCUIT BREAKER 8.468 KA					
	MOLDED CASE CIRCUIT BREAKER < 10KA 9.103 KA					
	MOLDED CASE CIRCUIT BREAKER < 20KA 8.468 KA					
	MOLDED CASE CIRCUIT BREAKER > 20KA 8.468 KA					
	CONTRIBUTIONS: AIS-LCP-04	0.158 KA	ANG:	-80.54		
	AIS-LCP4-P 015 AEL-PDP-11B	8.316 KA	ANG:	-65.27		
018 LC-AASBC03	3P Duty: 9.927 KA AT -78.88 DEG (71.53 MVA)	X/R:	7.93			

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====						
	VOLTAGE: 4160.	EQUIV. IMPEDANCE=	0.0467 + J 0.2374	OHMS		
	CONTRIBUTIONS: AIR BLOWER-03				0.546 KA	ANG: -87.64
	AASBC03-P	014 AMC-MCC-01B			9.388 KA	ANG: -78.37
019 LC-AASBC04		3P Duty: 9.927 KA AT	-78.88 DEG (71.53 MVA)	X/R: 7.93		
	VOLTAGE: 4160.	EQUIV. IMPEDANCE=	0.0467 + J 0.2374	OHMS		
	CONTRIBUTIONS: AIR BLOWER-04				0.546 KA	ANG: -87.64
	AASBC04-P	014 AMC-MCC-01B			9.388 KA	ANG: -78.37
100 PLANT MAIN SWBD SWB-1		3P Duty: 4.057 KA AT	-77.38 DEG (29.23 MVA)	X/R: 4.49		
	VOLTAGE: 4160.	EQUIV. IMPEDANCE=	0.1293 + J 0.5777	OHMS		
	CPS-XFMR-01	CPS ENERGY			3.937 KA	ANG: -257.29
	OE-WH	111 FUSE CUT-OUTS			0.015 KA	ANG: 99.61
	CBL-0061	BUS-0082			0.025 KA	ANG: 96.02
	OE-WL	101 FUSE CUT-OUTS			0.080 KA	ANG: 100.78
101 FUSE CUT-OUTS		3P Duty: 4.057 KA AT	-77.38 DEG (29.23 MVA)	X/R: 4.49		
	VOLTAGE: 4160.	EQUIV. IMPEDANCE=	0.1293 + J 0.5777	OHMS		
	PEL-XFMR02-F	108 PELXFM PRI			0.076 KA	ANG: 100.84
	HV44	102 HV44			0.004 KA	ANG: 99.58
	OE-WL	100 PLANT MAIN SWBD SWB-1			3.977 KA	ANG: -77.34
102 HV44		3P Duty: 3.882 KA AT	-74.50 DEG (27.97 MVA)	X/R: 3.62		
	VOLTAGE: 4160.	EQUIV. IMPEDANCE=	0.1654 + J 0.5962	OHMS		
	HEL-XFMR01-F	BUS-0032			0.004 KA	ANG: 99.57
	HV44	101 FUSE CUT-OUTS			3.878 KA	ANG: -74.49
103L HEL-ATS-01		3P Duty: 7.651 KA AT	-76.15 DEG (6.36 MVA)	X/R: 4.06		
	VOLTAGE: 480.	EQUIV. IMPEDANCE=	0.0087 + J 0.0352	OHMS		
	LOW VOLTAGE POWER CIRCUIT BREAKER	7.651 KA				
	MOLDED CASE CIRCUIT BREAKER < 10KA	9.614 KA				
	MOLDED CASE CIRCUIT BREAKER < 20KA	8.148 KA				
	MOLDED CASE CIRCUIT BREAKER > 20KA	7.651 KA				
	AUTO-0002	BUS-0033			7.618 KA	ANG: -76.13
	MCC1-F	104 MCC-1			0.033 KA	ANG: 99.56
104 MCC-1		3P Duty: 7.270 KA AT	-74.99 DEG (6.04 MVA)	X/R: 3.74		
	VOLTAGE: 480.	EQUIV. IMPEDANCE=	0.0099 + J 0.0368	OHMS		
	LOW VOLTAGE POWER CIRCUIT BREAKER	7.270 KA				
	MOLDED CASE CIRCUIT BREAKER < 10KA	8.948 KA				
	MOLDED CASE CIRCUIT BREAKER < 20KA	7.583 KA				
	MOLDED CASE CIRCUIT BREAKER > 20KA	7.270 KA				
	MCC1-F	103L HEL-ATS-01			7.237 KA	ANG: -74.97
	HEL-PDP01-F	105 HEL-PDP-01			0.033 KA	ANG: 99.55

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

```

=====
105 HEL-PDP-01          3P Duty:  5.882 KA AT  -59.46 DEG (  4.89 MVA) X/R:    1.71
VOLTAGE:   480.  EQUIV. IMPEDANCE=  0.0239 + J  0.0406 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER  5.882 KA
MOLDED CASE CIRCUIT BREAKER < 10KA  5.882 KA
MOLDED CASE CIRCUIT BREAKER < 20KA  5.882 KA
MOLDED CASE CIRCUIT BREAKER > 20KA  5.882 KA
CONTRIBUTIONS:  T.LOAD HEL-PDP01          0.033 KA    ANG:   -80.54
HEL-PDP01-F          104 MCC-1          5.851 KA    ANG:   -59.34

106 HEL-LP-01          3P Duty:  2.269 KA AT  -47.84 DEG (  0.82 MVA) X/R:    1.11
VOLTAGE:   208.  EQUIV. IMPEDANCE=  0.0355 + J  0.0392 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER  2.269 KA
MOLDED CASE CIRCUIT BREAKER < 10KA  2.269 KA
MOLDED CASE CIRCUIT BREAKER < 20KA  2.269 KA
MOLDED CASE CIRCUIT BREAKER > 20KA  2.269 KA
HEL-LP1-F          BUS-0045          2.269 KA    ANG:   -47.84

107 HEL-CPP-01          3P Duty:  0.757 KA AT  -63.65 DEG (  0.27 MVA) X/R:    2.02
VOLTAGE:   208.  EQUIV. IMPEDANCE=  0.0704 + J  0.1422 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER  0.757 KA
MOLDED CASE CIRCUIT BREAKER < 10KA  0.788 KA
MOLDED CASE CIRCUIT BREAKER < 20KA  0.757 KA
MOLDED CASE CIRCUIT BREAKER > 20KA  0.757 KA
HEL-CPP1-F          BUS-0048          0.757 KA    ANG:   -63.65

108 PELXFM PRI          3P Duty:  3.964 KA AT  -76.07 DEG ( 28.56 MVA) X/R:    4.05
VOLTAGE:  4160.  EQUIV. IMPEDANCE=  0.1459 + J  0.5880 OHMS
PEL-XFMR-02          BUS-0088          0.076 KA    ANG:   100.81
PEL-XFMR02-F          101 FUSE CUT-OUTS          3.888 KA    ANG:   -76.01

109 PMC-MCC-02          3P Duty:  7.977 KA AT  -75.66 DEG (  6.63 MVA) X/R:    3.95
VOLTAGE:   480.  EQUIV. IMPEDANCE=  0.0086 + J  0.0337 OHMS
LOW VOLTAGE POWER CIRCUIT BREAKER  7.977 KA
MOLDED CASE CIRCUIT BREAKER < 10KA  9.956 KA
MOLDED CASE CIRCUIT BREAKER < 20KA  8.438 KA
MOLDED CASE CIRCUIT BREAKER > 20KA  7.977 KA
CONTRIBUTIONS:  T.LOAD PMC-MCC-02          0.076 KA    ANG:   -80.54
                  LC-DDMP02          0.295 KA    ANG:   -79.32
                  LC-DDMP01          0.295 KA    ANG:   -79.32
AEL-PDP2-F          110 AEL-PDP-02          0.043 KA    ANG:    99.73
PMC-MCC-02          BUS-0088          7.270 KA    ANG:  -255.29

110 AEL-PDP-02          3P Duty:  4.735 KA AT  -46.25 DEG (  3.94 MVA) X/R:    1.07
  
```

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====						
VOLTAGE:	480.	EQUIV. IMPEDANCE=	0.0405 + J 0.0423	OHMS		
LOW VOLTAGE POWER CIRCUIT BREAKER			4.735	KA		
MOLDED CASE CIRCUIT BREAKER < 10KA			4.735	KA		
MOLDED CASE CIRCUIT BREAKER < 20KA			4.735	KA		
MOLDED CASE CIRCUIT BREAKER > 20KA			4.735	KA		
CONTRIBUTIONS: T.LOAD AEL-PDP02			0.043	KA	ANG:	-80.54
AEL-PDP2-F	109	PMC-MCC-02	4.700	KA	ANG:	-45.96
111 FUSE CUT-OUTS	3P Duty:	4.009 KA AT	-76.91 DEG (28.88 MVA)	X/R:	4.32
VOLTAGE:	4160.	EQUIV. IMPEDANCE=	0.1357 + J 0.5836	OHMS		
T-PS1-F		BUS-0080	0.015	KA	ANG:	99.61
OE-WH		100 PLANT MAIN SWBD SWB-1	3.993	KA	ANG:	-76.90
112 PMC-MCC-01	3P Duty:	5.650 KA AT	-77.45 DEG (4.70 MVA)	X/R:	4.50
VOLTAGE:	480.	EQUIV. IMPEDANCE=	0.0107 + J 0.0479	OHMS		
LOW VOLTAGE POWER CIRCUIT BREAKER			5.650	KA		
MOLDED CASE CIRCUIT BREAKER < 10KA			7.277	KA		
MOLDED CASE CIRCUIT BREAKER < 20KA			6.167	KA		
MOLDED CASE CIRCUIT BREAKER > 20KA			5.650	KA		
CONTRIBUTIONS: T.LOAD PMC-MCC-01			0.078	KA	ANG:	-80.54
PEL-PDP-F	114	PEL-PDP-01	0.028	KA	ANG:	99.59
AEL-PDP1-F	113	AEL-PDP-01	0.028	KA	ANG:	99.76
T-PS1		BUS-0080	5.515	KA	ANG:	-257.38
113 AEL-PDP-01	3P Duty:	3.136 KA AT	-44.58 DEG (2.61 MVA)	X/R:	1.01
VOLTAGE:	480.	EQUIV. IMPEDANCE=	0.0629 + J 0.0620	OHMS		
LOW VOLTAGE POWER CIRCUIT BREAKER			3.136	KA		
MOLDED CASE CIRCUIT BREAKER < 10KA			3.136	KA		
MOLDED CASE CIRCUIT BREAKER < 20KA			3.136	KA		
MOLDED CASE CIRCUIT BREAKER > 20KA			3.136	KA		
CONTRIBUTIONS: T.LOAD AEL-PDP01			0.028	KA	ANG:	-80.54
AEL-PDP1-F	112	PMC-MCC-01	3.113	KA	ANG:	-44.27
114 PEL-PDP-01	3P Duty:	4.450 KA AT	-57.62 DEG (3.70 MVA)	X/R:	1.59
VOLTAGE:	480.	EQUIV. IMPEDANCE=	0.0334 + J 0.0526	OHMS		
LOW VOLTAGE POWER CIRCUIT BREAKER			4.450	KA		
MOLDED CASE CIRCUIT BREAKER < 10KA			4.450	KA		
MOLDED CASE CIRCUIT BREAKER < 20KA			4.450	KA		
MOLDED CASE CIRCUIT BREAKER > 20KA			4.450	KA		
CONTRIBUTIONS: T.LOAD PEL-PDP01			0.028	KA	ANG:	-80.54
PEL-PDP-F	112	PMC-MCC-01	4.424	KA	ANG:	-57.47
115 SEL-PDP-11	3P Duty:	5.570 KA AT	-75.97 DEG (4.63 MVA)	X/R:	4.14
VOLTAGE:	480.	EQUIV. IMPEDANCE=	0.0121 + J 0.0483	OHMS		

THREE PHASE FAULT REPORT
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

=====					
	LOW VOLTAGE POWER CIRCUIT BREAKER	5.570 KA			
	MOLDED CASE CIRCUIT BREAKER < 10KA	7.032 KA			
	MOLDED CASE CIRCUIT BREAKER < 20KA	5.959 KA			
	MOLDED CASE CIRCUIT BREAKER > 20KA	5.570 KA			
	CONTRIBUTIONS: T.LOAD SEL-PDP-11		0.223 KA	ANG:	-84.29
	SEL-PDP-F	BUS-0079	5.349 KA	ANG:	-255.63
116 SEL-LP-12	3P Duty: 1.956 KA AT -71.34 DEG (0.81 MVA)		X/R:	2.97	
	VOLTAGE: 240. EQUIV. IMPEDANCE= 0.0227 + J 0.0671 OHMS				
	LOW VOLTAGE POWER CIRCUIT BREAKER	1.956 KA			
	MOLDED CASE CIRCUIT BREAKER < 10KA	2.267 KA			
	MOLDED CASE CIRCUIT BREAKER < 20KA	1.956 KA			
	MOLDED CASE CIRCUIT BREAKER > 20KA	1.956 KA			
	SEL-LP12-F	BUS-0052	1.956 KA	ANG:	-71.34
117 SEL-CPP-11	3P Duty: 0.755 KA AT -64.52 DEG (0.27 MVA)		X/R:	2.10	
	VOLTAGE: 208. EQUIV. IMPEDANCE= 0.0684 + J 0.1436 OHMS				
	LOW VOLTAGE POWER CIRCUIT BREAKER	0.755 KA			
	MOLDED CASE CIRCUIT BREAKER < 10KA	0.795 KA			
	MOLDED CASE CIRCUIT BREAKER < 20KA	0.755 KA			
	MOLDED CASE CIRCUIT BREAKER > 20KA	0.755 KA			
	SEL-CPP11-F	BUS-0055	0.755 KA	ANG:	-64.52
BUS-0082	3P Duty: 4.057 KA AT -77.38 DEG (29.23 MVA)		X/R:	4.49	
	VOLTAGE: 4160. EQUIV. IMPEDANCE= 0.1293 + J 0.5777 OHMS				
	SEL-XFMR01-F	BUS-0078	0.025 KA	ANG:	-83.98
	CBL-0061	100 PLANT MAIN SWBD SWB-1	4.032 KA	ANG:	-77.34
CPS ENERGY	3P Duty: 2.947 KA AT -67.01 DEG (70.43 MVA)		X/R:	2.38	
	VOLTAGE: 13800. EQUIV. IMPEDANCE= 1.0559 + J 2.4893 OHMS				
	CONTRIBUTIONS: CPS UTI2		2.912 KA	ANG:	-66.85
	CPS-XFMR-01	100 PLANT MAIN SWBD SWB-1	0.036 KA	ANG:	-80.43

F A U L T S T U D Y S U M M A R Y
 (FOR APPLICATION OF LOW VOLTAGE BREAKERS)
 PRE FAULT VOLTAGE: 1.0000
 MODEL TRANSFORMER TAPS: NO

BUS RECORD NO NAME	V O L T A G E A V A I L A B L E			F A U L T D U T I E S (KA)	
	L-L	3 PHASE	X/R	LINE/GRND	X/R
001 AMC-MCC-01A	4160.	10.089	8.53		
002 LC-AASBC01	4160.	9.951	7.95		
003 LC-AASBC02	4160.	9.951	7.95		
005 AEL-PDP-11A	480.	9.752	4.74		
006 AIS-LCP-01	480.	8.469	2.27		
007 AIS-LCP-02	480.	8.469	2.27		
008L AEL-ATS-01	480.	9.333	3.88		
009 AEL-PDP-12	480.	8.901	3.28		
010 AEL-LP-11	208.	5.213	0.71		
011 AEL-CPP-11	208.	1.505	2.39		
012 AEL-MPC-01	208.	1.414	2.02		
013 AEL-MPC-02	208.	1.304	1.65		
014 AMC-MCC-01B	4160.	10.064	8.50		
015 AEL-PDP-11B	480.	9.751	4.74		
016 AIS-LCP-03	480.	8.468	2.27		
017 AIS-LCP-04	480.	8.468	2.27		
018 LC-AASBC03	4160.	9.927	7.93		
019 LC-AASBC04	4160.	9.927	7.93		
100 PLANT MAIN SWBD SWB-1	4160.	4.057	4.49		
101 FUSE CUT-OUTS	4160.	4.057	4.49		
102 HV44	4160.	3.882	3.62		
103L HEL-ATS-01	480.	7.651	4.06		
104 MCC-1	480.	7.270	3.74		
105 HEL-PDP-01	480.	5.882	1.71		
106 HEL-LP-01	208.	2.269	1.11		
107 HEL-CPP-01	208.	0.757	2.02		
108 PELXFM PRI	4160.	3.964	4.05		
109 PMC-MCC-02	480.	7.977	3.95		
110 AEL-PDP-02	480.	4.735	1.07		
111 FUSE CUT-OUTS	4160.	4.009	4.32		
112 PMC-MCC-01	480.	5.650	4.50		
113 AEL-PDP-01	480.	3.136	1.01		
114 PEL-PDP-01	480.	4.450	1.59		
115 SEL-PDP-11	480.	5.570	4.14		
116 SEL-LP-12	240.	1.956	2.97		
117 SEL-CPP-11	208.	0.755	2.10		
BUS-0082	4160.	4.057	4.49		
CPS ENERGY	13800.	2.947	2.38		


69 FAULTED BUSES, 89 BRANCHES, 22 CONTRIBUTIONS


*** SHORT CIRCUIT STUDY COMPLETE ***

APPENDIX D: REFERENCES


I. SCHNEIDER ELECTRIC ENGINEERING SERVICES, LLC

- 1 Response to Consultant Engineer review comments
- 2 Time Margins for Solid State Relays
- 3 Time Margins for Induction Disk Relays
- 4 Trip Dials for Micrologic 6.0, 6.0A, 6.0P, 6.0H
- 5 Trip Dials for LX, LXI, and MX
- 6 Trip Dials for Electronic Trip ET1.0 & ET1.0I
- 7 Trip Dials for Molded Case Breakers
- 8 Setpoint file for MULTILIN SR469 relays





TRIP ADJUSTMENT DIALS FOR MICROLOGIC 6.0, 6.0A, 6.0P, & 6.0H TRIP UNITS




Notes

ln = sensor
 lr = long time pickup setting
 tr = long time delay setting
 lsd = short time pickup setting
 tsd = short time delay setting
 li = instantaneous setting
 lg = ground fault pickup setting
 tg = ground fault delay setting

1) Eight interchangeable rating plugs are available to limit the long-time pickup setting range for greater versatility. (Type A is the standard plug and corresponds to settings shown above.)

2) P and H trip units also have protective relay features and selectable long-time delay bands such as $I^4 T$. These settings are programmed in through a keypad or computer link.


**TRIP ADJUSTMENT DIALS FOR
250A, 400A & 600A FRAME
LX & LXI MICROLOGIC CIRCUIT BREAKERS**



micrologic® STANDARD SERIES B

P = Rating Plug Amps
S = Sensor Rating Amps

**TRIP ADJUSTMENT DIALS FOR
250A, 400A & 800A FRAME
MX MICROLOGIC CIRCUIT BREAKERS**




micrologic® STANDARD SERIES B


P = Rating Plug Amps
S = Sensor Rating Amps

*The maximum instantaneous setting for new LX 600A frame breakers is 7

TRIP ADJUSTMENT DIAL FOR M-FRAME, ET1.0



TRIP ADJUSTMENT DIAL FOR P- AND R-FRAME, ET1.0I










Notes

li = instantaneous setting

MOLDED CASE CIRCUIT BREAKERS

MAGNETIC (INSTANTANEOUS) TRIP ADJUSTMENT DIALS
(ON FRONT OF BREAKER)



NOTE: THE "LO" AND "HI" MARKINGS APPEAR ON THE DIAL FACES.
THE MARKINGS IN PARENTHESES DO NOT.

SETTINGS SHOWN ARE FOR ILLUSTRATION ONLY

SAWS LEON CREEK 08312010.469

C:\DOCUMENTS AND SETTINGS\ALL USERS\DOCUMENTS\GE POWER MANAGEMENT\469PC\

DEVICE DEFINITION**ORDER CODE: 469****VERSION: 5.1X****SERIAL NUMBER: (NONE)****DESCRIPTION: BLOWER MOTOR****TEXT COLOR**

469 SETUP

PREFERENCES

Default Message Cycle Time	2.0 s
Default Message Timeout	300 s
Average Motor Load Calculation Period	15 min
Temperature Display Units	Celsius
Trace Memory Trigger Position	25 %
Trace Memory Buffers	8 x 28 cycles
Display Update Interval	0.4 s
Motor Load Filter Interval	0 cycles

MESSAGE SCRATCHPAD

First Scratchpad Message
 Second Scratchpad Message
 Third Scratchpad Message
 Fourth Scratchpad Message
 Fifth Scratchpad Message

COMMUNICATION

Ethernet Subnet Mask	255.255.255. 0
DeviceNet MAC ID	1
DeviceNet Baud Rate	125 kbps
Front RS232 baud rate	19200 baud
Slave Address	254
Computer RS485 Baud Rate	9600 baud
Computer RS485 Parity	None
Auxiliary RS485 Baud Rate	9600 baud
Auxiliary RS485 Parity	None

SYSTEM SETUP

CURRENT SENSING

Phase CT Primary	250 A
Motor Full Load Amps	109 A
Ground CT Type	5 A Secondary
Ground CT Primary	50 A
Phase Differential CT Type	None

VOLTAGE SENSING

VoltageTransformer Connection Type	Wye
Voltage Transformer Ratio	35.00 :1
Motor Nameplate Voltage	4160 V

POWER SYSTEM

Nominal System Frequency	60 Hz
System Phase Sequence	ABC

REDUCED VOLTAGE

Reduced Voltage Starting	On/Yes
Control Relays for Reduced Voltage Starting	Auxiliary 2
Transition On	Current Only
Reduced Voltage Start Level	120 % FLA
Reduced Voltage Start Timer	30 s
Incomplete Sequence Trip Relays	Trip

DIGITAL INPUTS

STARTER

Starter Status Switch	Start Aux b
-----------------------	-------------

OUTPUT RELAYS

TRIP RELAY

Force R1 Operate Time	0 s
-----------------------	-----

ALARM RELAY

Force R4 Operate Time	0 s
-----------------------	-----

AUX RELAY 2

Force R2 Output Operate Time	0 s
------------------------------	-----

AUX RELAY 3

Force R3 Operate Time	0 s
-----------------------	-----

SAWS LEON CREEK 08312010.469

C:\DOCUMENTS AND SETTINGS\ALL USERS\DOCUMENTS\GE POWER MANAGEMENT\469PC\

DEVICE DEFINITION**ORDER CODE: 469****VERSION: 5.1X****SERIAL NUMBER: (NONE)****DESCRIPTION: BLOWER MOTOR****TEXT COLOR**BLOCK START RELAY

Force R5 Operate Time 0 s

PROTECTION

THERMAL MODEL

469 THERMAL MODEL

Curve Style	Standard
Overload Pickup Level	1.15 FLA
Cool Time Constant Running	15 min
Cool Time Constant Stopped	30 min
Hot/Cold Safe Stall Ratio	1.00
Thermal Capacity Alarm Relays	Alarm
Thermal Capacity Alarm Level	75 % used
Overload Trip Relays	Trip

OVERLOAD CURVE

Standard Overload Curve Number 2

MECHANICAL JAM

Mechanical Jam Trip	Latched
Mechanical Jam Trip Relays	Trip
Mechanical Jam Pickup	2.50 xFLA
Mechanical Jam Delay	5 s

UNDERCURRENT

Block Undercurrent from Start 0 s

CURRENT UNBALANCE

Current Unbalance Alarm	Unlatched
Current Unbalance Alarm Relays	Alarm
Current Unbalance Alarm Pickup	15 %
Current Unbalance Alarm Delay	5 s
Current Unbalance Alarm Events	On/Yes
Current Unbalance Trip	Latched
Current Unbalance Trip Relays	Trip
Current Unbalance Trip Pickup	20 %
Current Unbalance Trip Delay	10 s

GROUND FAULT

Ground Fault Trip	Latched
Ground Fault Trip Relays	Trip
Ground Fault Trip Pickup	0.30 CT
Intentional GF Trip Delay	10 ms

JOGGING BLOCK

Jogging Block	On/Yes
Maximum Starts/Hour Permissible	3
Time Between Starts	10 min

RTD TEMPERATURE

RTD TYPES

Stator RTD Type	100 Ohm Platinum
Bearing RTD Type	100 Ohm Platinum
Ambient RTD Type	100 Ohm Platinum
Other RTD Type	100 Ohm Platinum

RTD #1

RTD #1 Application None

RTD #2

RTD #2 Application	Stator
RTD #2 Name	

RTD #3

RTD #3 Application	Stator
RTD #3 Name	

RTD #4

RTD #4 Application None

RTD #5

SAWS LEON CREEK 08312010.469

C:\DOCUMENTS AND SETTINGS\ALL USERS\DOCUMENTS\GE POWER MANAGEMENT\469PC\

DEVICE DEFINITION**ORDER CODE: 469****VERSION: 5.1X****SERIAL NUMBER: (NONE)****DESCRIPTION: BLOWER MOTOR****TEXT COLOR**RTD #5 (continued from last page)

RTD #5 Application	Stator
RTD #5 Name	

RTD #6

RTD #6 Application	Stator
RTD #6 Name	

RTD #7

RTD #7 Application	Bearing
RTD #7 Name	

RTD #8

RTD #8 Application	Bearing
RTD #8 Name	

RTD #9

RTD #9 Application	Bearing
RTD #9 Name	

RTD #10

RTD #10 Application	Bearing
RTD #10 Name	

RTD #11

RTD #11 Application	Other
RTD #11 Name	

RTD #12

RTD #12 Application	Ambient
RTD #12 Name	

POWER ELEMENTSPOWER FACTOR

Block Power Factor Element from Start	1 s
---------------------------------------	-----

REACTIVE POWER

Block kvar Element from Start	1 s
-------------------------------	-----

UNDERPOWER

Block Underpower From Start	0 s
-----------------------------	-----

REVERSE POWER

Block Reverse Power From Start	0 s
--------------------------------	-----

TORQUE SETUP

Stator Resistance	0.004 mOhm
Pole Pairs	2
Torque Unit	Newton-meter

OVERTORQUE SETUP

Overtorque Alarm Relays	Alarm
Overtorque Alarm Level	4000.0 Nm
Overtorque Alarm Delay	1.0 s

CURRENT DEMAND

Current Demand Period	15 min
-----------------------	--------

KW DEMAND

kW Demand Period	15 min
------------------	--------

KVAR DEMAND

kvar Demand Period	15 min
--------------------	--------

KVA DEMAND

kVA Demand Period	15 min
-------------------	--------

ANALOG OUTPUTS

Analog Output 1 Selection	None
Analog Output 2 Selection	None
Analog Output 3 Selection	None

SAWS LEON CREEK 08312010.469

C:\DOCUMENTS AND SETTINGS\ALL USERS\DOCUMENTS\GE POWER MANAGEMENT\469PC\

DEVICE DEFINITION**ORDER CODE: 469****VERSION: 5.1X****SERIAL NUMBER: (NONE)****DESCRIPTION: BLOWER MOTOR****TEXT COLOR**

ANALOG OUTPUTS (continued from last page)

Analog Output 4 Selection None

TWO SPEED MOTOR**SPEED 2 OVERLOAD**

Speed2 Standard Overload Curve Number 4

SPEED 2 UNDERCURRENT

Block Speed2 Undercurrent from Start 0 s

Speed2 Undercurrent Alarm Pickup 0.70 FLA

Speed2 Undercurrent Alarm Delay 1 s

Speed2 Undercurrent Trip Pickup 0.70 FLA


Speed2 Undercurrent Trip Delay 1 s

SPEED 2 ACCELERATION

Speed2 Acceleration Timer From Start 10.0 s

Acceleration Timer From Speed One to Two 10.0 s

APPENDIX E: SYSTEM STUDY ONE-LINE DIAGRAMS



- NOTES:
- 1) SCA - MAXIMUM AVAILABLE THREE-PHASE RMS SYMMETRICAL SHORT-CIRCUIT AMPERES.
 - 2) [Symbol] - BUS IDENTIFICATION NUMBER USED BY COMPUTER PROGRAM WHEN PERFORMING SHORT-CIRCUIT ANALYSIS.
 - 3) [Symbol] - DEVICE IDENTIFICATION NUMBER USED BY COMPUTER PROGRAM WHEN PERFORMING TIME-CURRENT COORDINATION ANALYSIS.
 - 4) ALL LOW-VOLTAGE CABLES WERE CONSIDERED TO BE TYPE THHN, SINGLE CONDUCTOR COPPER, RUN IN STEEL CONDUIT, UNLESS OTHERWISE NOTED.
 - 5) ALL DEVICES WERE CONSIDERED TO BE THREE-POLE UNLESS OTHERWISE NOTED.
 - 6) AF DENOTES AMPERE FRAME RATING
AS DENOTES AMPERE SENSOR RATING
AP DENOTES AMPERE PLUG RATING
AT DENOTES AMPERE TRIP RATING
 - 7) L DENOTES LONG TIME FUNCTION
S DENOTES SHORT TIME FUNCTION
I DENOTES INSTANTANEOUS FUNCTION
G DENOTES GROUND FUNCTION
 - 8) KVAm - CONNECTED MOTOR KVA USED FOR FAULT CALCULATIONS (1 HP = 1 KVAm).
 - 9) [Symbol] TIME-CURRENT CURVE SERIES CIRCUITS ILLUSTRATED IN REPORT.
 - 10) (*) DENOTES ASSUMED INFORMATION.

5					
4					
3					
2	07/12/11			BMH	SM
1	08/17/11			BMH	SM
-	01/24/11			HEH	SM
REV. LEVEL	DATE	DESCRIPTION	DRAWN	CHKD.	

Square D
Engineering Services


SUITE B-325
2365 HARRODSBURG ROAD
LEXINGTON, KENTUCKY 40504

SAWS LEON CREEK WRC
SAN ANTONIO, TX

ONE - LINE DIAGRAM
SCALE: NTS

D-ML-10-660-1

PLANT MAIN DISTRIBUTION SWITCHBOARD SWB-1



SQUARE D
Engineering Services
by Schneider Electric

Square D
Engineering Services
SUITE B-325
2365 HARRODSBURG ROAD
LEXINGTON, KENTUCKY 40504
ONE - LINE DIAGRAM
SCALE
NTS
D-ML-10-660-2