



SAN ANTONIO WATER SYSTEM
DSP Clayton Tank Replacement Project
SAWS Job No. 14-6101
Solicitation No. CO-00028

ADDENDUM NO. 8
November 9, 2015

TO BIDDER OF RECORD:

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the SAWS DSP Clayton Tank Replacement Project, for the San Antonio Water System, San Antonio, Texas, Dated October 2015, as fully and completely as if the same were set forth therein.

BIDDING AND CONTRACT DOCUMENTS

1. CLARIFICATION - PERIMETER DRAIN

The 6" diameter perimeter drain shown on Sheet M-SPS-9 is for the chlorine building. The 4" diameter perimeter drain shown in Addendum No. 4 is for the Ground Storage Tank (GST). Both perimeter drains discharge into the GST overflow box.

ACKNOWLEDGEMENT BY BIDDER

THE UNDERSIGNED ACKNOWLEDGES RECEIPT OF THIS ADDENDUM NO. 7 AND THE BID SUBMITTED HERewith IS IN ACCORDANCE WITH THE INFORMATION AND STIPULATION SET FORTH.

Date

Signature of bidder

END OF ADDENDUM NO. 8

