



King Street Pump Station Improvements (Volume I) & ASR Lime System Improvements (Volume II) - RFCSP

Solicitation Number: CO-00670

Job No.: 20-6002

and 22-8603

ADDENDUM 8

November 21, 2023

To Respondent of Record:

This addendum, applicable to work referenced above, is an amendment to the price proposal, plans and specifications and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the Addendum number and issue date on the space provided in submitted copies of the Respondent Questionnaire.

CHANGES TO THE SPECIFICATIONS

1. SECTION 15090 COMMON REQUIRMENTS FOR PROCESS VALVES:
 - Paragraph 2.2. C.1; DELETE the sentence "1. Manufacturers: Beck, EMI, or Limitorque" and REPLACE with "1. Manufacturers: Beck, EMI, Limitorque, or EIM(M2CP)".
2. SECTION 15103 AWWA BALL VALVES:
 - Paragraph 1.03.C.8.a; DELETE the sentence "a) Electric operators; full compliance with AWWA C540" in its entirety and REPLACE with "a) Electric operators; full compliance with AWWA C542".
 - Paragraph 2.01.B; DELETE item "3. No approved equals" and REPLACE with the following "3. EIM (M2CP Series)".

END OF ADDENDUM

This Addendum is one (1) page in its entirety.



MKS 11/21/2023

Mythri Krishnamoorthysujatha, P.E.
Tetra Tech