



- NOTE:
1. BUTTERFLY VALVES WILL BE USED ONLY IF DIAMETER OF STEEL PIPING IS 20" OR GREATER. OTHERWISE GATE VALVES WILL BE INSTALLED.
 2. SIZE OF STEEL PIPING SHALL BE DETERMINED BY ENGINEER.

DD-903-06	SAN ANTONIO WATER SYSTEM SAN ANTONIO, TEXAS	APPROVED: MARCH 2011
SHEET 1 OF 1	ELEVATED STORAGE TANK - FLOOR PLAN	REVISED:

