



NOTE:

1. ALL GAUGES TO BE GLYCOL FILLED AT A 4" MIN.
2. ALL GAUGES MUST READ PRESSURE IN POUNDS PER SQUARE INCH (PSI) AND FEET OF WATER.

DD-903-22

SAN ANTONIO WATER SYSTEM
SAN ANTONIO, TEXAS



APPROVED:
MARCH 2011

SHEET
1 OF 1

PRESSURE GAUGE

REVISED: