



NOTE:  
 FITTINGS AND PIPE SIZE TO BE DETERMINED BY ENGINEER.

SIDE VIEW  
 SECTION AA

NOTE:  
 20" AND SMALLER, USE GATE VALVE, FLG.  
 24" AND LARGER, USE BUTTERFLY VALVE, FLG.

|   |                            |  |           |                 |
|---|----------------------------|--|-----------|-----------------|
| PROPERTY OF<br>SAN ANTONIO WATER SYSTEM<br>SAN ANTONIO, TEXAS | ALTITUDE VALVE<br>ASSEMBLY |  | APPROVED  | REVISED         |
|   |                            |  | 7-14-00   |                 |
|   |                            |  | DD-901-04 | SHEET<br>1 OF 3 |