



VAULT DETAIL

NOTES:

1. CENTER OF RUNGS MUST PROVIDE 7" MINIMUM TOE CLEARANCE FROM CONCRETE VAULT WALL.
2. CONTRACTOR TO VERIFY ALL DIMENSIONS PRIOR TO FABRICATION.

PROPERTY OF SAN ANTONIO WATER SYSTEM SAN ANTONIO, TEXAS	VAULT LADDER DETAILS	APPROVED	REVISED	
		7-14-00	9-09-04	11-23-04
		DD-900-13		SHEET 6 OF 11