



BROOKS RECYCLED WATER PUMP STATION UPGRADES PROJECT (REBID)

Solicitation Number: CO-00687

Job No.: 21-8601

ADDENDUM 4

October 11, 2023

To Bidder of Record:

This addendum, applicable to work referenced above, is an amendment to the bid proposal, plans and specifications and as such will be a part of and included in the Contract Documents. Acknowledge receipt of this addendum by entering the Addendum number and issue date on the space provided in submitted copies of the bid proposal.

RESPONSES TO QUESTIONS

- 1. Question: On Sheet E-08, for DS-BAR-01; one-line shows the circuit breaker as a 1200A ACB, meaning air circuit breaker that will require it to be a 1-section switchboard. The site plan E-05 shows it being mounted on a rack outside of the transformer foundation which can't be utilized for switchboard.**

Response: The 1200A CB is not meant to be an Air Circuit Breaker – the contractor can furnish a 1200A molded case circuit breaker in a NEMA 3R 316SS Enclosure that meets the requirements of this installation.

- 2. Question: On Sheet E-08 there is a Keynote #10 at DS-BAR-01, but it is not listed on the coded notes. What are the intentions or requirements for this circuit breaker? If it is to be a switchboard, switchboard section to be fabricated in a NEMA 4X 316SS enclosure would increase the equipment pricing outrageously high, would NEMA 3R 316SS be acceptable?**

Response: Keynote 10 ID was removed from the drawing in Addendum 3. The intention of the circuit breaker is to open upon overcurrent situation. A NEMA 3R 316SS enclosure that meets the requirements of this installation is acceptable.

CHANGES TO THE SPECIFICATIONS

1. Revision to Invitation to Bidders

- a. Revise the first sentence of the 7th paragraph to read as follows:

“Bids will be received either Electronically or through Sealed bids, until 10:00 AM (CDT), October 18, 2023.”

- b. Revise the last paragraph to read as follows:

“If Bidders intend to submit bids electronically, Bidders will need to submit a request by October 17, 2023 at 10:00 AM (CDT) to receive access to the File Transfer Protocol (FTP) site via email to Janie.Powell@saws.org. Bidder’s email requesting access to the FTP site shall provide the legal name of Bidder’s company and the intended recipient’s email address and phone number. No requests for FTP site access will be accepted after October 17, 2023 at 10:00 AM (CDT).”

2. Revision to Electronic Bid Opening Instructions

- a. Revise the header to read:

“October 18, 2023 at 10:00 am”

- b. Revise the 1st paragraph to read:


“In order to receive electronic bids for this project, SAWS will utilize a SAWS secured File Transfer Protocol (FTP) site. Only Bidders bidding as Prime Contractors will need to submit their request prior to 10:00 a.m. (CDT) **October 17, 2023**, to receive access to the FTP site via email to Janie.Powell@saws.org. Bidder’s email shall provide the legal name of the Bidder’s company and the intended recipient’s email address and phone number. No requests for FTP site access will be accepted after 10:00 a.m. (CDT) **October 17, 2023**. Once a Bidder is approved for access, an email with a hyperlink to the FTP site and a unique password for the Bidder will be provided to the Bidder’s email recipient.”

- c. Revise the 2nd paragraph to read:

“Once access is received, Bidders may upload the required documents per the Bid Proposal checklist any time before 10:00 am (CDT), **October 18, 2023**. Please ensure to allow sufficient time should Bidder’s experience technical difficulties in uploading the required documents. No changes to the Bid nor bid price can be made once the Bid has been received by SAWS.”

END OF ADDENDUM

This Addendum, including these pages, is two (2) pages in its entirety.


V. Ryan Sowa
Kimley-Horn & Associates

